



Langdon Education Campus Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-009061	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 101	Low Left	WF-09132021-009061	12/23/2021	FT-FY22-12012021-009061-A	<1	FT-FY22-12012021-009061-B	<1
WS-009062	4/6/2021	4/6/2022	1	Combo Fountain	In classroom 101	Low Mid	WF-04062021-009062	12/23/2021	FT-FY22-12012021-009062-A	<1	FT-FY22-12012021-009062-B	<1
WS-009063	9/13/2021	9/13/2022	1	Classroom Faucet	In classroom 101	High Right	WF-09132021-009063	12/23/2021	FT-FY22-12012021-009063-A	<1	FT-FY22-12012021-009063-B	<1
WS-009064	9/13/2021	9/13/2022	1	Classroom Faucet	In classroom 102	High Left	WF-09132021-009064	12/23/2021	FT-FY22-12012021-009064-A	<1	FT-FY22-12012021-009064-B	<1
WS-009065	4/6/2021	4/6/2022	1	Combo Fountain	In classroom 102	Low Mid	WF-04062021-009065	12/23/2021	FT-FY22-12012021-009065-A	<1	FT-FY22-12012021-009065-B	<1
WS-009066	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 102	Low Right	WF-09132021-009066	12/23/2021	FT-FY22-12012021-009066-A	<1	FT-FY22-12012021-009066-B	<1
WS-009067	4/6/2021	4/6/2022	1	Break Room	In staff work room 113		WF-04062021-009067	12/23/2021	FT-FY22-12012021-009067-A	<1	FT-FY22-12012021-009067-B	<1
WS-009068	4/6/2021	4/6/2022	1	Cooler	In hallway adjacent to room 104	High Left	WF-04062021-009068	12/23/2021	FT-FY22-12012021-009068-A	<1	FT-FY22-12012021-009068-B	<1
WS-009069	4/6/2021	4/6/2022	1	Cooler	In hallway adjacent to room 104	Low Right	WF-04062021-009069	12/23/2021	FT-FY22-12012021-009069-A	<1	FT-FY22-12012021-009069-B	<1
WS-009070	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 104	Low Left	WF-09132021-009070	12/23/2021	FT-FY22-12012021-009070-A	<1	FT-FY22-12012021-009070-B	<1
WS-009072	9/13/2021	9/13/2022	1	Classroom Faucet	In classroom 104	High Right	WF-09132021-009072	12/23/2021	FT-FY22-12012021-009072-A	<1	FT-FY22-12012021-009072-B	<1
WS-009073	9/13/2021	9/13/2022	1	Classroom Faucet	In classroom 106	High Left	WF-09132021-009073	12/23/2021	FT-FY22-12012021-009073-A	<1	FT-FY22-12012021-009073-B	<1
WS-009074	4/6/2021	4/6/2022	1	Combo Fountain	In classroom 106	Low Mid	WF-04062021-009074	12/23/2021	FT-FY22-12012021-009074-A	1.4	FT-FY22-12012021-009074-B	<1
WS-009075	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 106	Low Right	WF-09132021-009075	12/23/2021	FT-FY22-12012021-009075-A	<1	FT-FY22-12012021-009075-B	<1
WS-009077	4/6/2021	4/6/2022	1	Cooler	In hallway across from room 105	Low Right	WF-04062021-009077	12/23/2021	FT-FY22-12012021-009077-A	<1	FT-FY22-12012021-009077-B	<1
WS-009078	9/13/2021	9/13/2022	1	Classroom Faucet	In classroom 107	High Left	WF-09132021-009078	12/23/2021	FT-FY22-12012021-009078-A	<1	FT-FY22-12012021-009078-B	<1
WS-009079	4/6/2021	4/6/2022	1	Combo Fountain	In classroom 107	Low Mid	WF-04062021-009079	12/23/2021	FT-FY22-12012021-009079-A	<1	FT-FY22-12012021-009079-B	<1
WS-009080	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 107	Low Right	WF-09132021-009080	12/23/2021	FT-FY22-12012021-009080-A	<1	FT-FY22-12012021-009080-B	<1
WS-009081	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 108	Low Left	WF-09132021-009081	12/23/2021	FT-FY22-12012021-009081-A	<1	FT-FY22-12012021-009081-B	<1
WS-009082	4/6/2021	4/6/2022	1	Combo Fountain	In classroom 108	Low Mid	WF-04062021-009082	12/23/2021	FT-FY22-12012021-009082-A	2.0	FT-FY22-12012021-009082-B	<1
WS-009083	9/13/2021	9/13/2022	1	Classroom Faucet	In classroom 108	High Right	WF-09132021-009083	12/23/2021	FT-FY22-12012021-009083-A	<1	FT-FY22-12012021-009083-B	<1
WS-009084	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 109	Low Left	WF-09132021-009084	12/23/2021	FT-FY22-12012021-009084-A	<1	FT-FY22-12012021-009084-B	<1
WS-009085	4/6/2021	4/6/2022	1	Combo Fountain	In classroom 109	Low Mid	WF-04062021-009085	12/23/2021	FT-FY22-12012021-009085-A	<1	FT-FY22-12012021-009085-B	<1
WS-009086	9/13/2021	9/13/2022	1	Classroom Faucet	In classroom 109	High Right	WF-09132021-009086	12/23/2021	FT-FY22-12012021-009086-A	<1	FT-FY22-12012021-009086-B	<1
WS-009087	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 110	Low Left	WF-09132021-009087	12/23/2021	FT-FY22-12012021-009087-A	<1	FT-FY22-12012021-009087-B	<1
WS-009088	4/6/2021	4/6/2022	1	Combo Fountain	In classroom 110	Low Mid	WF-04062021-009088	12/23/2021	FT-FY22-12012021-009088-A	<1	FT-FY22-12012021-009088-B	<1
WS-009089	9/13/2021	9/13/2022	1	Classroom Faucet	In classroom 110	High Right	WF-09132021-009089	12/23/2021	FT-FY22-12012021-009089-A	<1	FT-FY22-12012021-009089-B	<1
WS-009090	9/13/2021	9/13/2022	1	Classroom Faucet	In resource room 103	High Left	WF-09132021-009090	12/23/2021	FT-FY22-12012021-009090-A	<1	FT-FY22-12012021-009090-B	<1
WS-009091	4/6/2021	4/6/2022	1	Combo Fountain	In resource room 103	Low Mid	WF-04062021-009091	12/23/2021	FT-FY22-12012021-009091-A	<1	FT-FY22-12012021-009091-B	<1
WS-009092	9/13/2021	9/13/2022	1	Combo Faucet	In resource room 103	Low Right	WF-09132021-009092	12/23/2021	FT-FY22-12012021-009092-A	<1	FT-FY22-12012021-009092-B	<1
WS-009095	4/6/2021	4/6/2022	1	Cooler	In hallway across from room 154	Low Right	WF-04062021-009095	12/23/2021	FT-FY22-12012021-009095-A	<1	FT-FY22-12012021-009095-B	<1
WS-009096	4/6/2021	4/6/2022	1	Break Room	In staff work room 154		WF-04062021-009096	12/23/2021	FT-FY22-12012021-009096-A	<1	FT-FY22-12012021-009096-B	<1
WS-009097	4/6/2021	4/6/2022	2	Cooler	In hallway across from room 254	High Left	WF-04062021-009097	12/23/2021	FT-FY22-12012021-009097-A	<1	FT-FY22-12012021-009097-B	<1
WS-009098	4/6/2021	4/6/2022	2	Cooler	In hallway across from room 254	Low Right	WF-04062021-009098	12/23/2021	FT-FY22-12012021-009098-A	<1	FT-FY22-12012021-009098-B	<1
WS-009099	4/6/2021	4/6/2022	2	Break Room	In staff work room 254		WF-04062021-009099	12/23/2021	FT-FY22-12012021-009099-A	<1	FT-FY22-12012021-009099-B	<1
WS-009102	4/6/2021	4/6/2022	2	Combo Fountain	In science lab room 247 second clockwise from entry door		WF-04062021-009102	12/23/2021	FT-FY22-12012021-009102-A	<1	FT-FY22-12012021-009102-B	<1
WS-009106	4/6/2021	4/6/2022	2	Break Room	In classroom 209		WF-04062021-009106	12/23/2021	FT-FY22-12012021-009106-A	<1	FT-FY22-12012021-009106-B	<1

WS-009107	4/6/2021	4/6/2022	2	Cooler	In hallway adjacent to room 204	High Left	WF-04062021-009107	12/23/2021	FT-FY22-12012021-009107-A	<1	FT-FY22-12012021-009107-B	<1
WS-009108	4/6/2021	4/6/2022	2	Cooler	In hallway adjacent to room 204	Low Right	WF-04062021-009108	12/23/2021	FT-FY22-12012021-009108-A	<1	FT-FY22-12012021-009108-B	<1
WS-009109	4/6/2021	4/6/2022	2	Cooler	In hallway across from room 212	High Left	WF-04062021-009109	12/23/2021	FT-FY22-12012021-009109-A	<1	FT-FY22-12012021-009109-B	<1
WS-009110	4/6/2021	4/6/2022	2	Cooler	In hallway across from room 212	Low Right	WF-04062021-009110	12/23/2021	FT-FY22-12012021-009110-A	<1	FT-FY22-12012021-009110-B	<1
WS-009113	4/6/2021	4/6/2022	1	Cooler	In auditorium		WF-04062021-009113	12/23/2021	FT-FY22-12012021-009113-A	<1	FT-FY22-12012021-009113-B	<1
WS-009114	4/6/2021	4/6/2022	1	Health Suite	In health suite 004		WF-04062021-009114	12/23/2021	FT-FY22-12012021-009114-A	<1	FT-FY22-12012021-009114-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009059	1/18/2021	1/18/2022	Basement	Food Prep Sink	In kitchen first clockwise from entry	Right	WF-01182021-009059	12/23/2021	FT-FY22-12012021-009059-A	<1	FT-FY22-12012021-009059-B	<1