



Langdon Education Campus Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002691	3/19/2024	3/19/2025	1	Bottle Filler	In auditorium	WF-03192024-002691	12/10/2024	FT-FY25-11082024-002691-A	<2	FT-FY25-11082024-002691-B	<2	
WS-009061	8/28/2024	8/28/2025	1	Combo Faucet	In classroom 101	Low Left	WF-08282024-009061	12/10/2024	FT-FY25-11082024-009061-A	4.2	FT-FY25-11082024-009061-B	<2
WS-009062	3/19/2024	3/19/2025	1	Combo Fountain	In classroom 101	Low Mid	WF-03192024-009062	12/10/2024	FT-FY25-11082024-009062-A	<2	FT-FY25-11082024-009062-B	<2
WS-009063	8/28/2024	8/28/2025	1	Classroom Faucet	In classroom 101	High Right	WF-08282024-009063	12/10/2024	FT-FY25-11082024-009063-A	<2	FT-FY25-11082024-009063-B	<2
WS-009064	8/28/2024	8/28/2025	1	Classroom Faucet	In classroom 102	High Left	WF-08282024-009064	12/10/2024	FT-FY25-11082024-009064-A	<2	FT-FY25-11082024-009064-B	<2
WS-009065	3/19/2024	3/19/2025	1	Combo Fountain	In classroom 102	Low Mid	WF-03192024-009065	12/10/2024	FT-FY25-11082024-009065-A	<2	FT-FY25-11082024-009065-B	<2
WS-009066	8/28/2024	8/28/2025	1	Combo Faucet	In classroom 102	Low Right	WF-08282024-009066	12/10/2024	FT-FY25-11082024-009066-A	<2	FT-FY25-11082024-009066-B	<2
WS-009067	3/19/2024	3/19/2025	1	Break Room	In staff work room 113		WF-03192024-009067	12/10/2024	FT-FY25-11082024-009067-A	<2	FT-FY25-11082024-009067-B	<2
WS-009068	3/19/2024	3/19/2025	1	Cooler	In hallway adjacent to room 104	High Left	WF-03192024-009068	12/10/2024	FT-FY25-11082024-009068-A	<2	FT-FY25-11082024-009068-B	<2
WS-009069	3/19/2024	3/19/2025	1	Cooler	In hallway adjacent to room 104	Low Right	WF-03192024-009069	12/10/2024	FT-FY25-11082024-009069-A	<2	FT-FY25-11082024-009069-B	<2
WS-009072	8/28/2024	8/28/2025	1	Classroom Faucet	In classroom 104	High Right	WF-08282024-009072	12/10/2024	FT-FY25-11082024-009072-A	<2	FT-FY25-11082024-009072-B	<2
WS-009073	8/28/2024	8/28/2025	1	Classroom Faucet	In classroom 106	High Left	WF-08282024-009073	12/10/2024	FT-FY25-11082024-009073-A	<2	FT-FY25-11082024-009073-B	<2
WS-009075	8/28/2024	8/28/2025	1	Combo Faucet	In classroom 106	Low Right	WF-08282024-009075	12/10/2024	FT-FY25-11082024-009075-A	<2	FT-FY25-11082024-009075-B	<2
WS-009076	3/19/2024	3/19/2025	1	Cooler	In hallway across from room 105	High Left	WF-03192024-009076	12/10/2024	FT-FY25-11082024-009076-A	<2	FT-FY25-11082024-009076-B	<2
WS-009077	3/19/2024	3/19/2025	1	Cooler	In hallway across from room 105	Low Right	WF-03192024-009077	12/10/2024	FT-FY25-11082024-009077-A	<2	FT-FY25-11082024-009077-B	<2
WS-009078	8/28/2024	8/28/2025	1	Classroom Faucet	In classroom 107	High Left	WF-08282024-009078	12/10/2024	FT-FY25-11082024-009078-A	<2	FT-FY25-11082024-009078-B	<2
WS-009080	8/28/2024	8/28/2025	1	Combo Faucet	In classroom 107	Low Right	WF-08282024-009080	12/10/2024	FT-FY25-11082024-009080-A	<2	FT-FY25-11082024-009080-B	<2
WS-009081	8/28/2024	8/28/2025	1	Combo Faucet	In classroom 108	Low Left	WF-08282024-009081	12/10/2024	FT-FY25-11082024-009081-A	<2	FT-FY25-11082024-009081-B	<2
WS-009083	8/28/2024	8/28/2025	1	Classroom Faucet	In classroom 108	High Right	WF-08282024-009083	12/10/2024	FT-FY25-11082024-009083-A	<2	FT-FY25-11082024-009083-B	<2
WS-009084	8/28/2024	8/28/2025	1	Combo Faucet	In classroom 109	Low Left	WF-08282024-009084	12/10/2024	FT-FY25-11082024-009084-A	<2	FT-FY25-11082024-009084-B	<2
WS-009086	8/28/2024	8/28/2025	1	Classroom Faucet	In classroom 109	High Right	WF-08282024-009086	12/10/2024	FT-FY25-11082024-009086-A	<2	FT-FY25-11082024-009086-B	<2
WS-009087	8/28/2024	8/28/2025	1	Combo Faucet	In classroom 110	Low Left	WF-08282024-009087	12/10/2024	FT-FY25-11082024-009087-A	<2	FT-FY25-11082024-009087-B	<2
WS-009089	8/28/2024	8/28/2025	1	Classroom Faucet	In classroom 110	High Right	WF-08282024-009089	12/10/2024	FT-FY25-11082024-009089-A	2.4	FT-FY25-11082024-009089-B	<2
WS-009090	8/28/2024	8/28/2025	1	Classroom Faucet	In resource room 103	High Left	WF-08282024-009090	12/10/2024	FT-FY25-11082024-009090-A	<2	FT-FY25-11082024-009090-B	<2
WS-009091	3/19/2024	3/19/2025	1	Combo Fountain	In resource room 103	Low Mid	WF-03192024-009091	12/10/2024	FT-FY25-11082024-009091-A	<2	FT-FY25-11082024-009091-B	<2
WS-009092	8/28/2024	8/28/2025	1	Combo Faucet	In resource room 103	Low Right	WF-08282024-009092	12/10/2024	FT-FY25-11082024-009092-A	<2	FT-FY25-11082024-009092-B	<2
WS-009095	3/19/2024	3/19/2025	1	Cooler	In hallway across from room 154	Low Right	WF-03192024-009095	12/10/2024	FT-FY25-11082024-009095-A	<2	FT-FY25-11082024-009095-B	<2
WS-009096	3/19/2024	3/19/2025	1	Break Room	In staff work room 154		WF-03192024-009096	12/10/2024	FT-FY25-11082024-009096-A	<2	FT-FY25-11082024-009096-B	<2
WS-009097	3/19/2024	3/19/2025	2	Cooler	In hallway across from room 254	High Left	WF-03192024-009097	12/10/2024	FT-FY25-11082024-009097-A	<2	FT-FY25-11082024-009097-B	<2
WS-009098	3/19/2024	3/19/2025	2	Cooler	In hallway across from room 254	Low Right	WF-03192024-009098	12/10/2024	FT-FY25-11082024-009098-A	<2	FT-FY25-11082024-009098-B	<2
WS-009099	3/19/2024	3/19/2025	2	Break Room	In staff work room 254		WF-03192024-009099	12/10/2024	FT-FY25-11082024-009099-A	<2	FT-FY25-11082024-009099-B	<2
WS-009102	3/19/2024	3/19/2025	2	Combo Fountain	In science lab room 247 second clockwise from entry door		WF-03192024-009102	12/10/2024	FT-FY25-11082024-009102-A	<2	FT-FY25-11082024-009102-B	<2
WS-009106	3/19/2024	3/19/2025	2	Break Room	In classroom 209		WF-03192024-009106	12/10/2024	FT-FY25-11082024-009106-A	<2	FT-FY25-11082024-009106-B	<2

WS- 009107	3/19/2024	3/19/2025	2	Cooler	In hallway adjacent to room 204	High Left	WF-03192024-009107	12/10/2024	FT-FY25-11082024-009107-A	<2	FT-FY25-11082024-009107-B	<2
WS- 009109	3/19/2024	3/19/2025	2	Cooler	In hallway across from room 212	High Left	WF-03192024-009109	12/10/2024	FT-FY25-11082024-009109-A	<2	FT-FY25-11082024-009109-B	<2
WS- 009110	3/19/2024	3/19/2025	2	Cooler	In hallway across from room 212	Low Right	WF-03192024-009110	12/10/2024	FT-FY25-11082024-009110-A	<2	FT-FY25-11082024-009110-B	<2
WS- 009114	3/19/2024	3/19/2025	1	Health Suite	In health suite 004		WF-03192024-009114	12/10/2024	FT-FY25-11082024-009114-A	<2	FT-FY25-11082024-009114-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009059	12/18/2023	12/18/2024	Basement	Food Prep Sink	In kitchen first clockwise from entry	Right	WF-12182023-009059	12/10/2024	FT-FY25-11082024-009059-A	<2	FT-FY25-11082024-009059-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.