



Langdon EC Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002691	3/12/2025	3/12/2026	1	Bottle Filler	In auditorium	WF-03122025-002691	12/11/2025	FT-FY26-12012025-002691-A	<2	FT-FY26-12012025-002691-B	<2	
WS- 009056	3/12/2025	3/12/2026	2	Combo Fountain	In classroom 212	WF-03122025-009056	12/11/2025	FT-FY26-12012025-009056-A	<2	FT-FY26-12012025-009056-B	<2	
WS- 009061	8/19/2025	8/19/2026	1	Combo Faucet	In classroom 101	Low Left	WF-08192025-009061	12/11/2025	FT-FY26-12012025-009061-A	<2	FT-FY26-12012025-009061-B	<2
WS- 009062	3/12/2025	3/12/2026	1	Combo Fountain	In classroom 101	Low Mid	WF-03122025-009062	12/11/2025	FT-FY26-12012025-009062-A	<2	FT-FY26-12012025-009062-B	<2
WS- 009063	8/19/2025	8/19/2026	1	Classroom Faucet	In classroom 101	High Right	WF-08192025-009063	12/11/2025	FT-FY26-12012025-009063-A	<2	FT-FY26-12012025-009063-B	<2
WS- 009064	8/19/2025	8/19/2026	1	Classroom Faucet	In classroom 102	High Left	WF-08192025-009064	12/11/2025	FT-FY26-12012025-009064-A	2.9	FT-FY26-12012025-009064-B	<2
WS- 009065	3/12/2025	3/12/2026	1	Combo Fountain	In classroom 102	Low Mid	WF-03122025-009065	12/11/2025	FT-FY26-12012025-009065-A	<2	FT-FY26-12012025-009065-B	<2
WS- 009066	8/19/2025	8/19/2026	1	Combo Faucet	In classroom 102	Low Right	WF-08192025-009066	12/11/2025	FT-FY26-12012025-009066-A	<2	FT-FY26-12012025-009066-B	<2
WS- 009067	3/12/2025	3/12/2026	1	Break Room	In staff work room 113		WF-03122025-009067	12/11/2025	FT-FY26-12012025-009067-A	<2	FT-FY26-12012025-009067-B	<2
WS- 009068	3/12/2025	3/12/2026	1	Cooler	In hallway adjacent to room 104	High Left	WF-03122025-009068	12/11/2025	FT-FY26-12012025-009068-A	<2	FT-FY26-12012025-009068-B	<2
WS- 009069	3/12/2025	3/12/2026	1	Cooler	In hallway adjacent to room 104	Low Right	WF-03122025-009069	12/11/2025	FT-FY26-12012025-009069-A	<2	FT-FY26-12012025-009069-B	<2
WS- 009073	8/19/2025	8/19/2026	1	Classroom Faucet	In classroom 106	High Left	WF-08192025-009073	12/11/2025	FT-FY26-12012025-009073-A	<2	FT-FY26-12012025-009073-B	<2
WS- 009074	3/12/2025	3/12/2026	1	Combo Fountain	In classroom 106	Low Mid	WF-03122025-009074	12/11/2025	FT-FY26-12012025-009074-A	<2	FT-FY26-12012025-009074-B	<2
WS- 009075	8/19/2025	8/19/2026	1	Combo Faucet	In classroom 106	Low Right	WF-08192025-009075	12/11/2025	FT-FY26-12012025-009075-A	<2	FT-FY26-12012025-009075-B	<2
WS- 009076	3/12/2025	3/12/2026	1	Cooler	In hallway across from room 105	High Left	WF-03122025-009076	12/11/2025	FT-FY26-12012025-009076-A	<2	FT-FY26-12012025-009076-B	<2
WS- 009077	3/12/2025	3/12/2026	1	Cooler	In hallway across from room 105	Low Right	WF-03122025-009077	12/11/2025	FT-FY26-12012025-009077-A	<2	FT-FY26-12012025-009077-B	<2
WS- 009078	8/19/2025	8/19/2026	1	Classroom Faucet	In classroom 107	High Left	WF-08192025-009078	12/11/2025	FT-FY26-12012025-009078-A	<2	FT-FY26-12012025-009078-B	<2
WS- 009079	3/12/2025	3/12/2026	1	Combo Fountain	In classroom 107	Low Mid	WF-03122025-009079	12/11/2025	FT-FY26-12012025-009079-A	<2	FT-FY26-12012025-009079-B	<2
WS- 009080	8/19/2025	8/19/2026	1	Combo Faucet	In classroom 107	Low Right	WF-08192025-009080	12/11/2025	FT-FY26-12012025-009080-A	<2	FT-FY26-12012025-009080-B	<2
WS- 009081	8/19/2025	8/19/2026	1	Combo Faucet	In classroom 108	Low Left	WF-08192025-009081	12/11/2025	FT-FY26-12012025-009081-A	<2	FT-FY26-12012025-009081-B	<2
WS- 009082	3/12/2025	3/12/2026	1	Combo Fountain	In classroom 108	Low Mid	WF-03122025-009082	12/11/2025	FT-FY26-12012025-009082-A	<2	FT-FY26-12012025-009082-B	<2
WS- 009083	8/19/2025	8/19/2026	1	Classroom Faucet	In classroom 108	High Right	WF-08192025-009083	12/11/2025	FT-FY26-12012025-009083-A	3.4	FT-FY26-12012025-009083-B	<2
WS- 009084	8/19/2025	8/19/2026	1	Combo Faucet	In classroom 109	Low Left	WF-08192025-009084	12/11/2025	FT-FY26-12012025-009084-A	<2	FT-FY26-12012025-009084-B	<2
WS- 009086	8/19/2025	8/19/2026	1	Classroom Faucet	In classroom 109	High Right	WF-08192025-009086	12/11/2025	FT-FY26-12012025-009086-A	<2	FT-FY26-12012025-009086-B	<2
WS- 009087	8/19/2025	8/19/2026	1	Combo Faucet	In classroom 110	Low Left	WF-08192025-009087	12/11/2025	FT-FY26-12012025-009087-A	<2	FT-FY26-12012025-009087-B	<2
WS- 009088	3/12/2025	3/12/2026	1	Combo Fountain	In classroom 110	Low Mid	WF-03122025-009088	12/11/2025	FT-FY26-12012025-009088-A	<2	FT-FY26-12012025-009088-B	<2
WS- 009089	8/19/2025	8/19/2026	1	Classroom Faucet	In classroom 110	High Right	WF-08192025-009089	12/11/2025	FT-FY26-12012025-009089-A	<2	FT-FY26-12012025-009089-B	<2
WS- 009090	8/19/2025	8/19/2026	1	Classroom Faucet	In resource room 103	High Left	WF-08192025-009090	12/11/2025	FT-FY26-12012025-009090-A	<2	FT-FY26-12012025-009090-B	<2
WS- 009094	3/12/2025	3/12/2026	1	Cooler	In hallway across from room 154	High Left	WF-03122025-009094	12/11/2025	FT-FY26-12012025-009094-A	<2	FT-FY26-12012025-009094-B	<2
WS- 009095	3/12/2025	3/12/2026	1	Cooler	In hallway across from room 154	Low Right	WF-03122025-009095	12/11/2025	FT-FY26-12012025-009095-A	<2	FT-FY26-12012025-009095-B	<2
WS- 009096	3/12/2025	3/12/2026	1	Break Room	In staff work room 154		WF-03122025-009096	12/11/2025	FT-FY26-12012025-009096-A	<2	FT-FY26-12012025-009096-B	<2
WS- 009097	3/12/2025	3/12/2026	2	Cooler	In hallway across from room 254	High Left	WF-03122025-009097	12/11/2025	FT-FY26-12012025-009097-A	<2	FT-FY26-12012025-009097-B	<2
WS- 009098	3/12/2025	3/12/2026	2	Cooler	In hallway across from room 254	Low Right	WF-03122025-009098	12/11/2025	FT-FY26-12012025-009098-A	<2	FT-FY26-12012025-009098-B	<2
WS- 009099	3/12/2025	3/12/2026	2	Break Room	In staff work room 254		WF-03122025-009099	12/11/2025	FT-FY26-12012025-009099-A	<2	FT-FY26-12012025-009099-B	<2

WS- 009102	3/12/2025	3/12/2026	2	Combo Fountain	In science lab room 247 second clockwise from entry door	WF-03122025-009102	12/11/2025	FT-FY26-12012025-009102-A	<2	FT-FY26-12012025-009102-B	<2
WS- 009106	3/12/2025	3/12/2026	2	Break Room	In classroom 209	WF-03122025-009106	12/11/2025	FT-FY26-12012025-009106-A	<2	FT-FY26-12012025-009106-B	<2
WS- 009107	3/12/2025	3/12/2026	2	Cooler	In hallway adjacent to room 204 High Left	WF-03122025-009107	12/11/2025	FT-FY26-12012025-009107-A	<2	FT-FY26-12012025-009107-B	<2
WS- 009109	3/12/2025	3/12/2026	2	Cooler	In hallway across from room 212 High Left	WF-03122025-009109	12/11/2025	FT-FY26-12012025-009109-A	<2	FT-FY26-12012025-009109-B	<2
WS- 009110	3/12/2025	3/12/2026	2	Cooler	In hallway across from room 212 Low Right	WF-03122025-009110	12/11/2025	FT-FY26-12012025-009110-A	<2	FT-FY26-12012025-009110-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009059	11/24/2025	11/24/2026	Basement	Food Prep Sink	In kitchen first clockwise from entry Right	WF-11242025-009059	12/11/2025	FT-FY26-12012025-009059-A	<2	FT-FY26-12012025-009059-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.