



Langdon Education Campus Lead in Water Test Results



FY21 Filter Test

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|------------------|---------------------------------|------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 009061 | 9/22/2020 | 9/22/2021 | 1 | Combo Faucet | In classroom 101 | Low Left | WF-09222020-009061 | 2/2/2021 | FT-FY21-012021-009061-A | 2.4 | FT-FY21-012021-009061-B | <1 |
| WS- 009062 | 5/8/2020 | 5/8/2021 | 1 | Combo Fountain | In classroom 101 | Low Mid | WF-05082020-009062 | 2/2/2021 | FT-FY21-012021-009062-A | 2.4 | FT-FY21-012021-009062-B | <1 |
| WS- 009063 | 9/22/2020 | 9/22/2021 | 1 | Classroom Faucet | In classroom 101 | High Right | WF-09222020-009063 | 2/2/2021 | FT-FY21-012021-009063-A | 3.6 | FT-FY21-012021-009063-B | <1 |
| WS- 009064 | 9/22/2020 | 9/22/2021 | 1 | Classroom Faucet | In classroom 102 | High Left | WF-09222020-009064 | 2/2/2021 | FT-FY21-012021-009064-A | 2.4 | FT-FY21-012021-009064-B | <1 |
| WS- 009065 | 5/8/2020 | 5/8/2021 | 1 | Combo Fountain | In classroom 102 | Low Mid | WF-05082020-009065 | 2/2/2021 | FT-FY21-012021-009065-A | <1 | FT-FY21-012021-009065-B | <1 |
| WS- 009066 | 9/22/2020 | 9/22/2021 | 1 | Combo Faucet | In classroom 102 | Low Right | WF-09222020-009066 | 2/2/2021 | FT-FY21-012021-009066-A | 2.0 | FT-FY21-012021-009066-B | <1 |
| WS- 009067 | 5/8/2020 | 5/8/2021 | 1 | Break Room | In staff work room 113 | | WF-05082020-009067 | 2/2/2021 | FT-FY21-012021-009067-A | <1 | FT-FY21-012021-009067-B | <1 |
| WS- 009068 | 5/8/2020 | 5/8/2021 | 1 | Cooler | In hallway adjacent to room 104 | High Left | WF-05082020-009068 | 2/2/2021 | FT-FY21-012021-009068-A | <1 | FT-FY21-012021-009068-B | <1 |
| WS- 009069 | 5/8/2020 | 5/8/2021 | 1 | Cooler | In hallway adjacent to room 104 | Low Right | WF-05082020-009069 | 2/2/2021 | FT-FY21-012021-009069-A | <1 | FT-FY21-012021-009069-B | <1 |
| WS- 009070 | 9/22/2020 | 9/22/2021 | 1 | Combo Faucet | In classroom 104 | Low Left | WF-09222020-009070 | 2/2/2021 | FT-FY21-012021-009070-A | <1 | FT-FY21-012021-009070-B | <1 |
| WS- 009071 | 5/8/2020 | 5/8/2021 | 1 | Combo Fountain | In classroom 104 | Low Mid | WF-05082020-009071 | 2/2/2021 | FT-FY21-012021-009071-A | <1 | FT-FY21-012021-009071-B | <1 |
| WS- 009072 | 9/22/2020 | 9/22/2021 | 1 | Classroom Faucet | In classroom 104 | High Right | WF-09222020-009072 | 2/2/2021 | FT-FY21-012021-009072-A | <1 | FT-FY21-012021-009072-B | <1 |
| WS- 009073 | 9/22/2020 | 9/22/2021 | 1 | Classroom Faucet | In classroom 106 | High Left | WF-09222020-009073 | 2/2/2021 | FT-FY21-012021-009073-A | 2.0 | FT-FY21-012021-009073-B | <1 |
| WS- 009075 | 9/22/2020 | 9/22/2021 | 1 | Combo Faucet | In classroom 106 | Low Right | WF-09222020-009075 | 2/2/2021 | FT-FY21-012021-009075-A | 1.5 | FT-FY21-012021-009075-B | <1 |
| WS- 009076 | 5/8/2020 | 5/8/2021 | 1 | Cooler | In hallway across from room 105 | High Left | WF-05082020-009076 | 2/2/2021 | FT-FY21-012021-009076-A | <1 | FT-FY21-012021-009076-B | <1 |
| WS- 009077 | 5/8/2020 | 5/8/2021 | 1 | Cooler | In hallway across from room 105 | Low Right | WF-05082020-009077 | 2/2/2021 | FT-FY21-012021-009077-A | <1 | FT-FY21-012021-009077-B | <1 |
| WS- 009078 | 9/22/2020 | 9/22/2021 | 1 | Classroom Faucet | In classroom 107 | High Left | WF-09222020-009078 | 2/2/2021 | FT-FY21-012021-009078-A | <1 | FT-FY21-012021-009078-B | <1 |
| WS- 009079 | 5/8/2020 | 5/8/2021 | 1 | Combo Fountain | In classroom 107 | Low Mid | WF-05082020-009079 | 2/2/2021 | FT-FY21-012021-009079-A | <1 | FT-FY21-012021-009079-B | <1 |
| WS- 009080 | 9/22/2020 | 9/22/2021 | 1 | Combo Faucet | In classroom 107 | Low Right | WF-09222020-009080 | 2/2/2021 | FT-FY21-012021-009080-A | <1 | FT-FY21-012021-009080-B | <1 |
| WS- 009081 | 9/22/2020 | 9/22/2021 | 1 | Combo Faucet | In classroom 108 | Low Left | WF-09222020-009081 | 2/2/2021 | FT-FY21-012021-009081-A | <1 | FT-FY21-012021-009081-B | <1 |
| WS- 009082 | 5/8/2020 | 5/8/2021 | 1 | Combo Fountain | In classroom 108 | Low Mid | WF-05082020-009082 | 2/2/2021 | FT-FY21-012021-009082-A | <1 | FT-FY21-012021-009082-B | <1 |
| WS- 009083 | 9/22/2020 | 9/22/2021 | 1 | Classroom Faucet | In classroom 108 | High Right | WF-09222020-009083 | 2/2/2021 | FT-FY21-012021-009083-A | <1 | FT-FY21-012021-009083-B | <1 |
| WS- 009084 | 9/22/2020 | 9/22/2021 | 1 | Combo Faucet | In classroom 109 | Low Left | WF-09222020-009084 | 2/2/2021 | FT-FY21-012021-009084-A | <1 | FT-FY21-012021-009084-B | <1 |
| WS- 009085 | 5/8/2020 | 5/8/2021 | 1 | Combo Fountain | In classroom 109 | Low Mid | WF-05082020-009085 | 2/2/2021 | FT-FY21-012021-009085-A | <1 | FT-FY21-012021-009085-B | <1 |
| WS- 009087 | 9/22/2020 | 9/22/2021 | 1 | Combo Faucet | In classroom 110 | Low Left | WF-09222020-009087 | 2/2/2021 | FT-FY21-012021-009087-A | 3.1 | FT-FY21-012021-009087-B | <1 |
| WS- 009088 | 5/8/2020 | 5/8/2021 | 1 | Combo Fountain | In classroom 110 | Low Mid | WF-05082020-009088 | 2/2/2021 | FT-FY21-012021-009088-A | 1.3 | FT-FY21-012021-009088-B | <1 |
| WS- 009089 | 9/22/2020 | 9/22/2021 | 1 | Classroom Faucet | In classroom 110 | High Right | WF-09222020-009089 | 2/2/2021 | FT-FY21-012021-009089-A | 2.5 | FT-FY21-012021-009089-B | <1 |
| WS- 009090 | 9/22/2020 | 9/22/2021 | 1 | Classroom Faucet | In resource room 103 | High Left | WF-09222020-009090 | 2/2/2021 | FT-FY21-012021-009090-A | <1 | FT-FY21-012021-009090-B | <1 |
| WS- 009091 | 5/8/2020 | 5/8/2021 | 1 | Combo Fountain | In resource room 103 | Low Mid | WF-05082020-009091 | 2/2/2021 | FT-FY21-012021-009091-A | <1 | FT-FY21-012021-009091-B | <1 |
| WS- 009092 | 9/22/2020 | 9/22/2021 | 1 | Combo Faucet | In resource room 103 | Low Right | WF-09222020-009092 | 2/2/2021 | FT-FY21-012021-009092-A | <1 | FT-FY21-012021-009092-B | <1 |
| WS- 009094 | 5/8/2020 | 5/8/2021 | 1 | Cooler | In hallway across from room 154 | High Left | WF-05082020-009094 | 2/2/2021 | FT-FY21-012021-009094-A | <1 | FT-FY21-012021-009094-B | <1 |
| WS- 009095 | 5/8/2020 | 5/8/2021 | 1 | Cooler | In hallway across from room 154 | Low Right | WF-05082020-009095 | 2/2/2021 | FT-FY21-012021-009095-A | <1 | FT-FY21-012021-009095-B | <1 |
| WS- 009096 | 5/8/2020 | 5/8/2021 | 1 | Break Room | In staff work room 154 | | WF-05082020-009096 | 2/2/2021 | FT-FY21-012021-009096-A | 4.8 | FT-FY21-012021-009096-B | <1 |

| | | | | | | | | | | | | | |
|------------|----------|----------|---|----------------|--|------|-------|--------------------|----------|-------------------------|-----|-------------------------|----|
| WS- 009097 | 5/8/2020 | 5/8/2021 | 2 | Cooler | In hallway across from room 254 | High | Left | WF-05082020-009097 | 2/2/2021 | FT-FY21-012021-009097-A | <1 | FT-FY21-012021-009097-B | <1 |
| WS- 009098 | 5/8/2020 | 5/8/2021 | 2 | Cooler | In hallway across from room 254 | Low | Right | WF-05082020-009098 | 2/2/2021 | FT-FY21-012021-009098-A | <1 | FT-FY21-012021-009098-B | <1 |
| WS- 009099 | 5/8/2020 | 5/8/2021 | 2 | Break Room | In staff work room 254 | | | WF-05082020-009099 | 2/2/2021 | FT-FY21-012021-009099-A | 1.1 | FT-FY21-012021-009099-B | <1 |
| WS- 009102 | 5/8/2020 | 5/8/2021 | 2 | Combo Fountain | In science lab room 247 second clockwise from entry door | | | WF-05082020-009102 | 2/2/2021 | FT-FY21-012021-009102-A | 2.7 | FT-FY21-012021-009102-B | <1 |
| WS- 009106 | 5/8/2020 | 5/8/2021 | 2 | Break Room | In classroom 209 | | | WF-05082020-009106 | 2/2/2021 | FT-FY21-012021-009106-A | <1 | FT-FY21-012021-009106-B | <1 |
| WS- 009107 | 5/8/2020 | 5/8/2021 | 2 | Cooler | In hallway adjacent to room 204 | High | Left | WF-05082020-009107 | 2/2/2021 | FT-FY21-012021-009107-A | <1 | FT-FY21-012021-009107-B | <1 |
| WS- 009108 | 5/8/2020 | 5/8/2021 | 2 | Cooler | In hallway adjacent to room 204 | Low | Right | WF-05082020-009108 | 2/2/2021 | FT-FY21-012021-009108-A | <1 | FT-FY21-012021-009108-B | <1 |
| WS- 009109 | 5/8/2020 | 5/8/2021 | 2 | Cooler | In hallway across from room 212 | High | Left | WF-05082020-009109 | 2/2/2021 | FT-FY21-012021-009109-A | <1 | FT-FY21-012021-009109-B | <1 |
| WS- 009110 | 5/8/2020 | 5/8/2021 | 2 | Cooler | In hallway across from room 212 | Low | Right | WF-05082020-009110 | 2/2/2021 | FT-FY21-012021-009110-A | <1 | FT-FY21-012021-009110-B | <1 |
| WS- 009113 | 5/8/2020 | 5/8/2021 | 1 | Cooler | In auditorium | | | WF-05082020-009113 | 2/2/2021 | FT-FY21-012021-009113-A | <1 | FT-FY21-012021-009113-B | <1 |
| WS- 009114 | 5/8/2020 | 5/8/2021 | 1 | Health Suite | In health suite 004 | | | WF-05082020-009114 | 2/2/2021 | FT-FY21-012021-009114-A | <1 | FT-FY21-012021-009114-B | <1 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | | | |
|---|-----------------------|------------------------|----------|----------------|---------------------------------------|---------------------|---------------|----------------------|----------------------------------|-------------------------|----------------------------------|-------------------------|----|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) | | |
| WS- 009059 | 1/18/2021 | 1/18/2022 | Basement | Food Prep Sink | In kitchen first clockwise from entry | | Right | WF-01182021-009059 | 2/2/2021 | FT-FY21-012021-009059-A | <1 | FT-FY21-012021-009059-B | <1 |

FY21 Filter Test

| Greater than 5ppb - Devices requiring remediation | | | | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|------------------|------------------|---------------------|---------------|----------------------|----------------------------------|----------------------|----------------------------------|-----|-------------------------|----|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) | | | |
| WS- 009074 | 5/8/2020 | 5/8/2021 | 1 | Combo Fountain | In classroom 106 | | Low | Mid | WF-05082020-009074 | 2/2/2021 | FT-FY21-012021-009074-A | 6.1 | FT-FY21-012021-009074-B | <1 |
| WS- 009086 | 9/22/2020 | 9/22/2021 | 1 | Classroom Faucet | In classroom 109 | | High | Right | WF-09222020-009086 | 2/2/2021 | FT-FY21-012021-009086-A | 6.5 | FT-FY21-012021-009086-B | <1 |