



Langdon ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009056	5/15/2019	5/15/2020	2	Combo Fountain	In classroom 212	WF-05152019-009056	12/8/2019	FT-FY20-112019-009056-A	<1	FT-FY20-112019-009056-B	<1	
WS- 009061	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 101	Low Left	WF-10022019-009061	12/8/2019	FT-FY20-112019-009061-A	<1	FT-FY20-112019-009061-B	<1
WS- 009062	5/15/2019	5/15/2020	1	Combo Fountain	In classroom 101	Low Mid	WF-05152019-009062	12/8/2019	FT-FY20-112019-009062-A	<1	FT-FY20-112019-009062-B	<1
WS- 009063	10/2/2019	10/2/2020	1	Classroom Faucet	In classroom 101	High Right	WF-10022019-009063	12/8/2019	FT-FY20-112019-009063-A	<1	FT-FY20-112019-009063-B	<1
WS- 009064	10/2/2019	10/2/2020	1	Classroom Faucet	In classroom 102	High Left	WF-10022019-009064	12/8/2019	FT-FY20-112019-009064-A	<1	FT-FY20-112019-009064-B	<1
WS- 009065	5/15/2019	5/15/2020	1	Combo Fountain	In classroom 102	Low Mid	WF-05152019-009065	12/8/2019	FT-FY20-112019-009065-A	<1	FT-FY20-112019-009065-B	<1
WS- 009066	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 102	Low Right	WF-10022019-009066	12/8/2019	FT-FY20-112019-009066-A	<1	FT-FY20-112019-009066-B	<1
WS- 009067	5/15/2019	5/15/2020	1	Break Room	In staff work room 113		WF-05152019-009067	12/8/2019	FT-FY20-112019-009067-A	<1	FT-FY20-112019-009067-B	<1
WS- 009068	5/15/2019	5/15/2020	1	Cooler	In hallway adjacent to room 104	High Left	WF-05152019-009068	12/8/2019	FT-FY20-112019-009068-A	<1	FT-FY20-112019-009068-B	<1
WS- 009069	5/15/2019	5/15/2020	1	Cooler	In hallway adjacent to room 104	Low Right	WF-05152019-009069	12/8/2019	FT-FY20-112019-009069-A	<1	FT-FY20-112019-009069-B	<1
WS- 009070	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 104	Low Left	WF-10022019-009070	12/8/2019	FT-FY20-112019-009070-A	<1	FT-FY20-112019-009070-B	<1
WS- 009071	5/15/2019	5/15/2020	1	Combo Fountain	In classroom 104	Low Mid	WF-05152019-009071	12/8/2019	FT-FY20-112019-009071-A	<1	FT-FY20-112019-009071-B	<1
WS- 009072	10/2/2019	10/2/2020	1	Classroom Faucet	In classroom 104	High Right	WF-10022019-009072	12/8/2019	FT-FY20-112019-009072-A	<1	FT-FY20-112019-009072-B	<1
WS- 009073	10/2/2019	10/2/2020	1	Classroom Faucet	In classroom 106	High Left	WF-10022019-009073	12/8/2019	FT-FY20-112019-009073-A	<1	FT-FY20-112019-009073-B	<1
WS- 009074	5/15/2019	5/15/2020	1	Combo Fountain	In classroom 106	Low Mid	WF-05152019-009074	12/8/2019	FT-FY20-112019-009074-A	<1	FT-FY20-112019-009074-B	<1
WS- 009075	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 106	Low Right	WF-10022019-009075	12/8/2019	FT-FY20-112019-009075-A	<1	FT-FY20-112019-009075-B	<1
WS- 009076	5/15/2019	5/15/2020	1	Cooler	In hallway across from room 105	High Left	WF-05152019-009076	12/8/2019	FT-FY20-112019-009076-A	<1	FT-FY20-112019-009076-B	<1
WS- 009077	5/15/2019	5/15/2020	1	Cooler	In hallway across from room 105	Low Right	WF-05152019-009077	12/8/2019	FT-FY20-112019-009077-A	<1	FT-FY20-112019-009077-B	<1
WS- 009078	10/2/2019	10/2/2020	1	Classroom Faucet	In classroom 107	High Left	WF-10022019-009078	12/8/2019	FT-FY20-112019-009078-A	1.4	FT-FY20-112019-009078-B	<1
WS- 009079	5/15/2019	5/15/2020	1	Combo Fountain	In classroom 107	Low Mid	WF-05152019-009079	12/8/2019	FT-FY20-112019-009079-A	<1	FT-FY20-112019-009079-B	<1
WS- 009080	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 107	Low Right	WF-10022019-009080	12/8/2019	FT-FY20-112019-009080-A	<1	FT-FY20-112019-009080-B	<1
WS- 009081	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 108	Low Left	WF-10022019-009081	12/8/2019	FT-FY20-112019-009081-A	1	FT-FY20-112019-009081-B	<1
WS- 009082	5/15/2019	5/15/2020	1	Combo Fountain	In classroom 108	Low Mid	WF-05152019-009082	12/8/2019	FT-FY20-112019-009082-A	<1	FT-FY20-112019-009082-B	<1
WS- 009083	10/2/2019	10/2/2020	1	Classroom Faucet	In classroom 108	High Right	WF-10022019-009083	12/8/2019	FT-FY20-112019-009083-A	1.1	FT-FY20-112019-009083-B	<1
WS- 009084	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 109	Low Left	WF-10022019-009084	12/8/2019	FT-FY20-112019-009084-A	<1	FT-FY20-112019-009084-B	<1
WS- 009085	5/15/2019	5/15/2020	1	Combo Fountain	In classroom 109	Low Mid	WF-05152019-009085	12/8/2019	FT-FY20-112019-009085-A	<1	FT-FY20-112019-009085-B	<1
WS- 009086	10/2/2019	10/2/2020	1	Classroom Faucet	In classroom 109	High Right	WF-10022019-009086	12/8/2019	FT-FY20-112019-009086-A	<1	FT-FY20-112019-009086-B	<1
WS- 009087	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 110	Low Left	WF-10022019-009087	12/8/2019	FT-FY20-112019-009087-A	<1	FT-FY20-112019-009087-B	<1
WS- 009088	5/15/2019	5/15/2020	1	Combo Fountain	In classroom 110	Low Mid	WF-05152019-009088	12/8/2019	FT-FY20-112019-009088-A	<1	FT-FY20-112019-009088-B	<1
WS- 009089	10/2/2019	10/2/2020	1	Classroom Faucet	In classroom 110	High Right	WF-10022019-009089	12/8/2019	FT-FY20-112019-009089-A	<1	FT-FY20-112019-009089-B	<1
WS- 009090	10/2/2019	10/2/2020	1	Classroom Faucet	In resource room 103	High Left	WF-10022019-009090	12/8/2019	FT-FY20-112019-009090-A	<1	FT-FY20-112019-009090-B	<1
WS- 009091	5/15/2019	5/15/2020	1	Combo Fountain	In resource room 103	Low Mid	WF-05152019-009091	12/8/2019	FT-FY20-112019-009091-A	<1	FT-FY20-112019-009091-B	<1
WS- 009092	10/2/2019	10/2/2020	1	Combo Faucet	In resource room 103	Low Right	WF-10022019-009092	12/8/2019	FT-FY20-112019-009092-A	<1	FT-FY20-112019-009092-B	<1
WS- 009094	5/15/2019	5/15/2020	1	Cooler	In hallway across from room 154	High Left	WF-05152019-009094	12/8/2019	FT-FY20-112019-009094-A	<1	FT-FY20-112019-009094-B	<1
WS- 009095	5/15/2019	5/15/2020	1	Cooler	In hallway across from room 154	Low Right	WF-05152019-009095	12/8/2019	FT-FY20-112019-009095-A	<1	FT-FY20-112019-009095-B	<1
WS- 009096	5/15/2019	5/15/2020	1	Break Room	In staff work room 154		WF-05152019-009096	12/8/2019	FT-FY20-112019-009096-A	<1	FT-FY20-112019-009096-B	<1

WS- 009097	5/15/2019	5/15/2020	2	Cooler	In hallway across from room 254	High Left	WF-05152019-009097	12/8/2019	FT-FY20-112019-009097-A	<1	FT-FY20-112019-009097-B	<1
WS- 009098	5/15/2019	5/15/2020	2	Cooler	In hallway across from room 254	Low Right	WF-05152019-009098	12/8/2019	FT-FY20-112019-009098-A	<1	FT-FY20-112019-009098-B	<1
WS- 009099	5/15/2019	5/15/2020	2	Break Room	In staff work room 254		WF-05152019-009099	12/8/2019	FT-FY20-112019-009099-A	<1	FT-FY20-112019-009099-B	<1
WS- 009102	5/15/2019	5/15/2020	2	Combo Fountain	In science lab room 247 second clockwise from entry door		WF-05152019-009102	12/8/2019	FT-FY20-112019-009102-A	<1	FT-FY20-112019-009102-B	<1
WS- 009106	5/15/2019	5/15/2020	2	Break Room	In classroom 209		WF-05152019-009106	12/8/2019	FT-FY20-112019-009106-A	2.9	FT-FY20-112019-009106-B	<1
WS- 009107	5/15/2019	5/15/2020	2	Cooler	In hallway adjacent to room 204	High Left	WF-05152019-009107	12/8/2019	FT-FY20-112019-009107-A	<1	FT-FY20-112019-009107-B	<1
WS- 009108	5/15/2019	5/15/2020	2	Cooler	In hallway adjacent to room 204	Low Right	WF-05152019-009108	12/8/2019	FT-FY20-112019-009108-A	<1	FT-FY20-112019-009108-B	<1
WS- 009109	5/15/2019	5/15/2020	2	Cooler	In hallway across from room 212	High Left	WF-05152019-009109	12/8/2019	FT-FY20-112019-009109-A	<1	FT-FY20-112019-009109-B	<1
WS- 009110	5/15/2019	5/15/2020	2	Cooler	In hallway across from room 212	Low Right	WF-05152019-009110	12/8/2019	FT-FY20-112019-009110-A	<1	FT-FY20-112019-009110-B	<1
WS- 009113	9/5/2019	9/5/2020	1	Cooler	In auditorium		WF-09052019-009113	12/8/2019	FT-FY20-112019-009113-A	<1	FT-FY20-112019-009113-B	<1
WS- 009114	5/15/2019	5/15/2020	1	Health Suite	In health suite 004		WF-05152019-009114	12/8/2019	FT-FY20-112019-009114-A	<1	FT-FY20-112019-009114-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009059	7/23/2019	7/23/2020	Basement	Food Prep Sink	In kitchen first clockwise from entry	Right	WF-07232019-009059	12/8/2019	FT-FY20-112019-009059-A	<1	FT-FY20-112019-009059-B	<1