



LANGDON EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	LANGDON EDUCATIONAL CAMPUS	WS- 009059	8/19/2016	Basement	Food Prep Sink	In kitchen	FT-82016-009059-A	< 1	FT-82016-009059-B	< 1
2	LANGDON EDUCATIONAL CAMPUS	WS- 009062	8/19/2016	1	Fountain	In classroom 101 Low Mid	FT-82016-009062-A	< 1	FT-82016-009062-B	< 1
3	LANGDON EDUCATIONAL CAMPUS	WS- 009065	8/19/2016	1	Fountain	In classroom 102 Low Mid	FT-82016-009065-A	< 1	FT-82016-009065-B	< 1
4	LANGDON EDUCATIONAL CAMPUS	WS- 009066	8/19/2016	1	Classroom Faucet	In classroom 102 Low Right	FT-82016-009066-A	< 1	FT-82016-009066-B	< 1
5	LANGDON EDUCATIONAL CAMPUS	WS- 009068	8/19/2016	1	Cooler	In hallway adjacent to room 104 High Left	FT-82016-009068-A	< 1	FT-82016-009068-B	< 1
6	LANGDON EDUCATIONAL CAMPUS	WS- 009069	8/19/2016	1	Cooler	In hallway adjacent to room 104 Low Right	FT-82016-009069-A	< 1	FT-82016-009069-B	< 1
7	LANGDON EDUCATIONAL CAMPUS	WS- 009071	8/19/2016	1	Fountain	In classroom 104 Low Mid	FT-82016-009071-A	< 1	FT-82016-009071-B	< 1
8	LANGDON EDUCATIONAL CAMPUS	WS- 009074	8/19/2016	1	Fountain	In classroom 106 Low Mid	FT-82016-009074-A	< 1	FT-82016-009074-B	< 1
9	LANGDON EDUCATIONAL CAMPUS	WS- 009076	8/19/2016	1	Cooler	In hallway across from room 105 High Left	FT-82016-009076-A	< 1	FT-82016-009076-B	< 1
10	LANGDON EDUCATIONAL CAMPUS	WS- 009077	8/19/2016	1	Cooler	In hallway across from room 105 Low Right	FT-82016-009077-A	< 1	FT-82016-009077-B	< 1
11	LANGDON EDUCATIONAL CAMPUS	WS- 009079	8/19/2016	1	Fountain	In classroom 107 Low Mid	FT-82016-009079-A	< 1	FT-82016-009079-B	< 1
12	LANGDON EDUCATIONAL CAMPUS	WS- 009082	8/19/2016	1	Fountain	In classroom 108 Low Mid	FT-82016-009082-A	< 1	FT-82016-009082-B	< 1
13	LANGDON EDUCATIONAL CAMPUS	WS- 009085	8/19/2016	1	Fountain	In classroom 109 Low Mid	FT-82016-009085-A	< 1	FT-82016-009085-B	< 1
14	LANGDON EDUCATIONAL CAMPUS	WS- 009088	8/19/2016	1	Fountain	In classroom 110 Low Mid	FT-82016-009088-A	< 1	FT-82016-009088-B	< 1
15	LANGDON EDUCATIONAL CAMPUS	WS- 009091	8/19/2016	1	Fountain	In resource room 103 Low Mid	FT-82016-009091-A	< 1	FT-82016-009091-B	< 1
16	LANGDON EDUCATIONAL CAMPUS	WS- 009092	8/19/2016	1	Classroom Faucet	In resource room 103 Low Right	FT-82016-009092-A	< 1	FT-82016-009092-B	< 1
17	LANGDON EDUCATIONAL CAMPUS	WS- 009094	8/19/2016	1	Cooler	In hallway across from room 154 High Left	FT-82016-009094-A	< 1	FT-82016-009094-B	< 1
18	LANGDON EDUCATIONAL CAMPUS	WS- 009095	8/19/2016	1	Cooler	In hallway across from room 154 Low Right	FT-82016-009095-A	< 1	FT-82016-009095-B	< 1
19	LANGDON EDUCATIONAL CAMPUS	WS- 009097	8/19/2016	2	Cooler	In hallway across from room 254 High Left	FT-82016-009097-A	< 1	FT-82016-009097-B	< 1
20	LANGDON EDUCATIONAL CAMPUS	WS- 009098	8/19/2016	2	Cooler	In hallway across from room 254 Low Right	FT-82016-009098-A	< 1	FT-82016-009098-B	< 1
21	LANGDON EDUCATIONAL CAMPUS	WS- 009102	8/19/2016	2	Fountain	In science lab room 247 second clockwise from entry door	FT-82016-009102-A	< 1	FT-82016-009102-B	< 1
22	LANGDON EDUCATIONAL CAMPUS	WS- 009107	8/19/2016	2	Cooler	In hallway adjacent to room 204 High Left	FT-82016-009107-A	< 1	FT-82016-009107-B	< 1
23	LANGDON EDUCATIONAL CAMPUS	WS- 009108	8/19/2016	2	Cooler	In hallway adjacent to room 204 Low Right	FT-82016-009108-A	< 1	FT-82016-009108-B	< 1

24	LANGDON EDUCATIONAL CAMPUS	WS- 009109	8/19/2016	2	Cooler	In hallway across from room 212	High Left	FT-82016-009109-A	< 1	FT-82016-009109-B	< 1
25	LANGDON EDUCATIONAL CAMPUS	WS-009110**	8/19/2016	2	Cooler	In hallway across from room 212	Low Right	FT-82016-009110-A	< 1	FT-82016-009110-B	6.73
			9/2/2016					Re-test A	< 1	Re-test B	< 1
26	LANGDON EDUCATIONAL CAMPUS	WS- 009113	8/19/2016	1	Cooler	In auditorium		FT-82016-009113-A	< 1	FT-82016-009113-B	< 1
27	LANGDON EDUCATIONAL CAMPUS	WS- 009114	42601	1	Health Suite	In health suite 004		FT-82016-009114-A	< 1	FT-82016-009114-B	< 1

**Filter inspected, found improperly installed, repaired, and re-sampled.