



Langdon ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009056	5/24/2018	5/24/2019	2	Combo Fountain	In classroom 212	WF-05242018-009056	11/28/2018	FT-FY19-112018-009056-A	<1	FT-FY19-112018-009056-B	<1
WS- 009061	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 101	Low Left WF-10092018-009061	11/28/2018	FT-FY19-112018-009061-A	<1	FT-FY19-112018-009061-B	<1
WS- 009062	5/23/2018	5/23/2019	1	Combo Fountain	In classroom 101	Low Mid WF-05232018-009062	11/28/2018	FT-FY19-112018-009062-A	<1	FT-FY19-112018-009062-B	<1
WS- 009063	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 101	High Right WF-10092018-009063	11/28/2018	FT-FY19-112018-009063-A	<1	FT-FY19-112018-009063-B	<1
WS- 009064	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 102	High Left WF-10092018-009064	11/28/2018	FT-FY19-112018-009064-A	<1	FT-FY19-112018-009064-B	<1
WS- 009065	5/23/2018	5/23/2019	1	Combo Fountain	In classroom 102	Low Mid WF-05232018-009065	11/28/2018	FT-FY19-112018-009065-A	<1	FT-FY19-112018-009065-B	<1
WS- 009066	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 102	Low Right WF-10092018-009066	11/28/2018	FT-FY19-112018-009066-A	<1	FT-FY19-112018-009066-B	<1
WS- 009067	5/23/2018	5/23/2019	1	Break Room	In staff work room 113	WF-05232018-009067	11/28/2018	FT-FY19-112018-009067-A	<1	FT-FY19-112018-009067-B	<1
WS- 009068	5/23/2018	5/23/2019	1	Cooler	In hallway adjacent to room 104	High Left WF-05232018-009068	11/28/2018	FT-FY19-112018-009068-A	<1	FT-FY19-112018-009068-B	<1
WS- 009069	5/23/2018	5/23/2019	1	Cooler	In hallway adjacent to room 104	Low Right WF-05232018-009069	11/28/2018	FT-FY19-112018-009069-A	<1	FT-FY19-112018-009069-B	<1
WS- 009070	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 104	Low Left WF-10092018-009070	11/28/2018	FT-FY19-112018-009070-A	<1	FT-FY19-112018-009070-B	<1
WS- 009071	5/23/2018	5/23/2019	1	Combo Fountain	In classroom 104	Low Mid WF-05232018-009071	11/28/2018	FT-FY19-112018-009071-A	<1	FT-FY19-112018-009071-B	<1
WS- 009072	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 104	High Right WF-10092018-009072	11/28/2018	FT-FY19-112018-009072-A	<1	FT-FY19-112018-009072-B	<1
WS- 009073	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 106	High Left WF-10092018-009073	11/28/2018	FT-FY19-112018-009073-A	<1	FT-FY19-112018-009073-B	<1
WS- 009074	5/23/2018	5/23/2019	1	Combo Fountain	In classroom 106	Low Mid WF-05232018-009074	11/28/2018	FT-FY19-112018-009074-A	<1	FT-FY19-112018-009074-B	<1
WS- 009075	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 106	Low Right WF-10092018-009075	11/28/2018	FT-FY19-112018-009075-A	<1	FT-FY19-112018-009075-B	<1
WS- 009076	5/23/2018	5/23/2019	1	Cooler	In hallway across from room 105	High Left WF-05232018-009076	11/28/2018	FT-FY19-112018-009076-A	<1	FT-FY19-112018-009076-B	<1
WS- 009077	5/23/2018	5/23/2019	1	Cooler	In hallway across from room 105	Low Right WF-05232018-009077	11/28/2018	FT-FY19-112018-009077-A	<1	FT-FY19-112018-009077-B	<1
WS- 009079	5/23/2018	5/23/2019	1	Combo Fountain	In classroom 107	Low Mid WF-05232018-009079	11/28/2018	FT-FY19-112018-009079-A	<1	FT-FY19-112018-009079-B	<1
WS- 009080	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 107	Low Right WF-10092018-009080	11/28/2018	FT-FY19-112018-009080-A	<1	FT-FY19-112018-009080-B	<1
WS- 009081	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 108	Low Left WF-10092018-009081	11/28/2018	FT-FY19-112018-009081-A	<1	FT-FY19-112018-009081-B	<1
WS- 009082	5/23/2018	5/23/2019	1	Combo Fountain	In classroom 108	Low Mid WF-05232018-009082	11/28/2018	FT-FY19-112018-009082-A	<1	FT-FY19-112018-009082-B	<1
WS- 009083	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 108	High Right WF-10092018-009083	11/28/2018	FT-FY19-112018-009083-A	<1	FT-FY19-112018-009083-B	<1
WS- 009084	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 109	Low Left WF-10092018-009084	11/28/2018	FT-FY19-112018-009084-A	<1	FT-FY19-112018-009084-B	<1
WS- 009085	5/23/2018	5/23/2019	1	Combo Fountain	In classroom 109	Low Mid WF-05232018-009085	11/28/2018	FT-FY19-112018-009085-A	<1	FT-FY19-112018-009085-B	<1
WS- 009086	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 109	High Right WF-10092018-009086	11/28/2018	FT-FY19-112018-009086-A	<1	FT-FY19-112018-009086-B	1.3
WS- 009087	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 110	Low Left WF-10092018-009087	11/28/2018	FT-FY19-112018-009087-A	2.4	FT-FY19-112018-009087-B	<1
WS- 009088	5/23/2018	5/23/2019	1	Combo Fountain	In classroom 110	Low Mid WF-05232018-009088	11/28/2018	FT-FY19-112018-009088-A	<1	FT-FY19-112018-009088-B	<1
WS- 009090	10/9/2018	10/9/2019	1	Classroom Faucet	In resource room 103	High Left WF-10092018-009090	11/28/2018	FT-FY19-112018-009090-A	<1	FT-FY19-112018-009090-B	<1
WS- 009091	5/23/2018	5/23/2019	1	Combo Fountain	In resource room 103	Low Mid WF-05232018-009091	11/28/2018	FT-FY19-112018-009091-A	<1	FT-FY19-112018-009091-B	<1
WS- 009092	10/9/2018	10/9/2019	1	Combo Faucet	In resource room 103	Low Right WF-10092018-009092	11/28/2018	FT-FY19-112018-009092-A	<1	FT-FY19-112018-009092-B	<1
WS- 009094	5/23/2018	5/23/2019	1	Cooler	In hallway across from room 154	High Left WF-05232018-009094	11/28/2018	FT-FY19-112018-009094-A	<1	FT-FY19-112018-009094-B	<1
WS- 009095	5/23/2018	5/23/2019	1	Cooler	In hallway across from room 154	Low Right WF-05232018-009095	11/28/2018	FT-FY19-112018-009095-A	<1	FT-FY19-112018-009095-B	<1

WS-009096	5/23/2018	5/23/2019	1	Break Room	In staff work room 154		WF-05232018-009096	11/28/2018	FT-FY19-112018-009096-A	<1	FT-FY19-112018-009096-B	<1
WS-009097	5/23/2018	5/23/2019	2	Cooler	In hallway across from room 254	High Left	WF-05232018-009097	11/28/2018	FT-FY19-112018-009097-A	<1	FT-FY19-112018-009097-B	<1
WS-009098	5/23/2018	5/23/2019	2	Cooler	In hallway across from room 254	Low Right	WF-05232018-009098	11/28/2018	FT-FY19-112018-009098-A	<1	FT-FY19-112018-009098-B	<1
WS-009099	5/23/2018	5/23/2019	2	Break Room	In staff work room 254		WF-05232018-009099	11/28/2018	FT-FY19-112018-009099-A	<1	FT-FY19-112018-009099-B	<1
WS-009102	5/23/2018	5/23/2019	2	Combo Fountain	In science lab room 247 second clockwise from entry door		WF-05232018-009102	11/28/2018	FT-FY19-112018-009102-A	<1	FT-FY19-112018-009102-B	<1
WS-009106	5/24/2018	5/24/2019	2	Break Room	In classroom 209		WF-05242018-009106	11/28/2018	FT-FY19-112018-009106-A	<1	FT-FY19-112018-009106-B	<1
WS-009107	5/23/2018	5/23/2019	2	Cooler	In hallway adjacent to room 204	High Left	WF-05232018-009107	11/28/2018	FT-FY19-112018-009107-A	<1	FT-FY19-112018-009107-B	<1
WS-009108	5/23/2018	5/23/2019	2	Cooler	In hallway adjacent to room 204	Low Right	WF-05232018-009108	11/28/2018	FT-FY19-112018-009108-A	<1	FT-FY19-112018-009108-B	<1
WS-009109	5/23/2018	5/23/2019	2	Cooler	In hallway across from room 212	High Left	WF-05232018-009109	11/28/2018	FT-FY19-112018-009109-A	<1	FT-FY19-112018-009109-B	<1
WS-009110	5/23/2018	5/23/2019	2	Cooler	In hallway across from room 212	Low Right	WF-05232018-009110	11/28/2018	FT-FY19-112018-009110-A	<1	FT-FY19-112018-009110-B	<1
WS-009113	5/23/2018	5/23/2019	1	Cooler	In auditorium		WF-05232018-009113	11/28/2018	FT-FY19-112018-009113-A	<1	FT-FY19-112018-009113-B	<1
WS-009114	5/23/2018	5/23/2019	1	Health Suite	In health suite 004		WF-05232018-009114	11/28/2018	FT-FY19-112018-009114-A	<1	FT-FY19-112018-009114-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009059	Basement	Food Prep Sink	In kitchen				11/28/2018	FT-FY19-112018-009059-A	<1	FT-FY19-112018-009059-B	<1

FY19 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009078	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 107	High Left	WF-10092018-009078	11/28/2018	FT-FY19-112018-009078-A	7.2	FT-FY19-112018-009078-B	5.5
WS-009089	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 110	High Right	WF-10092018-009089	11/28/2018	FT-FY19-112018-009089-A	5	FT-FY19-112018-009089-B	2