



# Langley Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004217	3/9/2020	3/9/2021	Basement	Cooler	In hallway adjacent to stairwell 4	WF-03092020-004217	2/4/2021	FT-FY21-012021-004217-A	<1	FT-FY21-012021-004217-B	<1
WS- 004222	3/9/2020	3/9/2021	Basement	Cooler	In hallway adjacent to stairwell 3	WF-03092020-004222	2/4/2021	FT-FY21-012021-004222-A	<1	FT-FY21-012021-004222-B	<1
WS- 004223	3/9/2020	3/9/2021	Basement	Cooler	In hallway adjacent to room B02	WF-03092020-004223	2/4/2021	FT-FY21-012021-004223-A	<1	FT-FY21-012021-004223-B	<1
WS- 004224	3/9/2020	3/9/2021	Basement	Cooler	In hallway adjacent to room B01	WF-03092020-004224	2/4/2021	FT-FY21-012021-004224-A	<1	FT-FY21-012021-004224-B	<1
WS- 004225	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 125	WF-09102020-004225	2/4/2021	FT-FY21-012021-004225-A	<1	FT-FY21-012021-004225-B	<1
WS- 004226	3/9/2020	3/9/2021	1	Combo Fountain	In classroom 125	WF-03092020-004226	2/4/2021	FT-FY21-012021-004226-A	<1	FT-FY21-012021-004226-B	<1
WS- 004227	3/9/2020	3/9/2021	1	Break Room	In staff lounge	WF-03092020-004227	2/4/2021	FT-FY21-012021-004227-A	<1	FT-FY21-012021-004227-B	<1
WS- 004228	3/9/2020	3/9/2021	1	Combo Fountain	In staff lounge	WF-03092020-004228	2/4/2021	FT-FY21-012021-004228-A	<1	FT-FY21-012021-004228-B	<1
WS- 004229	3/9/2020	3/9/2021	1	Combo Fountain	In classroom 133	WF-03092020-004229	2/4/2021	FT-FY21-012021-004229-A	<1	FT-FY21-012021-004229-B	<1
WS- 004230	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 133	WF-09102020-004230	2/4/2021	FT-FY21-012021-004230-A	<1	FT-FY21-012021-004230-B	<1
WS- 004231	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 143	WF-09102020-004231	2/4/2021	FT-FY21-012021-004231-A	<1	FT-FY21-012021-004231-B	<1
WS- 004232	3/9/2020	3/9/2021	1	Combo Fountain	In classroom 143	WF-03092020-004232	2/4/2021	FT-FY21-012021-004232-A	<1	FT-FY21-012021-004232-B	<1
WS- 004233	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 149	WF-09102020-004233	2/4/2021	FT-FY21-012021-004233-A	<1	FT-FY21-012021-004233-B	<1
WS- 004234	3/9/2020	3/9/2021	1	Combo Fountain	In classroom 149	WF-03092020-004234	2/4/2021	FT-FY21-012021-004234-A	<1	FT-FY21-012021-004234-B	<1
WS- 004235	3/9/2020	3/9/2021	1	Combo Fountain	In classroom 137	WF-03092020-004235	2/4/2021	FT-FY21-012021-004235-A	<1	FT-FY21-012021-004235-B	<1
WS- 004236	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 137	WF-09102020-004236	2/4/2021	FT-FY21-012021-004236-A	<1	FT-FY21-012021-004236-B	<1
WS- 004237	3/9/2020	3/9/2021	1	Cooler	In hallway adjacent to principals office	WF-03092020-004237	2/4/2021	FT-FY21-012021-004237-A	<1	FT-FY21-012021-004237-B	<1
WS- 004238	3/9/2020	3/9/2021	1	Cooler	In hallway adjacent to room 104	WF-03092020-004238	2/4/2021	FT-FY21-012021-004238-A	<1	FT-FY21-012021-004238-B	<1
WS- 004239	3/9/2020	3/9/2021	1	Health Suite	In health suite in treatment room 10	WF-03092020-004239	2/4/2021	FT-FY21-012021-004239-A	<1	FT-FY21-012021-004239-B	<1
WS- 004240	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 113	WF-09102020-004240	2/4/2021	FT-FY21-012021-004240-A	<1	FT-FY21-012021-004240-B	<1
WS- 004241	3/9/2020	3/9/2021	1	Combo Fountain	In classroom 113	WF-03092020-004241	2/4/2021	FT-FY21-012021-004241-A	<1	FT-FY21-012021-004241-B	<1
WS- 004242	3/9/2020	3/9/2021	1	Combo Fountain	In classroom 122	WF-03092020-004242	2/4/2021	FT-FY21-012021-004242-A	<1	FT-FY21-012021-004242-B	<1
WS- 004243	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 122	WF-09102020-004243	2/4/2021	FT-FY21-012021-004243-A	<1	FT-FY21-012021-004243-B	<1
WS- 004244	3/9/2020	3/9/2021	2	Cooler	In hallway adjacent to room 201	WF-03092020-004244	2/4/2021	FT-FY21-012021-004244-A	<1	FT-FY21-012021-004244-B	<1
WS- 004245	3/9/2020	3/9/2021	2	Cooler	In hallway adjacent to room 204	WF-03092020-004245	2/4/2021	FT-FY21-012021-004245-A	<1	FT-FY21-012021-004245-B	<1
WS- 004247	3/9/2020	3/9/2021	2	Combo Fountain	In classroom 208	WF-03092020-004247	2/4/2021	FT-FY21-012021-004247-A	<1	FT-FY21-012021-004247-B	<1
WS- 004249	3/9/2020	3/9/2021	2	Combo Fountain	In art room 217	WF-03092020-004249	2/4/2021	FT-FY21-012021-004249-A	<1	FT-FY21-012021-004249-B	<1
WS- 004251	3/9/2020	3/9/2021	2	Combo Fountain	In classroom 211	WF-03092020-004251	2/4/2021	FT-FY21-012021-004251-A	<1	FT-FY21-012021-004251-B	<1
WS- 004261	3/9/2020	3/9/2021	3	Classroom Faucet	In science lab room 332 on teachers island	WF-03092020-004261	2/4/2021	FT-FY21-012021-004261-A	<1	FT-FY21-012021-004261-B	<1
WS- 004266	3/9/2020	3/9/2021	3	Cooler	In hallway adjacent to room 304	WF-03092020-004266	2/4/2021	FT-FY21-012021-004266-A	<1	FT-FY21-012021-004266-B	<1
WS- 004268	3/9/2020	3/9/2021	3	Combo Fountain	In room 312	WF-03092020-004268	2/4/2021	FT-FY21-012021-004268-A	<1	FT-FY21-012021-004268-B	<1
WS- 012564	3/9/2020	3/9/2021	2	Combo Fountain	In classroom 230	WF-03092020-012564	2/4/2021	FT-FY21-012021-012564-A	<1	FT-FY21-012021-012564-B	<1

WS- 012566	3/9/2020	3/9/2021	3	Classroom Faucet	In science lab prep room 333	WF-03092020-012566	2/4/2021	FT-FY21-012021-012566-A	<1	FT-FY21-012021-012566-B	<1
------------	----------	----------	---	------------------	------------------------------	--------------------	----------	-------------------------	----	-------------------------	----

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004221	1/29/2021	1/29/2022	Basement	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-01292021-004221	2/4/2021	FT-FY21-012021-004221-A	<1	FT-FY21-012021-004221-B	<1