



Langley Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004127	2/13/2024	2/13/2025	2	Bottle Filler	In hallway adjacent to room 201	WF-02132024-004127	12/6/2024	FT-FY25-11082024-004127-A	<2	FT-FY25-11082024-004127-B	<2
WS- 004224	2/13/2024	2/13/2025	Basement	Cooler	In hallway adjacent to room B01	WF-02132024-004224	12/6/2024	FT-FY25-11082024-004224-A	<2	FT-FY25-11082024-004224-B	<2
WS- 004225	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 125	WF-08132024-004225	12/6/2024	FT-FY25-11082024-004225-A	<2	FT-FY25-11082024-004225-B	<2
WS- 004226	2/13/2024	2/13/2025	1	Combo Fountain	In classroom 125	WF-02132024-004226	12/6/2024	FT-FY25-11082024-004226-A	<2	FT-FY25-11082024-004226-B	<2
WS- 004227	2/13/2024	2/13/2025	1	Break Room	In staff lounge	WF-02132024-004227	12/6/2024	FT-FY25-11082024-004227-A	<2	FT-FY25-11082024-004227-B	<2
WS- 004228	2/13/2024	2/13/2025	1	Combo Fountain	In staff lounge	WF-02132024-004228	12/6/2024	FT-FY25-11082024-004228-A	<2	FT-FY25-11082024-004228-B	<2
WS- 004229	2/13/2024	2/13/2025	1	Combo Fountain	In classroom 133	WF-02132024-004229	12/6/2024	FT-FY25-11082024-004229-A	<2	FT-FY25-11082024-004229-B	<2
WS- 004230	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 133	WF-08132024-004230	12/6/2024	FT-FY25-11082024-004230-A	<2	FT-FY25-11082024-004230-B	<2
WS- 004231	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 143	WF-08132024-004231	12/6/2024	FT-FY25-11082024-004231-A	<2	FT-FY25-11082024-004231-B	<2
WS- 004232	2/13/2024	2/13/2025	1	Combo Fountain	In classroom 143	WF-02132024-004232	12/6/2024	FT-FY25-11082024-004232-A	<2	FT-FY25-11082024-004232-B	<2
WS- 004233	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 149	WF-08132024-004233	12/6/2024	FT-FY25-11082024-004233-A	<2	FT-FY25-11082024-004233-B	<2
WS- 004234	2/13/2024	2/13/2025	1	Combo Fountain	In classroom 149	WF-02132024-004234	12/6/2024	FT-FY25-11082024-004234-A	<2	FT-FY25-11082024-004234-B	<2
WS- 004235	2/13/2024	2/13/2025	1	Combo Fountain	In classroom 137	WF-02132024-004235	12/6/2024	FT-FY25-11082024-004235-A	<2	FT-FY25-11082024-004235-B	<2
WS- 004236	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 137	WF-08132024-004236	12/6/2024	FT-FY25-11082024-004236-A	<2	FT-FY25-11082024-004236-B	<2
WS- 004237	2/13/2024	2/13/2025	1	Cooler	In hallway adjacent to principals office	WF-02132024-004237	12/6/2024	FT-FY25-11082024-004237-A	<2	FT-FY25-11082024-004237-B	<2
WS- 004239	2/13/2024	2/13/2025	1	Health Suite	In health suite in treatment room 10	WF-02132024-004239	12/6/2024	FT-FY25-11082024-004239-A	<2	FT-FY25-11082024-004239-B	<2
WS- 004240	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 113	WF-08132024-004240	12/6/2024	FT-FY25-11082024-004240-A	<2	FT-FY25-11082024-004240-B	<2
WS- 004241	2/13/2024	2/13/2025	1	Combo Fountain	In classroom 113	WF-02132024-004241	12/6/2024	FT-FY25-11082024-004241-A	<2	FT-FY25-11082024-004241-B	<2
WS- 004242	2/13/2024	2/13/2025	1	Combo Fountain	In classroom 122	WF-02132024-004242	12/6/2024	FT-FY25-11082024-004242-A	<2	FT-FY25-11082024-004242-B	<2
WS- 004243	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 122	WF-08132024-004243	12/6/2024	FT-FY25-11082024-004243-A	<2	FT-FY25-11082024-004243-B	<2
WS- 004244	2/13/2024	2/13/2025	2	Cooler	In hallway adjacent to room 201	WF-02132024-004244	12/6/2024	FT-FY25-11082024-004244-A	<2	FT-FY25-11082024-004244-B	<2
WS- 004247	2/13/2024	2/13/2025	2	Combo Fountain	In classroom 208	WF-02132024-004247	12/6/2024	FT-FY25-11082024-004247-A	2.7	FT-FY25-11082024-004247-B	<2
WS- 004249	2/13/2024	2/13/2025	2	Combo Fountain	In art room 217	WF-02132024-004249	12/6/2024	FT-FY25-11082024-004249-A	4.0	FT-FY25-11082024-004249-B	<2
WS- 004261	2/13/2024	2/13/2025	3	Classroom Faucet	In science lab room 332 on teachers island	WF-02132024-004261	12/6/2024	FT-FY25-11082024-004261-A	<2	FT-FY25-11082024-004261-B	<2
WS- 004265	2/13/2024	2/13/2025	3	Cooler	In hallway adjacent to room 301	WF-02132024-004265	12/6/2024	FT-FY25-11082024-004265-A	<2	FT-FY25-11082024-004265-B	<2
WS- 004266	2/13/2024	2/13/2025	3	Cooler	In hallway adjacent to room 304	WF-02132024-004266	12/6/2024	FT-FY25-11082024-004266-A	<2	FT-FY25-11082024-004266-B	<2
WS- 004268	2/13/2024	2/13/2025	3	Combo Fountain	In room 312	WF-02132024-004268	12/6/2024	FT-FY25-11082024-004268-A	<2	FT-FY25-11082024-004268-B	<2
WS- 006893	2/13/2024	2/13/2025	3	Bottle Filler	In hallway adjacent to room 304	WF-02132024-006893	12/6/2024	FT-FY25-11082024-006893-A	<2	FT-FY25-11082024-006893-B	<2
WS- 007177	2/13/2024	2/13/2025	1	Bottle Filler	In hallway adjacent to principals office	WF-02132024-007177	12/6/2024	FT-FY25-11082024-007177-A	<2	FT-FY25-11082024-007177-B	<2
WS- 012564	2/13/2024	2/13/2025	2	Combo Fountain	In classroom 230	WF-02132024-012564	12/6/2024	FT-FY25-11082024-012564-A	<2	FT-FY25-11082024-012564-B	<2
WS- 012566	2/13/2024	2/13/2025	3	Classroom Faucet	In science lab prep room 333	WF-02132024-012566	12/6/2024	FT-FY25-11082024-012566-A	<2	FT-FY25-11082024-012566-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004221	12/18/2023	12/18/2024	Basement	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-12182023-004221	12/6/2024	FT-FY25-11082024-004221-A	<2	FT-FY25-11082024-004221-B	<2

FY25 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004251	2/13/2024	2/13/2025	2	Combo Fountain	In classroom 211	WF-02132024-004251	12/6/2024	FT-FY25-11082024-004251-A	6.0	FT-FY25-11082024-004251-B	3.8

After First Retest (Plumbing Check)

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004251	12/17/2024	12/17/2025	2	Combo Fountain	In classroom 211	WF-12172024-004251	1/7/2025	FT-FY25-12192024-004251-A	<2	FT-FY25-12192024-004251-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.