



Langley Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004217	3/4/2021	3/4/2022	Basement	Cooler	In hallway adjacent to stairwell 4	WF-03042021-004217	1/6/2022	FT-FY22-12012021-004217-A	<1	FT-FY22-12012021-004217-B	<1
WS- 004223	3/4/2021	3/4/2022	Basement	Cooler	In hallway adjacent to room B02	WF-03042021-004223	1/6/2022	FT-FY22-12012021-004223-A	<1	FT-FY22-12012021-004223-B	<1
WS- 004225	9/1/2021	9/1/2022	1	Combo Faucet	In classroom 125	WF-09012021-004225	1/6/2022	FT-FY22-12012021-004225-A	<1	FT-FY22-12012021-004225-B	<1
WS- 004226	3/4/2021	3/4/2022	1	Combo Fountain	In classroom 125	WF-03042021-004226	1/6/2022	FT-FY22-12012021-004226-A	<1	FT-FY22-12012021-004226-B	<1
WS- 004227	3/4/2021	3/4/2022	1	Break Room	In staff lounge	WF-03042021-004227	1/6/2022	FT-FY22-12012021-004227-A	<1	FT-FY22-12012021-004227-B	<1
WS- 004228	3/4/2021	3/4/2022	1	Combo Fountain	In staff lounge	WF-03042021-004228	1/6/2022	FT-FY22-12012021-004228-A	<1	FT-FY22-12012021-004228-B	<1
WS- 004229	3/4/2021	3/4/2022	1	Combo Fountain	In classroom 133	WF-03042021-004229	1/6/2022	FT-FY22-12012021-004229-A	<1	FT-FY22-12012021-004229-B	<1
WS- 004230	9/1/2021	9/1/2022	1	Combo Faucet	In classroom 133	WF-09012021-004230	1/6/2022	FT-FY22-12012021-004230-A	<1	FT-FY22-12012021-004230-B	<1
WS- 004231	9/1/2021	9/1/2022	1	Combo Faucet	In classroom 143	WF-09012021-004231	1/6/2022	FT-FY22-12012021-004231-A	<1	FT-FY22-12012021-004231-B	<1
WS- 004232	3/4/2021	3/4/2022	1	Combo Fountain	In classroom 143	WF-03042021-004232	1/6/2022	FT-FY22-12012021-004232-A	<1	FT-FY22-12012021-004232-B	<1
WS- 004233	9/1/2021	9/1/2022	1	Combo Faucet	In classroom 149	WF-09012021-004233	1/6/2022	FT-FY22-12012021-004233-A	<1	FT-FY22-12012021-004233-B	<1
WS- 004234	3/4/2021	3/4/2022	1	Combo Fountain	In classroom 149	WF-03042021-004234	1/6/2022	FT-FY22-12012021-004234-A	<1	FT-FY22-12012021-004234-B	<1
WS- 004237	3/4/2021	3/4/2022	1	Cooler	In hallway adjacent to principals office	WF-03042021-004237	1/6/2022	FT-FY22-12012021-004237-A	<1	FT-FY22-12012021-004237-B	<1
WS- 004238	3/4/2021	3/4/2022	1	Cooler	In hallway adjacent to room 104	WF-03042021-004238	1/6/2022	FT-FY22-12012021-004238-A	<1	FT-FY22-12012021-004238-B	<1
WS- 004239	3/4/2021	3/4/2022	1	Health Suite	In health suite in treatment room 10	WF-03042021-004239	1/6/2022	FT-FY22-12012021-004239-A	<1	FT-FY22-12012021-004239-B	<1
WS- 004240	9/1/2021	9/1/2022	1	Combo Faucet	In classroom 113	WF-09012021-004240	1/6/2022	FT-FY22-12012021-004240-A	<1	FT-FY22-12012021-004240-B	<1
WS- 004241	3/4/2021	3/4/2022	1	Combo Fountain	In classroom 113	WF-03042021-004241	1/6/2022	FT-FY22-12012021-004241-A	<1	FT-FY22-12012021-004241-B	<1
WS- 004242	3/4/2021	3/4/2022	1	Combo Fountain	In classroom 122	WF-03042021-004242	1/6/2022	FT-FY22-12012021-004242-A	<1	FT-FY22-12012021-004242-B	<1
WS- 004243	9/1/2021	9/1/2022	1	Combo Faucet	In classroom 122	WF-09012021-004243	1/6/2022	FT-FY22-12012021-004243-A	<1	FT-FY22-12012021-004243-B	<1
WS- 004244	3/4/2021	3/4/2022	2	Cooler	In hallway adjacent to room 201	WF-03042021-004244	1/6/2022	FT-FY22-12012021-004244-A	<1	FT-FY22-12012021-004244-B	<1
WS- 004245	3/4/2021	3/4/2022	2	Cooler	In hallway adjacent to room 204	WF-03042021-004245	1/6/2022	FT-FY22-12012021-004245-A	<1	FT-FY22-12012021-004245-B	<1
WS- 004247	3/4/2021	3/4/2022	2	Combo Fountain	In classroom 208	WF-03042021-004247	1/6/2022	FT-FY22-12012021-004247-A	<1	FT-FY22-12012021-004247-B	<1
WS- 004249	3/4/2021	3/4/2022	2	Combo Fountain	In art room 217	WF-03042021-004249	1/6/2022	FT-FY22-12012021-004249-A	<1	FT-FY22-12012021-004249-B	<1
WS- 004251	3/4/2021	3/4/2022	2	Combo Fountain	In classroom 211	WF-03042021-004251	1/6/2022	FT-FY22-12012021-004251-A	<1	FT-FY22-12012021-004251-B	<1
WS- 004261	3/4/2021	3/4/2022	3	Classroom Faucet	In science lab room 332 on teachers island	WF-03042021-004261	1/6/2022	FT-FY22-12012021-004261-A	<1	FT-FY22-12012021-004261-B	<1
WS- 004265	3/4/2021	3/4/2022	3	Cooler	In hallway adjacent to room 301	WF-03042021-004265	1/6/2022	FT-FY22-12012021-004265-A	<1	FT-FY22-12012021-004265-B	<1
WS- 004266	3/4/2021	3/4/2022	3	Cooler	In hallway adjacent to room 304	WF-03042021-004266	1/6/2022	FT-FY22-12012021-004266-A	<1	FT-FY22-12012021-004266-B	<1
WS- 004268	3/4/2021	3/4/2022	3	Combo Fountain	In room 312	WF-03042021-004268	1/6/2022	FT-FY22-12012021-004268-A	<1	FT-FY22-12012021-004268-B	<1
WS- 012564	3/4/2021	3/4/2022	2	Combo Fountain	In classroom 230	WF-03042021-012564	1/6/2022	FT-FY22-12012021-012564-A	<1	FT-FY22-12012021-012564-B	<1
WS- 012566	3/4/2021	3/4/2022	3	Classroom Faucet	In science lab prep room 333	WF-03042021-012566	1/6/2022	FT-FY22-12012021-012566-A	<1	FT-FY22-12012021-012566-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004221	1/29/2021	1/29/2022	Basement	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-01292021-004221	1/6/2022	FT-FY22-12012021-004221-A	<1	FT-FY22-12012021-004221-B	<1