



Langley Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004109	9/29/2023	9/29/2024	2	Bottle Filler	In hallway adjacent to room 204	WF-09292023-004109	12/12/2023	FT-FY24-11012023-004109-A	<1	FT-FY24-11012023-004109-B	<1
WS- 004127	8/31/2023	8/31/2024	2	Bottle Filler	In hallway adjacent to room 201	WF-08312023-004127	12/12/2023	FT-FY24-11012023-004127-A	<1	FT-FY24-11012023-004127-B	<1
WS- 004217	2/17/2023	2/17/2024	Basement	Cooler	In hallway adjacent to stairwell 4	WF-02172023-004217	12/12/2023	FT-FY24-11012023-004217-A	<1	FT-FY24-11012023-004217-B	<1
WS- 004222	2/17/2023	2/17/2024	Basement	Cooler	In hallway adjacent to stairwell 3	WF-02172023-004222	12/12/2023	FT-FY24-11012023-004222-A	<1	FT-FY24-11012023-004222-B	<1
WS- 004223	2/17/2023	2/17/2024	Basement	Cooler	In hallway adjacent to room B02	WF-02172023-004223	12/12/2023	FT-FY24-11012023-004223-A	<1	FT-FY24-11012023-004223-B	<1
WS- 004224	2/17/2023	2/17/2024	Basement	Cooler	In hallway adjacent to room B01	WF-02172023-004224	12/12/2023	FT-FY24-11012023-004224-A	<1	FT-FY24-11012023-004224-B	<1
WS- 004225	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 125	WF-08162023-004225	12/12/2023	FT-FY24-11012023-004225-A	1.1	FT-FY24-11012023-004225-B	<1
WS- 004226	2/17/2023	2/17/2024	1	Combo Fountain	In classroom 125	WF-02172023-004226	12/12/2023	FT-FY24-11012023-004226-A	<1	FT-FY24-11012023-004226-B	<1
WS- 004227	2/17/2023	2/17/2024	1	Break Room	In staff lounge	WF-02172023-004227	12/12/2023	FT-FY24-11012023-004227-A	<1	FT-FY24-11012023-004227-B	<1
WS- 004228	2/17/2023	2/17/2024	1	Combo Fountain	In staff lounge	WF-02172023-004228	12/12/2023	FT-FY24-11012023-004228-A	4.0	FT-FY24-11012023-004228-B	1.3
WS- 004229	2/17/2023	2/17/2024	1	Combo Fountain	In classroom 133	WF-02172023-004229	12/12/2023	FT-FY24-11012023-004229-A	<1	FT-FY24-11012023-004229-B	<1
WS- 004230	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 133	WF-08162023-004230	12/12/2023	FT-FY24-11012023-004230-A	1.2	FT-FY24-11012023-004230-B	<1
WS- 004231	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 143	WF-08162023-004231	12/12/2023	FT-FY24-11012023-004231-A	<1	FT-FY24-11012023-004231-B	1.2
WS- 004232	2/17/2023	2/17/2024	1	Combo Fountain	In classroom 143	WF-02172023-004232	12/12/2023	FT-FY24-11012023-004232-A	<1	FT-FY24-11012023-004232-B	<1
WS- 004233	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 149	WF-08162023-004233	12/12/2023	FT-FY24-11012023-004233-A	4.5	FT-FY24-11012023-004233-B	<1
WS- 004234	2/17/2023	2/17/2024	1	Combo Fountain	In classroom 149	WF-02172023-004234	12/12/2023	FT-FY24-11012023-004234-A	4.0	FT-FY24-11012023-004234-B	<1
WS- 004235	2/17/2023	2/17/2024	1	Combo Fountain	In classroom 137	WF-02172023-004235	12/12/2023	FT-FY24-11012023-004235-A	2.7	FT-FY24-11012023-004235-B	<1
WS- 004237	2/17/2023	2/17/2024	1	Cooler	In hallway adjacent to principals office	WF-02172023-004237	12/12/2023	FT-FY24-11012023-004237-A	<1	FT-FY24-11012023-004237-B	<1
WS- 004238	2/17/2023	2/17/2024	1	Cooler	In hallway adjacent to room 104	WF-02172023-004238	12/12/2023	FT-FY24-11012023-004238-A	<1	FT-FY24-11012023-004238-B	<1
WS- 004239	2/17/2023	2/17/2024	1	Health Suite	In health suite in treatment room 10	WF-02172023-004239	12/12/2023	FT-FY24-11012023-004239-A	1.1	FT-FY24-11012023-004239-B	<1
WS- 004240	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 113	WF-08162023-004240	12/12/2023	FT-FY24-11012023-004240-A	3.9	FT-FY24-11012023-004240-B	<1
WS- 004241	2/17/2023	2/17/2024	1	Combo Fountain	In classroom 113	WF-02172023-004241	12/12/2023	FT-FY24-11012023-004241-A	<1	FT-FY24-11012023-004241-B	<1
WS- 004242	2/17/2023	2/17/2024	1	Combo Fountain	In classroom 122	WF-02172023-004242	12/12/2023	FT-FY24-11012023-004242-A	<1	FT-FY24-11012023-004242-B	<1
WS- 004243	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 122	WF-08162023-004243	12/12/2023	FT-FY24-11012023-004243-A	3.3	FT-FY24-11012023-004243-B	<1
WS- 004244	8/31/2023	8/31/2024	2	Cooler	In hallway adjacent to room 201	WF-08312023-004244	12/12/2023	FT-FY24-11012023-004244-A	<1	FT-FY24-11012023-004244-B	<1
WS- 004245	9/29/2023	9/29/2024	2	Cooler	In hallway adjacent to room 204	WF-09292023-004245	12/12/2023	FT-FY24-11012023-004245-A	<1	FT-FY24-11012023-004245-B	<1
WS- 004247	2/17/2023	2/17/2024	2	Combo Fountain	In classroom 208	WF-02172023-004247	12/12/2023	FT-FY24-11012023-004247-A	2.4	FT-FY24-11012023-004247-B	<1
WS- 004249	2/17/2023	2/17/2024	2	Combo Fountain	In art room 217	WF-02172023-004249	12/12/2023	FT-FY24-11012023-004249-A	1.3	FT-FY24-11012023-004249-B	<1
WS- 004251	2/17/2023	2/17/2024	2	Combo Fountain	In classroom 211	WF-02172023-004251	12/12/2023	FT-FY24-11012023-004251-A	<1	FT-FY24-11012023-004251-B	<1
WS- 004261	2/17/2023	2/17/2024	3	Classroom Faucet	In science lab room 332 on teachers island	WF-02172023-004261	12/12/2023	FT-FY24-11012023-004261-A	<1	FT-FY24-11012023-004261-B	<1
WS- 004265	2/17/2023	2/17/2024	3	Cooler	In hallway adjacent to room 301	WF-02172023-004265	12/12/2023	FT-FY24-11012023-004265-A	<1	FT-FY24-11012023-004265-B	<1
WS- 004268	2/17/2023	2/17/2024	3	Combo Fountain	In room 312	WF-02172023-004268	12/12/2023	FT-FY24-11012023-004268-A	1.0	FT-FY24-11012023-004268-B	<1
WS- 007177	2/17/2023	3/17/2024	1	Bottle Filler	In hallway adjacent to principals office	WF-02172023-007177	12/12/2023	FT-FY24-11012023-007177-A	<1	FT-FY24-11012023-007177-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004221	12/28/2022	12/28/2023	Basement	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-12282022-004221	12/12/2023	FT-FY24-11012023-004221-A	<1	FT-FY24-11012023-004221-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004236	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 137	WF-08162023-004236	12/12/2023	FT-FY24-11012023-004236-A	5.2	FT-FY24-11012023-004236-B	<1
WS- 012564	2/17/2023	2/17/2024	2	Combo Fountain	In classroom 230	WF-02172023-012564	12/12/2023	FT-FY24-11012023-012564-A	5.1	FT-FY24-11012023-012564-B	2.0
WS- 012566	2/17/2023	2/17/2024	3	Classroom Faucet	In science lab prep room 333	WF-02172023-012566	12/12/2023	FT-FY24-11012023-012566-A	21.9	FT-FY24-11012023-012566-B	6.9