



# Langley ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004217	3/18/2019	3/18/2020	Basement	Cooler	In hallway adjacent to stairwell 4	WF-03182019-004217	11/24/2019	FT-FY20-112019-004217-A	<1	FT-FY20-112019-004217-B	<1
WS- 004222	3/18/2019	3/18/2020	Basement	Cooler	In hallway adjacent to stairwell 3	WF-03182019-004222	11/24/2019	FT-FY20-112019-004222-A	<1	FT-FY20-112019-004222-B	<1
WS- 004223	3/18/2019	3/18/2020	Basement	Cooler	In hallway adjacent to room B02	WF-03182019-004223	11/24/2019	FT-FY20-112019-004223-A	<1	FT-FY20-112019-004223-B	<1
WS- 004224	3/18/2019	3/18/2020	Basement	Cooler	In hallway adjacent to room B01	WF-03182019-004224	11/24/2019	FT-FY20-112019-004224-A	<1	FT-FY20-112019-004224-B	<1
WS- 004225	9/25/2019	9/25/2020	1	Combo Faucet	In classroom 125	WF-09252019-004225	11/24/2019	FT-FY20-112019-004225-A	<1	FT-FY20-112019-004225-B	<1
WS- 004226	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 125	WF-03182019-004226	11/24/2019	FT-FY20-112019-004226-A	<1	FT-FY20-112019-004226-B	<1
WS- 004227	3/18/2019	3/18/2020	1	Break Room	In staff lounge	WF-03182019-004227	11/24/2019	FT-FY20-112019-004227-A	<1	FT-FY20-112019-004227-B	<1
WS- 004228	3/18/2019	3/18/2020	1	Combo Fountain	In staff lounge	WF-03182019-004228	11/24/2019	FT-FY20-112019-004228-A	<1	FT-FY20-112019-004228-B	<1
WS- 004229	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 133	WF-03182019-004229	11/24/2019	FT-FY20-112019-004229-A	<1	FT-FY20-112019-004229-B	<1
WS- 004230	9/25/2019	9/25/2020	1	Combo Faucet	In classroom 133	WF-09252019-004230	11/24/2019	FT-FY20-112019-004230-A	<1	FT-FY20-112019-004230-B	<1
WS- 004231	9/25/2019	9/25/2020	1	Combo Faucet	In classroom 143	WF-09252019-004231	11/24/2019	FT-FY20-112019-004231-A	2	FT-FY20-112019-004231-B	<1
WS- 004232	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 143	WF-03182019-004232	11/24/2019	FT-FY20-112019-004232-A	<1	FT-FY20-112019-004232-B	<1
WS- 004233	9/25/2019	9/25/2020	1	Combo Faucet	In classroom 149	WF-09252019-004233	11/24/2019	FT-FY20-112019-004233-A	<1	FT-FY20-112019-004233-B	<1
WS- 004234	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 149	WF-03182019-004234	11/24/2019	FT-FY20-112019-004234-A	<1	FT-FY20-112019-004234-B	<1
WS- 004235	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 137	WF-03182019-004235	11/24/2019	FT-FY20-112019-004235-A	<1	FT-FY20-112019-004235-B	<1
WS- 004236	9/25/2019	9/25/2020	1	Combo Faucet	In classroom 137	WF-09252019-004236	11/24/2019	FT-FY20-112019-004236-A	1.6	FT-FY20-112019-004236-B	<1
WS- 004237	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to principals office	WF-03182019-004237	11/24/2019	FT-FY20-112019-004237-A	<1	FT-FY20-112019-004237-B	<1
WS- 004239	3/18/2019	3/18/2020	1	Health Suite	In health suite in treatment room 10	WF-03182019-004239	11/24/2019	FT-FY20-112019-004239-A	<1	FT-FY20-112019-004239-B	<1
WS- 004240	9/25/2019	9/25/2020	1	Combo Faucet	In classroom 113	WF-09252019-004240	11/24/2019	FT-FY20-112019-004240-A	2.9	FT-FY20-112019-004240-B	<1
WS- 004241	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 113	WF-03182019-004241	11/24/2019	FT-FY20-112019-004241-A	<1	FT-FY20-112019-004241-B	<1
WS- 004242	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 122	WF-03182019-004242	11/24/2019	FT-FY20-112019-004242-A	<1	FT-FY20-112019-004242-B	<1
WS- 004243	9/25/2019	9/25/2020	1	Combo Faucet	In classroom 122	WF-09252019-004243	11/24/2019	FT-FY20-112019-004243-A	<1	FT-FY20-112019-004243-B	<1
WS- 004244	3/18/2019	3/18/2020	2	Cooler	In hallway adjacent to room 201	WF-03182019-004244	11/24/2019	FT-FY20-112019-004244-A	<1	FT-FY20-112019-004244-B	<1
WS- 004245	8/12/2019	8/12/2020	2	Cooler	In hallway adjacent to room 204	WF-08122019-004245	11/24/2019	FT-FY20-112019-004245-A	<1	FT-FY20-112019-004245-B	<1
WS- 004247	3/18/2019	3/18/2020	2	Combo Fountain	In classroom 208	WF-03182019-004247	11/24/2019	FT-FY20-112019-004247-A	<1	FT-FY20-112019-004247-B	<1
WS- 004249	3/18/2019	3/18/2020	2	Combo Fountain	In art room 217	WF-03182019-004249	11/24/2019	FT-FY20-112019-004249-A	<1	FT-FY20-112019-004249-B	<1
WS- 004251	3/18/2019	3/18/2020	2	Combo Fountain	In classroom 211	WF-03182019-004251	11/24/2019	FT-FY20-112019-004251-A	<1	FT-FY20-112019-004251-B	<1
WS- 004261	3/18/2019	3/18/2020	3	Classroom Faucet	In science lab room 332 on teachers island	WF-03182019-004261	11/24/2019	FT-FY20-112019-004261-A	<1	FT-FY20-112019-004261-B	<1
WS- 004265	3/18/2019	3/18/2020	3	Cooler	In hallway adjacent to room 301	WF-03182019-004265	11/24/2019	FT-FY20-112019-004265-A	<1	FT-FY20-112019-004265-B	<1
WS- 004266	3/18/2019	3/18/2020	3	Cooler	In hallway adjacent to room 304	WF-03182019-004266	11/24/2019	FT-FY20-112019-004266-A	<1	FT-FY20-112019-004266-B	<1
WS- 004268	3/18/2019	3/18/2020	3	Combo Fountain	In room 312	WF-03182019-004268	11/24/2019	FT-FY20-112019-004268-A	<1	FT-FY20-112019-004268-B	<1

WS- 012564	3/18/2019	3/18/2020	2	Combo Fountain	In classroom 230	WF-03182019-012564	11/24/2019	FT-FY20-112019-012564-A	<1	FT-FY20-112019-012564-B	<1
WS- 012566	3/18/2019	3/18/2020	3	Classroom Faucet	In science lab prep room 333	WF-03182019-012566	11/24/2019	FT-FY20-112019-012566-A	3.2	FT-FY20-112019-012566-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004221	7/3/2019	7/3/2020	Basement	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-07032019-004221	11/24/2019	FT-FY20-112019-004221-A	<1	FT-FY20-112019-004221-B	<1