



# LANGLEY LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	LANGLEY ES	5/6/2016	WS-004216	Utility	Basement	In sub basement tunnel(water source)	WT-042916-4233- A	37.9	WT-042916-4233- B	2.69	Non-drinking water source - Not accessible to children		
2	LANGLEY ES	5/6/2016	WS-004217	Cooler	Basement	In sub basement hallway adjacent to stair 4	WT-042916-4234- A	< 1	WT-042916-4234- B	< 1			
3	LANGLEY ES	5/6/2016	WS-004218	Kitchen	Basement	In sub basement kitchen first from left	WT-042916-4235- A	< 1	WT-042916-4235- B	< 1			
4	LANGLEY ES	5/6/2016	WS-004219	Kitchen	Basement	In sub basement kitchen second from left (shower head)	WT-042916-4236- A	< 1	WT-042916-4236- B	< 1			
5	LANGLEY ES	5/6/2016	WS-004220	Kitchen	Basement	In sub basement kitchen third from left	WT-042916-4237- A	< 1	WT-042916-4237- B	< 1			
6	LANGLEY ES	5/6/2016	WS-004221	Kitchen	Basement	In sub basement kitchen last from left Right	WT-042916-4238- A	< 1	WT-042916-4238- B	< 1			
7	LANGLEY ES	5/6/2016	WS-004222	Cooler	Basement	In sub basement hallway adjacent to stair 3	WT-042916-4239- A	< 1	WT-042916-4239- B	< 1			
8	LANGLEY ES	5/6/2016	WS-004223	Cooler	Basement	In hallway adjacent to room B02	WT-042916-4240- A	< 1	WT-042916-4240- B	< 1			
9	LANGLEY ES	5/6/2016	WS-004224	Cooler	Basement	In hallway adjacent to room B01	WT-042916-4241- A	< 1	WT-042916-4241- B	< 1			
10	LANGLEY ES	5/6/2016	WS-004225	Classroom	1	In classroom 125	WT-042916-4242- A	1.04	WT-042916-4242- B	< 1			
11	LANGLEY ES	5/6/2016	WS-004226	Fountain	1	In classroom 125	WT-042916-4243- A	1.31	WT-042916-4243- B	< 1			
12	LANGLEY ES	5/6/2016	WS-004227	Classroom	1	In staff lounge	WT-042916-4244- A	< 1	WT-042916-4244- B	< 1			
13	LANGLEY ES	5/6/2016	WS-004228	Fountain	1	In staff lounch	WT-042916-4245- A	< 1	WT-042916-4245- B	< 1			
14	LANGLEY ES	5/6/2016	WS-004229	Fountain	1	In classroom 133	WT-042916-4246- A	< 1	WT-042916-4246- B	< 1			
15	LANGLEY ES	5/6/2016	WS-004230	Classroom	1	In classroom 133	WT-042916-4247- A	< 1	WT-042916-4247- B	< 1			
16	LANGLEY ES	5/6/2016	WS-004231	Classroom	1	In classroom 143	WT-042916-4248- A	< 1	WT-042916-4248- B	< 1			
17	LANGLEY ES	5/6/2016	WS-004232	Fountain	1	In classroom 143	WT-042916-4249- A	< 1	WT-042916-4249- B	< 1			
18	LANGLEY ES	5/6/2016	WS-004233	Classroom	1	In classroom 149	WT-042916-4250- A	< 1	WT-042916-4250- B	< 1			
19	LANGLEY ES	5/6/2016	WS-004234	Fountain	1	In classroom 149	WT-042916-4251- A	1.24	WT-042916-4251- B	< 1			
20	LANGLEY ES	5/6/2016	WS-004235	Fountain	1	In classroom 137	WT-042916-4252- A	< 1	WT-042916-4252- B	< 1			
21	LANGLEY ES	5/6/2016	WS-004236	Classroom	1	In classroom 137	WT-042916-4253- A	< 1	WT-042916-4253- B	< 1			
22	LANGLEY ES	5/6/2016	WS-004237	Cooler	1	In hallway adjacent to principals office	WT-042916-4254- A	< 1	WT-042916-4254- B	< 1			
23	LANGLEY ES	5/6/2016	WS-004238	Cooler	1	In hallway adjacent to room 104	WT-042916-4255- A	< 1	WT-042916-4255- B	< 1			
24	LANGLEY ES	5/6/2016	WS-004239	Health Suite	1	In treatment room 10	WT-042916-4256- A	< 1	WT-042916-4256- B	< 1			
25	LANGLEY ES	5/6/2016	WS-004240	Classroom	1	In classroom 113	WT-042916-4257- A	< 1	WT-042916-4257- B	< 1			
26	LANGLEY ES	5/6/2016	WS-004241	Fountain	1	In classroom 113	WT-042916-4258- A	< 1	WT-042916-4258- B	< 1			
27	LANGLEY ES	5/6/2016	WS-004242	Fountain	1	In classroom 122	WT-042916-4259- A	1.71	WT-042916-4259- B	< 1			
28	LANGLEY ES	5/6/2016	WS-004243	Classroom	1	In classroom 122	WT-042916-4260- A	< 1	WT-042916-4260- B	< 1			
29	LANGLEY ES	5/6/2016	WS-004244	Cooler	2	In hallway adjacent to room 201	WT-042916-4261- A	< 1	WT-042916-4261- B	< 1			
30	LANGLEY ES	5/6/2016	WS-004245	Cooler	2	In hallway adjacent to room 204	WT-042916-4262- A	< 1	WT-042916-4262- B	< 1			
31	LANGLEY ES	5/6/2016	WS-004246	Classroom	2	In classroom 208	WT-042916-4263- A	< 1	WT-042916-4263- B	< 1			
32	LANGLEY ES	5/6/2016	WS-004247	Fountain	2	In classroom 208	WT-042916-4264- A	1.81	WT-042916-4264- B	< 1			
33	LANGLEY ES	5/6/2016	WS-004248	Classroom	2	In classroom 217	WT-042916-4265- A	1.22	WT-042916-4265- B	1.62			
34	LANGLEY ES	5/6/2016	WS-004249	Fountain	2	In classroom 217	WT-042916-4266- A	1.01	WT-042916-4266- B	< 1			
35	LANGLEY ES	5/6/2016	WS-004250	Classroom	2	In classroom 211	WT-042916-4267- A	< 1	WT-042916-4267- B	< 1			
36	LANGLEY ES	5/6/2016	WS-004251	Fountain	2	In classroom 211	WT-042916-4268- A	1.98	WT-042916-4268- B	< 1			
37	LANGLEY ES	5/6/2016	WS-004252	Classroom	3	In classroom 320	WT-042916-4269- A	< 1	WT-042916-4269- B	< 1			
38	LANGLEY ES	5/6/2016	WS-004253	Classroom	3	In classroom 332 south wall first from left	WT-042916-4270- A	9.49	WT-042916-4270- B	< 1			
39	LANGLEY ES	5/6/2016	WS-004254	Classroom	3	In classroom 332 south wall second from left	WT-042916-4271- A	12.2	WT-042916-4271- B	< 1			
40	LANGLEY ES	5/6/2016	WS-004255	Classroom	3	In classroom 332 west wall first from left	WT-042916-4272- A	5.63	WT-042916-4272- B	< 1			
41	LANGLEY ES	5/6/2016	WS-004256	Classroom	3	In classroom 332 west wall second from left	WT-042916-4273- A	10.8	WT-042916-4273- B	< 1			
42	LANGLEY ES	5/6/2016	WS-004257	Classroom	3	In classroom 332 west wall third from left	WT-042916-4274- A	4.09	WT-042916-4274- B	< 1			
43	LANGLEY ES	5/6/2016	WS-004258	Classroom	3	In classroom 332 west wall forth from left	WT-042916-4275- A	5.95	WT-042916-4275- B	< 1			
44	LANGLEY ES	5/6/2016	WS-004259	Classroom	3	In classroom 332 Wes wall fifth from left	WT-042916-4276- A	3.96	WT-042916-4276- B	< 1			
45	LANGLEY ES	5/6/2016	WS-004260	Classroom	3	In classroom 332 west wall last from left	WT-042916-4277- A	7.21	WT-042916-4277- B	< 1			
46	LANGLEY ES	5/6/2016	WS-004261	Classroom	3	In classroom 332 north wall	WT-042916-4278- A	< 1	WT-042916-4278- B	< 1			
47	LANGLEY ES	5/6/2016	WS-004262	Classroom	3	In classroom 332 east wall second from left	WT-042916-4279- A	3.72	WT-042916-4279- B	< 1			
48	LANGLEY ES	5/6/2016	WS-004263	Classroom	3	In classroom 332 east wall last from left	WT-042916-4280- A	17.5	WT-042916-4280- B	< 1	Filter will be installed and retested		
49	LANGLEY ES	5/6/2016	WS-004264	Classroom	3	In classroom 332 east wall first from left	WT-042916-4281- A	52.2	WT-042916-4281- B	< 1	Filter will be installed and retested		
50	LANGLEY ES	5/6/2016	WS-004265	Cooler	3	In hallway adjacent to room 301	WT-042916-4282- A	< 1	WT-042916-4282- B	< 1			



# LANGLEY LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
51	LANGLEY ES	5/6/2016	WS- 004266	Cooler	3	In hallway adjacent to room 304	WT-042916-4283- A	< 1	WT-042916-4283- B	< 1				
52	LANGLEY ES	5/6/2016	WS- 004267	Classroom	3	In music room	WT-042916-4284- A	1.73	WT-042916-4284- B	< 1				
53	LANGLEY ES	5/6/2016	WS- 004268	Fountain	3	In music room	WT-042916-4285- A	1.39	WT-042916-4285- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.