



Langley ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004217	3/26/2018	3/26/2019	Basement	Cooler	In hallway adjacent to stairwell 4	WF-03262018-004217	11/20/2018	FT-FY19-112018-004217-A	< 1	FT-FY19-112018-004217-B	< 1
WS-004222	3/26/2018	3/26/2019	Basement	Cooler	In hallway adjacent to stairwell 3	WF-03262018-004222	11/20/2018	FT-FY19-112018-004222-A	< 1	FT-FY19-112018-004222-B	< 1
WS-004223	3/26/2018	3/26/2019	Basement	Cooler	In hallway adjacent to room B02	WF-03262018-004223	11/20/2018	FT-FY19-112018-004223-A	< 1	FT-FY19-112018-004223-B	< 1
WS-004224	3/26/2018	3/26/2019	Basement	Cooler	In hallway adjacent to room B01	WF-03262018-004224	11/20/2018	FT-FY19-112018-004224-A	< 1	FT-FY19-112018-004224-B	< 1
WS-004225	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 125	WF-10032018-004225	11/20/2018	FT-FY19-112018-004225-A	< 1	FT-FY19-112018-004225-B	< 1
WS-004226	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 125	WF-03262018-004226	11/20/2018	FT-FY19-112018-004226-A	< 1	FT-FY19-112018-004226-B	< 1
WS-004227	3/26/2018	3/26/2019	1	Break Room	In staff lounge	WF-03262018-004227	11/20/2018	FT-FY19-112018-004227-A	< 1	FT-FY19-112018-004227-B	< 1
WS-004228	3/26/2018	3/26/2019	1	Combo Fountain	In staff lounge	WF-03262018-004228	11/20/2018	FT-FY19-112018-004228-A	< 1	FT-FY19-112018-004228-B	< 1
WS-004229	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 133	WF-03262018-004229	11/20/2018	FT-FY19-112018-004229-A	< 1	FT-FY19-112018-004229-B	< 1
WS-004230	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 133	WF-10032018-004230	11/20/2018	FT-FY19-112018-004230-A	< 1	FT-FY19-112018-004230-B	< 1
WS-004231	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 143	WF-10032018-004231	11/20/2018	FT-FY19-112018-004231-A	< 1	FT-FY19-112018-004231-B	< 1
WS-004232	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 143	WF-03262018-004232	11/20/2018	FT-FY19-112018-004232-A	< 1	FT-FY19-112018-004232-B	< 1
WS-004233	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 149	WF-10032018-004233	11/20/2018	FT-FY19-112018-004233-A	< 1	FT-FY19-112018-004233-B	< 1
WS-004234	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 149	WF-03262018-004234	11/20/2018	FT-FY19-112018-004234-A	< 1	FT-FY19-112018-004234-B	< 1
WS-004235	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 137	WF-03262018-004235	11/20/2018	FT-FY19-112018-004235-A	< 1	FT-FY19-112018-004235-B	< 1
WS-004236	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 137	WF-10032018-004236	11/20/2018	FT-FY19-112018-004236-A	< 1	FT-FY19-112018-004236-B	< 1
WS-004237	3/26/2018	3/26/2019	1	Cooler	In hallway adjacent to principals office	WF-03262018-004237	11/20/2018	FT-FY19-112018-004237-A	< 1	FT-FY19-112018-004237-B	< 1
WS-004238	3/26/2018	3/26/2019	1	Cooler	In hallway adjacent to room 104	WF-03262018-004238	11/20/2018	FT-FY19-112018-004238-A	< 1	FT-FY19-112018-004238-B	< 1
WS-004239	3/26/2018	3/26/2019	1	Health Suite	In health suite in treatment room 10	WF-03262018-004239	11/20/2018	FT-FY19-112018-004239-A	< 1	FT-FY19-112018-004239-B	< 1
WS-004240	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 113	WF-10032018-004240	11/20/2018	FT-FY19-112018-004240-A	< 1	FT-FY19-112018-004240-B	< 1
WS-004241	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 113	WF-03262018-004241	11/20/2018	FT-FY19-112018-004241-A	< 1	FT-FY19-112018-004241-B	< 1
WS-004242	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 122	WF-03262018-004242	11/20/2018	FT-FY19-112018-004242-A	< 1	FT-FY19-112018-004242-B	< 1
WS-004243	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 122	WF-10032018-004243	11/20/2018	FT-FY19-112018-004243-A	< 1	FT-FY19-112018-004243-B	< 1
WS-004244	3/26/2018	3/26/2019	2	Cooler	In hallway adjacent to room 201	WF-03262018-004244	11/20/2018	FT-FY19-112018-004244-A	< 1	FT-FY19-112018-004244-B	< 1
WS-004245	8/20/2018	8/20/2019	2	Cooler	In hallway adjacent to room 204	WF-08202018-004245	11/20/2018	FT-FY19-112018-004245-A	< 1	FT-FY19-112018-004245-B	< 1
WS-004247	3/26/2018	3/26/2019	2	Combo Fountain	In classroom 208	WF-03262018-004247	11/20/2018	FT-FY19-112018-004247-A	< 1	FT-FY19-112018-004247-B	< 1
WS-004249	3/26/2018	3/26/2019	2	Combo Fountain	In art room 217	WF-03262018-004249	11/20/2018	FT-FY19-112018-004249-A	< 1	FT-FY19-112018-004249-B	< 1
WS-004251	3/26/2018	3/26/2019	2	Combo Fountain	In classroom 211	WF-03262018-004251	11/20/2018	FT-FY19-112018-004251-A	< 1	FT-FY19-112018-004251-B	< 1
WS-004261	3/26/2018	3/26/2019	3	Classroom Faucet	In science lab room 332 ninth clockwise from left entry door	WF-3262018-004261	11/20/2018	FT-FY19-112018-004261-A	< 1	FT-FY19-112018-004261-B	< 1
WS-004265	3/26/2018	3/26/2019	3	Cooler	In hallway adjacent to room 301	WF-03262018-004265	11/20/2018	FT-FY19-112018-004265-A	< 1	FT-FY19-112018-004265-B	< 1
WS-004266	3/26/2018	3/26/2019	3	Cooler	In hallway adjacent to room 304	WF-03262018-004266	11/20/2018	FT-FY19-112018-004266-A	< 1	FT-FY19-112018-004266-B	< 1
WS-004268	3/26/2018	3/26/2019	3	Combo Fountain	In BCS room adjacent to room 313	WF-03262018-004268	11/20/2018	FT-FY19-112018-004268-A	< 1	FT-FY19-112018-004268-B	< 1
WS-012564	3/26/2018	3/26/2019	2	Combo Fountain	In classroom 230	WF-03262018-012564	11/20/2018	FT-FY19-112018-012564-A	< 1	FT-FY19-112018-012564-B	< 1

WS- 012566	3/26/2018	3/26/2019	3	Classroom Faucet	In science lab prep room 333	WF-3262018-012566	11/20/2018	FT-FY19-112018-012566-A	< 1	FT-FY19-112018-012566-B	< 1
------------	-----------	-----------	---	------------------	------------------------------	-------------------	------------	-------------------------	-----	-------------------------	-----

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004221	Basement	Food Prep Sink	In kitchen fourth clockwise from entry door	11/20/2018	FT-FY19-112018-004221-A	< 1	FT-FY19-112018-004221-B	< 1