



# Lasalle Backus Education Campus Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000550	5/12/2020	5/12/2021	Basement	Cooler	In cafeteria	High Left	WF-05122020-000550	2/11/2021	FT-FY21-022021-000550-A	<1	FT-FY21-022021-000550-B	<1
WS- 000551	5/12/2020	5/12/2021	Basement	Cooler	In cafeteria	Low Right	WF-05122020-000551	2/11/2021	FT-FY21-022021-000551-A	<1	FT-FY21-022021-000551-B	<1
WS- 000552	5/12/2020	5/12/2021	1	Cooler	In hallway adjacent to classroom 110	High Left	WF-05122020-000552	2/11/2021	FT-FY21-022021-000552-A	<1	FT-FY21-022021-000552-B	<1
WS- 000553	5/12/2020	5/12/2021	1	Cooler	In hallway adjacent to classroom 110	Low Right	WF-05122020-000553	2/11/2021	FT-FY21-022021-000553-A	<1	FT-FY21-022021-000553-B	<1
WS- 000556	5/12/2020	5/12/2021	1	Bottle Filler	In hallway adjacent to principal's office 113		WF-05122020-000556	2/11/2021	FT-FY21-022021-000556-A	<1	FT-FY21-022021-000556-B	<1
WS- 000557	5/12/2020	5/12/2021	1	Cooler	In hallway adjacent to principal's office 113	Low Left	WF-05122020-000557	2/11/2021	FT-FY21-022021-000557-A	<1	FT-FY21-022021-000557-B	<1
WS- 000558	5/12/2020	5/12/2021	1	Cooler	In hallway adjacent to principal's office 113	High Right	WF-05122020-000558	2/11/2021	FT-FY21-022021-000558-A	<1	FT-FY21-022021-000558-B	<1
WS- 000559	5/12/2020	5/12/2021	1	Bottle Filler	In hallway across from multipurpose room 122		WF-05122020-000559	2/11/2021	FT-FY21-022021-000559-A	<1	FT-FY21-022021-000559-B	<1
WS- 000560	5/12/2020	5/12/2021	1	Cooler	In hallway across from multipurpose room 122	High Left	WF-05122020-000560	2/11/2021	FT-FY21-022021-000560-A	<1	FT-FY21-022021-000560-B	<1
WS- 000561	5/12/2020	5/12/2021	1	Cooler	In hallway across from multipurpose room 122	Low Right	WF-05122020-000561	2/11/2021	FT-FY21-022021-000561-A	<1	FT-FY21-022021-000561-B	<1
WS- 000562	5/12/2020	5/12/2021	2	Cooler	In hallway adjacent to storage room 202	High Left	WF-05122020-000562	2/11/2021	FT-FY21-022021-000562-A	<1	FT-FY21-022021-000562-B	<1
WS- 000563	5/12/2020	5/12/2021	2	Cooler	In hallway adjacent to storage room 202	Low Right	WF-05122020-000563	2/11/2021	FT-FY21-022021-000563-A	<1	FT-FY21-022021-000563-B	<1
WS- 000564	5/12/2020	5/12/2021	3	Cooler	In hallway adjacent to classroom 308	High Left	WF-05122020-000564	2/11/2021	FT-FY21-022021-000564-A	<1	FT-FY21-022021-000564-B	<1
WS- 000565	5/12/2020	5/12/2021	3	Cooler	In hallway adjacent to classroom 308	Low Right	WF-05122020-000565	2/11/2021	FT-FY21-022021-000565-A	<1	FT-FY21-022021-000565-B	<1
WS- 010259	5/12/2020	5/12/2021	Ground Floor	Combo Fountain	In classroom G011		WF-05122020-010259	2/11/2021	FT-FY21-022021-010259-A	<1	FT-FY21-022021-010259-B	<1
WS- 010260	10/6/2020	10/6/2021	Ground Floor	Combo Faucet	In classroom G011		WF-10062020-010260	2/11/2021	FT-FY21-022021-010260-A	<1	FT-FY21-022021-010260-B	<1
WS- 010261	5/12/2020	5/12/2021	Ground Floor	Combo Fountain	In classroom G010		WF-05122020-010261	2/11/2021	FT-FY21-022021-010261-A	<1	FT-FY21-022021-010261-B	<1
WS- 010262	10/6/2020	10/6/2021	Ground Floor	Combo Faucet	In classroom G010		WF-10062020-010262	2/11/2021	FT-FY21-022021-010262-A	<1	FT-FY21-022021-010262-B	<1
WS- 010263	10/6/2020	10/6/2021	Ground Floor	Combo Faucet	In classroom G009		WF-10062020-010263	2/11/2021	FT-FY21-022021-010263-A	<1	FT-FY21-022021-010263-B	<1
WS- 010264	5/12/2020	5/12/2021	Ground Floor	Combo Fountain	In classroom G009		WF-05122020-010264	2/11/2021	FT-FY21-022021-010264-A	<1	FT-FY21-022021-010264-B	<1
WS- 010265	10/6/2020	10/6/2021	Ground Floor	Combo Faucet	In classroom G007		WF-10062020-010265	2/11/2021	FT-FY21-022021-010265-A	<1	FT-FY21-022021-010265-B	<1
WS- 010266	5/12/2020	5/12/2021	Ground Floor	Combo Fountain	In classroom G007		WF-05122020-010266	2/11/2021	FT-FY21-022021-010266-A	<1	FT-FY21-022021-010266-B	<1
WS- 010267	10/6/2020	10/6/2021	Ground Floor	Combo Faucet	In classroom G005		WF-10062020-010267	2/11/2021	FT-FY21-022021-010267-A	<1	FT-FY21-022021-010267-B	<1
WS- 010268	5/12/2020	5/12/2021	Ground Floor	Combo Fountain	In classroom G005		WF-05122020-010268	2/11/2021	FT-FY21-022021-010268-A	<1	FT-FY21-022021-010268-B	<1
WS- 010272	5/12/2020	5/12/2021	1	Cooler	In health suite		WF-05122020-010272	2/11/2021	FT-FY21-022021-010272-A	<1	FT-FY21-022021-010272-B	<1
WS- 010279	5/12/2020	5/12/2021	2	Break Room	In staff lounge		WF-05122020-010279	2/11/2021	FT-FY21-022021-010279-A	<1	FT-FY21-022021-010279-B	<1
WS- 010282	5/12/2020	5/12/2021	2	Cooler	In hallway adjacent to room 208		WF-05122020-010282	2/11/2021	FT-FY21-022021-010282-A	<1	FT-FY21-022021-010282-B	<1
WS- 010292	5/12/2020	5/12/2021	3	Cooler	In hallway adjacent to custodian closet		WF-05122020-010292	2/11/2021	FT-FY21-022021-010292-A	<1	FT-FY21-022021-010292-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010269	1/7/2021	1/7/2022	Ground Floor	Food Prep Sink	In kitchen	WF-01072021-010269	2/11/2021	FT-FY21-022021-010269-A	<1	FT-FY21-022021-010269-B	<1	