



# Lasalle Backus Education Campus Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000550	3/20/2023	3/20/2024	Basement	Cooler	In cafeteria	High Left	WF-03202023-000550	11/15/2023	FT-FY24-10102023-000550-A	<1	FT-FY24-10102023-000550-B	<1
WS- 000551	3/20/2023	3/20/2024	Basement	Cooler	In cafeteria	Low Right	WF-03202023-000551	11/15/2023	FT-FY24-10102023-000551-A	<1	FT-FY24-10102023-000551-B	<1
WS- 000552	3/20/2023	3/20/2024	1	Cooler	In hallway adjacent to classroom 110	High Left	WF-03202023-000552	11/15/2023	FT-FY24-10102023-000552-A	<1	FT-FY24-10102023-000552-B	<1
WS- 000554	3/20/2023	3/20/2024	1	Cooler	In hallway adjacent to storage room 104	Low Left	WF-03202023-000554	11/15/2023	FT-FY24-10102023-000554-A	<1	FT-FY24-10102023-000554-B	<1
WS- 000555	3/20/2023	3/20/2024	1	Cooler	In hallway adjacent to storage room 104	High Right	WF-03202023-000555	11/15/2023	FT-FY24-10102023-000555-A	<1	FT-FY24-10102023-000555-B	<1
WS- 000556	3/20/2023	3/20/2024	1	Bottle Filler	In hallway adjacent to principal's office 113		WF-03202023-000556	11/15/2023	FT-FY24-10102023-000556-A	<1	FT-FY24-10102023-000556-B	<1
WS- 000557	3/20/2023	3/20/2024	1	Cooler	In hallway adjacent to principal's office 113	Low Left	WF-03202023-000557	11/15/2023	FT-FY24-10102023-000557-A	<1	FT-FY24-10102023-000557-B	<1
WS- 000558	3/20/2023	3/20/2024	1	Cooler	In hallway adjacent to principal's office 113	High Right	WF-03202023-000558	11/15/2023	FT-FY24-10102023-000558-A	<1	FT-FY24-10102023-000558-B	<1
WS- 000559	3/20/2023	3/20/2024	1	Bottle Filler	In hallway across from multipurpose room 122		WF-03202023-000559	11/15/2023	FT-FY24-10102023-000559-A	<1	FT-FY24-10102023-000559-B	<1
WS- 000560	3/20/2023	3/20/2024	1	Cooler	In hallway across from multipurpose room 122	High Left	WF-03202023-000560	11/15/2023	FT-FY24-10102023-000560-A	<1	FT-FY24-10102023-000560-B	<1
WS- 000561	3/20/2023	3/20/2024	1	Cooler	In hallway across from multipurpose room 122	Low Right	WF-03202023-000561	11/15/2023	FT-FY24-10102023-000561-A	<1	FT-FY24-10102023-000561-B	<1
WS- 000562	3/20/2023	3/20/2024	2	Cooler	In hallway adjacent to storage room 202	High Left	WF-03202023-000562	11/15/2023	FT-FY24-10102023-000562-A	<1	FT-FY24-10102023-000562-B	<1
WS- 000563	3/20/2023	3/20/2024	2	Cooler	In hallway adjacent to storage room 202	Low Right	WF-03202023-000563	11/15/2023	FT-FY24-10102023-000563-A	<1	FT-FY24-10102023-000563-B	<1
WS- 000564	3/20/2023	3/20/2024	3	Cooler	In hallway adjacent to classroom 308	High Left	WF-03202023-000564	11/15/2023	FT-FY24-10102023-000564-A	<1	FT-FY24-10102023-000564-B	<1
WS- 000565	3/20/2023	3/20/2024	3	Cooler	In hallway adjacent to classroom 308	Low Right	WF-03202023-000565	11/15/2023	FT-FY24-10102023-000565-A	<1	FT-FY24-10102023-000565-B	<1
WS- 000580	3/20/2023	3/20/2024	Ground Floor	Cooler	In hallway adjacent to custodians office G008	High Left	WF-03202023-000580	11/15/2023	FT-FY24-10102023-000580-A	<1	FT-FY24-10102023-000580-B	<1
WS- 000581	3/20/2023	3/20/2024	Ground Floor	Cooler	In hallway adjacent to custodians office G008	Low Right	WF-03202023-000581	11/15/2023	FT-FY24-10102023-000581-A	<1	FT-FY24-10102023-000581-B	<1
WS- 010259	6/28/2023	6/28/2024	Ground Floor	Combo Fountain	In classroom G011		WF-06282023-010259	11/15/2023	FT-FY24-10102023-010259-A	<1	FT-FY24-10102023-010259-B	<1
WS- 010260	9/12/2023	9/12/2024	Ground Floor	Combo Faucet	In classroom G011		WF-09122023-010260	11/15/2023	FT-FY24-10102023-010260-A	<1	FT-FY24-10102023-010260-B	<1
WS- 010261	6/28/2023	6/28/2024	Ground Floor	Combo Fountain	In classroom G010		WF-06282023-010261	11/15/2023	FT-FY24-10102023-010261-A	<1	FT-FY24-10102023-010261-B	<1
WS- 010262	9/12/2023	9/12/2024	Ground Floor	Combo Faucet	In classroom G010		WF-09122023-010262	11/15/2023	FT-FY24-10102023-010262-A	2.9	FT-FY24-10102023-010262-B	<1
WS- 010263	9/12/2023	9/12/2024	Ground Floor	Combo Faucet	In classroom G009		WF-09122023-010263	11/15/2023	FT-FY24-10102023-010263-A	1.2	FT-FY24-10102023-010263-B	<1
WS- 010264	6/28/2023	6/28/2024	Ground Floor	Combo Fountain	In classroom G009		WF-06282023-010264	11/15/2023	FT-FY24-10102023-010264-A	<1	FT-FY24-10102023-010264-B	<1
WS- 010266	6/28/2023	6/28/2024	Ground Floor	Combo Fountain	In classroom G007		WF-06282023-010266	11/15/2023	FT-FY24-10102023-010266-A	<1	FT-FY24-10102023-010266-B	<1
WS- 010267	9/12/2023	9/12/2024	Ground Floor	Combo Faucet	In classroom G005		WF-09122023-010267	11/15/2023	FT-FY24-10102023-010267-A	1.3	FT-FY24-10102023-010267-B	<1
WS- 010268	6/28/2023	6/28/2024	Ground Floor	Combo Fountain	In classroom G005		WF-06282023-010268	11/15/2023	FT-FY24-10102023-010268-A	<1	FT-FY24-10102023-010268-B	<1
WS- 010272	3/20/2023	3/20/2024	1	Cooler	In health suite		WF-03202023-010272	11/15/2023	FT-FY24-10102023-010272-A	<1	FT-FY24-10102023-010272-B	<1
WS- 010279	6/28/2023	6/28/2024	2	Break Room	In staff lounge		WF-06282023-010279	11/15/2023	FT-FY24-10102023-010279-A	<1	FT-FY24-10102023-010279-B	<1
WS- 010282	6/28/2023	6/28/2024	2	Cooler	In hallway adjacent to room 208		WF-06282023-010282	11/15/2023	FT-FY24-10102023-010282-A	<1	FT-FY24-10102023-010282-B	<1
WS- 010292	6/28/2023	6/28/2024	3	Cooler	In hallway adjacent to custodian closet		WF-06282023-010292	11/15/2023	FT-FY24-10102023-010292-A	<1	FT-FY24-10102023-010292-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010269	12/20/2022	12/20/2023	Ground Floor	Food Prep Sink	In kitchen	WF-12202022-010269	11/15/2023	FT-FY24-10102023-010269-A	<1	FT-FY24-10102023-010269-B	<1