



LASALLE-BACKUS LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010267	12/29/2016	Ground Floor	Combo Faucet	In classroom G005	FT-122016-010267-A	< 1	FT-122016-010267-B	< 1
2	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010260	12/29/2016	Ground Floor	Combo Faucet	In classroom G011	FT-122016-010260-A	< 1	FT-122016-010260-B	< 1
3	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010279	12/29/2016	2	Classroom Faucet	In staff lounge	FT-122016-010279-A	< 1	FT-122016-010279-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010265	12/29/2016	Ground Floor	Combo Faucet	In classroom G007	FT-122016-010265-A	2.4	FT-122016-010265-B	< 1
2	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010262	12/29/2016	Ground Floor	Combo Faucet	In classroom G010	FT-122016-010262-A	2.7	FT-122016-010262-B	< 1
3	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010263	12/29/2016	Ground Floor	Combo Faucet	In classroom G009	FT-122016-010263-A	3.8	FT-122016-010263-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Less than 1 ppb - Device Returned to Service										
1	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010265	1/25/2017	Ground Floor	Combo Faucet	In classroom G007	FT-122016-010265-A	< 1	FT-122016-010265-B	< 1
2	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010262	1/25/2017	Ground Floor	Combo Faucet	In classroom G010	FT-122016-010262-A	< 1	FT-122016-010262-B	< 1

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010263	1/25/2017	Ground Floor	Combo Faucet	In classroom G009	FT-122016-010263-A	1.2	FT-122016-010263-B	< 1

Second Filter Re-Test (After Device Replacement)

Less than 1 ppb - Device Returned to Service										
1	LASALLE-BACKUS EDUCATIONAL CAMPUS	WS- 010263	4/7/2017	Ground Floor	Combo Faucet	In classroom G009	FT-122016-010263-A	< 1	FT-122016-010263-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb