



# Lasalle-Backus EC Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010259	5/31/2018	5/31/2019	Ground Floor	Combo Fountain	In classroom G011	WF-05312018-010259	8/26/2018	FT-FY19-082018-010259-A	< 1	FT-FY19-082018-010259-B	< 1	
WS- 010261	5/31/2018	5/31/2019	Ground Floor	Combo Fountain	In classroom G010	WF-05312018-010261	8/26/2018	FT-FY19-082018-010261-A	< 1	FT-FY19-082018-010261-B	< 1	
WS- 010264	5/31/2018	5/31/2019	Ground Floor	Combo Fountain	In classroom G009	WF-05312018-010264	8/26/2018	FT-FY19-082018-010264-A	< 1	FT-FY19-082018-010264-B	< 1	
WS- 010266	5/31/2018	5/31/2019	Ground Floor	Combo Fountain	In classroom G007	WF-05312018-010266	8/26/2018	FT-FY19-082018-010266-A	< 1	FT-FY19-082018-010266-B	< 1	
WS- 010268	5/31/2018	5/31/2019	Ground Floor	Combo Fountain	In classroom G005	WF-05312018-010268	8/26/2018	FT-FY19-082018-010268-A	< 1	FT-FY19-082018-010268-B	< 1	
WS- 010272	5/31/2018	5/31/2019	1	Cooler	In health suite	WF-05312018-010272	8/26/2018	FT-FY19-082018-010272-A	< 1	FT-FY19-082018-010272-B	< 1	
WS- 010279	5/31/2018	5/31/2019	2	Break Room	In staff lounge	WF-05312018-010279	8/26/2018	FT-FY19-082018-010279-A	< 1	FT-FY19-082018-010279-B	< 1	
WS- 010282	5/31/2018	5/31/2019	2	Cooler	In hallway adjacent to room 208	WF-05312018-010282	8/26/2018	FT-FY19-082018-010282-A	< 1	FT-FY19-082018-010282-B	< 1	
WS- 010292	5/31/2018	5/31/2019	3	Cooler	In hallway adjacent to custodian closet	WF-05312018-010292	8/26/2018	FT-FY19-082018-010292-A	< 1	FT-FY19-082018-010292-B	< 1	
WS- 010318	5/31/2018	5/31/2019	Ground Floor	Cooler	In hallway adjacent to room G008	WF-05312018-010318	8/26/2018	FT-FY19-082018-010318-A	< 1	FT-FY19-082018-010318-B	< 1	
WS- 000550	8/15/2018	8/15/2019	Basement	Cooler	In cafeteria	High Left	WF-08152018-000550	8/26/2018	FT-FY19-082018-000550-A	< 1	FT-FY19-082018-000550-B	< 1
WS- 000551	8/15/2018	8/15/2019	Basement	Cooler	In cafeteria	Low Right	WF-08152018-000551	8/26/2018	FT-FY19-082018-000551-A	< 1	FT-FY19-082018-000551-B	< 1
WS- 000554	8/15/2018	8/15/2019	1	Cooler	In hallway adjacent to storage room 104	Low Left	WF-08152018-000554	8/26/2018	FT-FY19-082018-000554-A	< 1	FT-FY19-082018-000554-B	< 1
WS- 000555	8/15/2018	8/15/2019	1	Cooler	In hallway adjacent to storage room 104	High Right	WF-08152018-000555	8/26/2018	FT-FY19-082018-000555-A	< 1	FT-FY19-082018-000555-B	< 1
WS- 000556	8/15/2018	8/15/2019	1	Bottle Filler	In hallway adjacent to principal's office 113		WF-08152018-000556	8/26/2018	FT-FY19-082018-000556-A	< 1	FT-FY19-082018-000556-B	< 1
WS- 000557	8/15/2018	8/15/2019	1	Cooler	In hallway adjacent to principal's office 113	Low Left	WF-08152018-000557	8/26/2018	FT-FY19-082018-000557-A	< 1	FT-FY19-082018-000557-B	< 1
WS- 000558	8/15/2018	8/15/2019	1	Cooler	In hallway adjacent to principal's office 113	High Right	WF-08152018-000558	8/26/2018	FT-FY19-082018-000558-A	< 1	FT-FY19-082018-000558-B	< 1
WS- 000559	8/15/2018	8/15/2019	1	Bottle Filler	In hallway across from multipurpose room 122		WF-08152018-000559	8/26/2018	FT-FY19-082018-000559-A	< 1	FT-FY19-082018-000559-B	< 1
WS- 000560	8/15/2018	8/15/2019	1	Cooler	In hallway across from multipurpose room 122	High Left	WF-08152018-000560	8/26/2018	FT-FY19-082018-000560-A	< 1	FT-FY19-082018-000560-B	< 1
WS- 000561	8/15/2018	8/15/2019	1	Cooler	In hallway across from multipurpose room 122	Low Right	WF-08152018-000561	8/26/2018	FT-FY19-082018-000561-A	< 1	FT-FY19-082018-000561-B	< 1
WS- 000562	8/15/2018	8/15/2019	2	Cooler	In hallway adjacent to storage room 202	High Left	WF-08152018-000562	8/26/2018	FT-FY19-082018-000562-A	< 1	FT-FY19-082018-000562-B	< 1
WS- 000563	8/15/2018	8/15/2019	2	Cooler	In hallway adjacent to storage room 202	Low Right	WF-08152018-000563	8/26/2018	FT-FY19-082018-000563-A	< 1	FT-FY19-082018-000563-B	< 1
WS- 000564	8/15/2018	8/15/2019	3	Cooler	In hallway adjacent to classroom 308	High Left	WF-08152018-000564	8/26/2018	FT-FY19-082018-000564-A	< 1	FT-FY19-082018-000564-B	< 1
WS- 000565	8/15/2018	8/15/2019	3	Cooler	In hallway adjacent to classroom 308	Low Right	WF-08152018-000565	8/26/2018	FT-FY19-082018-000565-A	< 1	FT-FY19-082018-000565-B	< 1
WS- 010260	11/15/2017	11/15/2018	Ground Floor	Combo Faucet	In classroom G011	WF-112017-010260	8/26/2018	FT-FY19-082018-010260-A	< 1	FT-FY19-082018-010260-B	< 1	
WS- 010262	11/15/2017	11/15/2018	Ground Floor	Combo Faucet	In classroom G010	WF-112017-010262	8/26/2018	FT-FY19-082018-010262-A	< 1	FT-FY19-082018-010262-B	1.6	
WS- 010263	11/15/2017	11/15/2018	Ground Floor	Combo Faucet	In classroom G009	WF-112017-010263	8/26/2018	FT-FY19-082018-010263-A	< 1	FT-FY19-082018-010263-B	< 1	
WS- 010265	11/15/2017	11/15/2018	Ground Floor	Combo Faucet	In classroom G007	WF-112017-010265	8/26/2018	FT-FY19-082018-010265-A	< 1	FT-FY19-082018-010265-B	< 1	
WS- 010267	11/15/2017	11/15/2018	Ground Floor	Combo Faucet	In classroom G005	WF-112017-010267	8/26/2018	FT-FY19-082018-010267-A	< 1	FT-FY19-082018-010267-B	< 1	

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010269	Ground Floor	Food Prep Sink	In kitchen	8/26/2018	FT-FY19-082018-010269-A	< 1	FT-FY19-082018-010269-B	< 1