



# Leckie EC Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000285	5/22/2019	5/22/2020	3	Cooler	In hallway adjacent to room 310	WF-05222019-000285	12/13/2019	FT-FY20-112019-000285-A	<1	FT-FY20-112019-000285-B	<1
WS-000289	5/22/2019	5/22/2020	3	Cooler	In hallway adjacent to custodial closet 303	WF-05222019-000289	12/13/2019	FT-FY20-112019-000289-A	<1	FT-FY20-112019-000289-B	<1
WS-000294	5/22/2019	5/22/2020	2	Cooler	In hallway adjacent to room 213	WF-05222019-000294	12/13/2019	FT-FY20-112019-000294-A	<1	FT-FY20-112019-000294-B	<1
WS-000296	5/22/2019	5/22/2020	2	Break Room	In staff lounge 207	WF-05222019-000296	12/13/2019	FT-FY20-112019-000296-A	<1	FT-FY20-112019-000296-B	<1
WS-000298	5/22/2019	5/22/2020	2	Cooler	In hallway adjacent to custodial closet	WF-05222019-000298	12/13/2019	FT-FY20-112019-000298-A	<1	FT-FY20-112019-000298-B	<1
WS-000299	5/22/2019	5/22/2020	1	Combo Fountain	In classroom 122	WF-05222019-000299	12/13/2019	FT-FY20-112019-000299-A	<1	FT-FY20-112019-000299-B	<1
WS-000303	10/7/2019	10/7/2020	1	Combo Faucet	In classroom 122	WF-10072019-000303	12/13/2019	FT-FY20-112019-000303-A	<1	FT-FY20-112019-000303-B	<1
WS-000307	5/22/2019	5/22/2020	1	Cooler	In hallway adjacent to room 115 High Left	WF-05222019-000307	12/13/2019	FT-FY20-112019-000307-A	<1	FT-FY20-112019-000307-B	<1
WS-000308	5/22/2019	5/22/2020	1	Cooler	In hallway adjacent to room 115 Low Right	WF-05222019-000308	12/13/2019	FT-FY20-112019-000308-A	<1	FT-FY20-112019-000308-B	<1
WS-000309	5/22/2019	5/22/2020	1	Combo Fountain	In classroom 115	WF-05222019-000309	12/13/2019	FT-FY20-112019-000309-A	<1	FT-FY20-112019-000309-B	<1
WS-000310	10/7/2019	10/7/2020	1	Combo Faucet	In classroom 115	WF-10072019-000310	12/13/2019	FT-FY20-112019-000310-A	<1	FT-FY20-112019-000310-B	<1
WS-000313	5/22/2019	5/22/2020	1	Combo Fountain	In classroom 120	WF-05222019-000313	12/13/2019	FT-FY20-112019-000313-A	<1	FT-FY20-112019-000313-B	<1
WS-000315	10/7/2019	10/7/2020	1	Combo Faucet	In classroom 120	WF-10072019-000315	12/13/2019	FT-FY20-112019-000315-A	<1	FT-FY20-112019-000315-B	<1
WS-000316	5/22/2019	5/22/2020	1	Combo Fountain	In classroom 113	WF-05222019-000316	12/13/2019	FT-FY20-112019-000316-A	<1	FT-FY20-112019-000316-B	<1
WS-000318	10/7/2019	10/7/2020	1	Combo Faucet	In classroom 113	WF-10072019-000318	12/13/2019	FT-FY20-112019-000318-A	<1	FT-FY20-112019-000318-B	<1
WS-000323	5/22/2019	5/22/2020	1	Combo Fountain	In classroom 111 Right	WF-05222019-000323	12/13/2019	FT-FY20-112019-000323-A	<1	FT-FY20-112019-000323-B	<1
WS-000325	10/7/2019	10/7/2020	1	Combo Faucet	In classroom 111 Left	WF-10072019-000325	12/13/2019	FT-FY20-112019-000325-A	<1	FT-FY20-112019-000325-B	<1
WS-000329	5/22/2019	5/22/2020	Basement	Cooler	In hallway adjacent to staff restroom High Left	WF-05222019-000329	12/13/2019	FT-FY20-112019-000329-A	<1	FT-FY20-112019-000329-B	<1
WS-000330	5/22/2019	5/22/2020	1	Cooler	In hallway adjacent to staff restroom High Left	WF-05222019-000330	12/13/2019	FT-FY20-112019-000330-A	<1	FT-FY20-112019-000330-B	<1
WS-000331	5/22/2019	5/22/2020	Basement	Cooler	In hallway adjacent to staff restroom Low Right	WF-05222019-000331	12/13/2019	FT-FY20-112019-000331-A	<1	FT-FY20-112019-000331-B	<1
WS-000333	5/22/2019	5/22/2020	1	Cooler	In hallway adjacent to staff restroom Low Right	WF-05222019-000333	12/13/2019	FT-FY20-112019-000333-A	<1	FT-FY20-112019-000333-B	<1
WS-000336	10/7/2019	10/7/2020	Basement	Combo Faucet	In classroom 012 Left	WF-10072019-000336	12/13/2019	FT-FY20-112019-000336-A	<1	FT-FY20-112019-000336-B	<1
WS-000337	5/22/2019	5/22/2020	Basement	Combo Fountain	In classroom 012 Right	WF-05222019-000337	12/13/2019	FT-FY20-112019-000337-A	<1	FT-FY20-112019-000337-B	<1
WS-000340	10/7/2019	10/7/2020	Basement	Combo Faucet	In classroom 014 Left	WF-10072019-000340	12/13/2019	FT-FY20-112019-000340-A	<1	FT-FY20-112019-000340-B	<1
WS-000343	5/22/2019	5/22/2020	Basement	Combo Fountain	In classroom 014 Right	WF-05222019-000343	12/13/2019	FT-FY20-112019-000343-A	<1	FT-FY20-112019-000343-B	<1
WS-000345	10/7/2019	10/7/2020	Basement	Combo Faucet	In classroom 016 Left	WF-10072019-000345	12/13/2019	FT-FY20-112019-000345-A	<1	FT-FY20-112019-000345-B	<1
WS-000348	5/22/2019	5/22/2020	Basement	Combo Fountain	In classroom 016 Right	WF-05222019-000348	12/13/2019	FT-FY20-112019-000348-A	<1	FT-FY20-112019-000348-B	<1
WS-000351	10/7/2019	10/7/2020	Basement	Combo Faucet	In classroom 018 Left	WF-10072019-000351	12/13/2019	FT-FY20-112019-000351-A	<1	FT-FY20-112019-000351-B	<1
WS-000354	5/22/2019	5/22/2020	Basement	Combo Fountain	In classroom 018 Right	WF-05222019-000354	12/13/2019	FT-FY20-112019-000354-A	<1	FT-FY20-112019-000354-B	<1
WS-000356	5/22/2019	5/22/2020	1	Cooler	In multi-purpose room	WF-05222019-000356	12/13/2019	FT-FY20-112019-000356-A	<1	FT-FY20-112019-000356-B	<1
WS-000361	5/22/2019	5/22/2020	1	Health Suite	In health suite 114	WF-05222019-000361	12/13/2019	FT-FY20-112019-000361-A	<1	FT-FY20-112019-000361-B	<1

WS- 000363	5/22/2019	5/22/2020	1	Cooler	Annex, adjacent to boys' restroom	High	Left	WF-05222019-000363	12/13/2019	FT-FY20-112019-000363-A	<1	FT-FY20-112019-000363-B	<1
WS- 000365	5/22/2019	5/22/2020	1	Cooler	Annex, adjacent to boys' restroom	Low	Right	WF-05222019-000365	12/13/2019	FT-FY20-112019-000365-A	<1	FT-FY20-112019-000365-B	<1
WS- 000461	5/22/2019	5/22/2020	1	Cooler	Double annex, in hallway adjacent to M104	High	Left	WF-05222019-000461	12/13/2019	FT-FY20-112019-000461-A	<1	FT-FY20-112019-000461-B	<1
WS- 000462	5/22/2019	5/22/2020	1	Cooler	Double annex, in hallway adjacent to M104	Low	Right	WF-05222019-000462	12/13/2019	FT-FY20-112019-000462-A	<1	FT-FY20-112019-000462-B	<1
WS- 000463	5/22/2019	5/22/2020	2	Cooler	Double annex, in hallway adjacent to M202	High	Left	WF-05222019-000463	12/13/2019	FT-FY20-112019-000463-A	<1	FT-FY20-112019-000463-B	<1
WS- 000464	5/22/2019	5/22/2020	2	Cooler	Double annex, in hallway adjacent to M202	Low	Right	WF-05222019-000464	12/13/2019	FT-FY20-112019-000464-A	<1	FT-FY20-112019-000464-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000347	7/10/2019	7/10/2020	1	Food Prep Sink	In kitchen second clockwise from entry door	High	WF-07102019-000347	12/13/2019	FT-FY20-112019-000347-A	<1	FT-FY20-112019-000347-B	<1
WS- 000350	7/10/2019	7/10/2020	1	Food Prep Sink	In kitchen third clockwise from entry door		WF-07102019-000350	12/13/2019	FT-FY20-112019-000350-A	<1	FT-FY20-112019-000350-B	<1