



# Leckie Elementary School Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000285	4/13/2021	4/13/2022	3	Cooler	In hallway adjacent to room 310	WF-04132021-000285	2/16/2022	FT-FY22-01182022-000285-A	<1	FT-FY22-01182022-000285-B	<1	
WS- 000289	4/13/2021	4/13/2022	3	Cooler	In hallway adjacent to custodial closet 303	WF-04132021-000289	2/16/2022	FT-FY22-01182022-000289-A	<1	FT-FY22-01182022-000289-B	<1	
WS- 000294	4/13/2021	4/13/2022	2	Cooler	In hallway adjacent to room 213	WF-04132021-000294	2/16/2022	FT-FY22-01182022-000294-A	<1	FT-FY22-01182022-000294-B	<1	
WS- 000296	4/13/2021	4/13/2022	2	Break Room	In staff lounge 207	WF-04132021-000296	2/16/2022	FT-FY22-01182022-000296-A	<1	FT-FY22-01182022-000296-B	<1	
WS- 000298	4/13/2021	4/13/2022	2	Cooler	In hallway adjacent to custodial closet	WF-04132021-000298	2/16/2022	FT-FY22-01182022-000298-A	<1	FT-FY22-01182022-000298-B	<1	
WS- 000299	4/13/2021	4/13/2022	1	Combo Fountain	In classroom 122	WF-04132021-000299	2/16/2022	FT-FY22-01182022-000299-A	<1	FT-FY22-01182022-000299-B	<1	
WS- 000303	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 122	WF-09202021-000303	2/16/2022	FT-FY22-01182022-000303-A	<1	FT-FY22-01182022-000303-B	<1	
WS- 000307	4/13/2021	4/13/2022	1	Cooler	In hallway adjacent to room 115	High Left	WF-04132021-000307	2/16/2022	FT-FY22-01182022-000307-A	<1	FT-FY22-01182022-000307-B	<1
WS- 000308	4/13/2021	4/13/2022	1	Cooler	In hallway adjacent to room 115	Low Right	WF-04132021-000308	2/16/2022	FT-FY22-01182022-000308-A	<1	FT-FY22-01182022-000308-B	<1
WS- 000309	4/13/2021	4/13/2022	1	Combo Fountain	In classroom 115	WF-04132021-000309	2/16/2022	FT-FY22-01182022-000309-A	<1	FT-FY22-01182022-000309-B	<1	
WS- 000310	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 115	WF-09202021-000310	2/16/2022	FT-FY22-01182022-000310-A	<1	FT-FY22-01182022-000310-B	<1	
WS- 000313	4/13/2021	4/13/2022	1	Combo Fountain	In classroom 120	WF-04132021-000313	2/16/2022	FT-FY22-01182022-000313-A	<1	FT-FY22-01182022-000313-B	<1	
WS- 000315	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 120	WF-09202021-000315	2/16/2022	FT-FY22-01182022-000315-A	<1	FT-FY22-01182022-000315-B	<1	
WS- 000316	4/13/2021	4/13/2022	1	Combo Fountain	In classroom 113	WF-04132021-000316	2/16/2022	FT-FY22-01182022-000316-A	<1	FT-FY22-01182022-000316-B	<1	
WS- 000318	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 113	WF-09202021-000318	2/16/2022	FT-FY22-01182022-000318-A	<1	FT-FY22-01182022-000318-B	<1	
WS- 000323	4/13/2021	4/13/2022	1	Combo Fountain	In classroom 111	Right	WF-04132021-000323	2/16/2022	FT-FY22-01182022-000323-A	<1	FT-FY22-01182022-000323-B	<1
WS- 000325	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 111	Left	WF-09202021-000325	2/16/2022	FT-FY22-01182022-000325-A	<1	FT-FY22-01182022-000325-B	<1
WS- 000329	4/13/2021	4/13/2022	Basement	Cooler	In hallway adjacent to staff restroom	High Left	WF-04132021-000329	2/16/2022	FT-FY22-01182022-000329-A	<1	FT-FY22-01182022-000329-B	<1
WS- 000330	4/13/2021	4/13/2022	1	Cooler	In hallway adjacent to staff restroom	High Left	WF-04132021-000330	2/16/2022	FT-FY22-01182022-000330-A	<1	FT-FY22-01182022-000330-B	<1
WS- 000331	4/13/2021	4/13/2022	Basement	Cooler	In hallway adjacent to staff restroom	Low Right	WF-04132021-000331	2/16/2022	FT-FY22-01182022-000331-A	<1	FT-FY22-01182022-000331-B	<1
WS- 000333	4/13/2021	4/13/2022	1	Cooler	In hallway adjacent to staff restroom	Low Right	WF-04132021-000333	2/16/2022	FT-FY22-01182022-000333-A	<1	FT-FY22-01182022-000333-B	<1
WS- 000336	9/20/2021	9/20/2022	Basement	Combo Faucet	In classroom 012	Left	WF-09202021-000336	2/16/2022	FT-FY22-01182022-000336-A	<1	FT-FY22-01182022-000336-B	<1
WS- 000337	4/13/2021	4/13/2022	Basement	Combo Fountain	In classroom 012	Right	WF-04132021-000337	2/16/2022	FT-FY22-01182022-000337-A	<1	FT-FY22-01182022-000337-B	<1
WS- 000340	9/20/2021	9/20/2022	Basement	Combo Faucet	In classroom 014	Left	WF-09202021-000340	2/16/2022	FT-FY22-01182022-000340-A	<1	FT-FY22-01182022-000340-B	<1
WS- 000343	4/13/2021	4/13/2022	Basement	Combo Fountain	In classroom 014	Right	WF-04132021-000343	2/16/2022	FT-FY22-01182022-000343-A	<1	FT-FY22-01182022-000343-B	<1
WS- 000345	9/20/2021	9/20/2022	Basement	Combo Faucet	In classroom 016	Left	WF-09202021-000345	2/16/2022	FT-FY22-01182022-000345-A	<1	FT-FY22-01182022-000345-B	<1
WS- 000348	4/13/2021	4/13/2022	Basement	Combo Fountain	In classroom 016	Right	WF-04132021-000348	2/16/2022	FT-FY22-01182022-000348-A	<1	FT-FY22-01182022-000348-B	<1
WS- 000351	9/20/2021	9/20/2022	Basement	Combo Faucet	In classroom 018	Left	WF-09202021-000351	2/16/2022	FT-FY22-01182022-000351-A	<1	FT-FY22-01182022-000351-B	<1
WS- 000354	4/13/2021	4/13/2022	Basement	Combo Fountain	In classroom 018	Right	WF-04132021-000354	2/16/2022	FT-FY22-01182022-000354-A	<1	FT-FY22-01182022-000354-B	<1
WS- 000356	4/13/2021	4/13/2022	1	Cooler	In multi-purpose room	WF-04132021-000356	2/16/2022	FT-FY22-01182022-000356-A	<1	FT-FY22-01182022-000356-B	<1	
WS- 000361	4/13/2021	4/13/2022	1	Health Suite	In health suite 114	WF-04132021-000361	2/16/2022	FT-FY22-01182022-000361-A	<1	FT-FY22-01182022-000361-B	<1	
WS- 000363	4/13/2021	4/13/2022	1	Cooler	Annex, adjacent to boys' restroom	High Left	WF-04132021-000363	2/16/2022	FT-FY22-01182022-000363-A	<1	FT-FY22-01182022-000363-B	<1
WS- 000365	4/13/2021	4/13/2022	1	Cooler	Annex, adjacent to boys' restroom	Low Right	WF-04132021-000365	2/16/2022	FT-FY22-01182022-000365-A	<1	FT-FY22-01182022-000365-B	<1
WS- 000463	4/13/2021	4/13/2022	2	Cooler	Double annex, in hallway adjacent to M202	High Left	WF-04132021-000463	2/16/2022	FT-FY22-01182022-000463-A	<1	FT-FY22-01182022-000463-B	<1

WS- 000464	4/13/2021	4/13/2022	2	Cooler	Double annex, in hallway adjacent to M202	Low	Right	WF-04132021-000464	2/16/2022	FT-FY22-01182022-000464-A	<1	FT-FY22-01182022-000464-B	<1
------------	-----------	-----------	---	--------	---	-----	-------	--------------------	-----------	---------------------------	----	---------------------------	----

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000347	2/7/2022	2/7/2023	1	Food Prep Sink	In kitchen second clockwise from entry door	High	WF-02072022-000347	2/16/2022	FT-FY22-01182022-000347-A	<1	FT-FY22-01182022-000347-B	<1
WS- 000350	2/7/2022	2/7/2023	1	Food Prep Sink	In kitchen third clockwise from entry door		WF-02072022-000350	2/16/2022	FT-FY22-01182022-000350-A	<1	FT-FY22-01182022-000350-B	<1