



# Leckie Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000285	5/13/2020	5/13/2021	3	Cooler	In hallway adjacent to room 310	WF-05132020-000285	1/7/2021	FT-FY21-012021-000285-A	<1	FT-FY21-012021-000285-B	<1	
WS-000289	5/13/2020	5/13/2021	3	Cooler	In hallway adjacent to custodial closet 303	WF-05132020-000289	1/7/2021	FT-FY21-012021-000289-A	<1	FT-FY21-012021-000289-B	<1	
WS-000294	5/13/2020	5/13/2021	2	Cooler	In hallway adjacent to room 213	WF-05132020-000294	1/7/2021	FT-FY21-012021-000294-A	<1	FT-FY21-012021-000294-B	<1	
WS-000296	5/13/2020	5/13/2021	2	Break Room	In staff lounge 207	WF-05132020-000296	1/7/2021	FT-FY21-012021-000296-A	<1	FT-FY21-012021-000296-B	<1	
WS-000299	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 122	WF-05132020-000299	1/7/2021	FT-FY21-012021-000299-A	<1	FT-FY21-012021-000299-B	<1	
WS-000303	9/30/2020	9/30/2021	1	Combo Faucet	In classroom 122	WF-09302020-000303	1/7/2021	FT-FY21-012021-000303-A	<1	FT-FY21-012021-000303-B	<1	
WS-000307	5/13/2020	5/13/2021	1	Cooler	In hallway adjacent to room 115	High Left	WF-05132020-000307	1/7/2021	FT-FY21-012021-000307-A	<1	FT-FY21-012021-000307-B	<1
WS-000308	5/13/2020	5/13/2021	1	Cooler	In hallway adjacent to room 115	Low Right	WF-05132020-000308	1/7/2021	FT-FY21-012021-000308-A	<1	FT-FY21-012021-000308-B	<1
WS-000309	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 115	WF-05132020-000309	1/7/2021	FT-FY21-012021-000309-A	<1	FT-FY21-012021-000309-B	<1	
WS-000310	9/30/2020	9/30/2021	1	Combo Faucet	In classroom 115	WF-09302020-000310	1/7/2021	FT-FY21-012021-000310-A	<1	FT-FY21-012021-000310-B	<1	
WS-000313	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 120	WF-05132020-000313	1/7/2021	FT-FY21-012021-000313-A	<1	FT-FY21-012021-000313-B	<1	
WS-000315	9/30/2020	9/30/2021	1	Combo Faucet	In classroom 120	WF-09302020-000315	1/7/2021	FT-FY21-012021-000315-A	<1	FT-FY21-012021-000315-B	<1	
WS-000316	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 113	WF-05132020-000316	1/7/2021	FT-FY21-012021-000316-A	<1	FT-FY21-012021-000316-B	<1	
WS-000318	9/30/2020	9/30/2021	1	Combo Faucet	In classroom 113	WF-09302020-000318	1/7/2021	FT-FY21-012021-000318-A	<1	FT-FY21-012021-000318-B	<1	
WS-000323	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 111	Right	WF-05132020-000323	1/7/2021	FT-FY21-012021-000323-A	<1	FT-FY21-012021-000323-B	<1
WS-000325	9/30/2020	9/30/2021	1	Combo Faucet	In classroom 111	Left	WF-09302020-000325	1/7/2021	FT-FY21-012021-000325-A	<1	FT-FY21-012021-000325-B	<1
WS-000329	5/13/2020	5/13/2021	Basement	Cooler	In hallway adjacent to staff restroom	High Left	WF-05132020-000329	1/7/2021	FT-FY21-012021-000329-A	<1	FT-FY21-012021-000329-B	<1
WS-000330	5/13/2020	5/13/2021	1	Cooler	In hallway adjacent to staff restroom	High Left	WF-05132020-000330	1/7/2021	FT-FY21-012021-000330-A	<1	FT-FY21-012021-000330-B	<1
WS-000331	5/13/2020	5/13/2021	Basement	Cooler	In hallway adjacent to staff restroom	Low Right	WF-05132020-000331	1/7/2021	FT-FY21-012021-000331-A	<1	FT-FY21-012021-000331-B	<1
WS-000333	5/13/2020	5/13/2021	1	Cooler	In hallway adjacent to staff restroom	Low Right	WF-05132020-000333	1/7/2021	FT-FY21-012021-000333-A	<1	FT-FY21-012021-000333-B	<1
WS-000336	9/30/2020	9/30/2021	Basement	Combo Faucet	In classroom 012	Left	WF-09302020-000336	1/7/2021	FT-FY21-012021-000336-A	<1	FT-FY21-012021-000336-B	<1
WS-000337	5/13/2020	5/13/2021	Basement	Combo Fountain	In classroom 012	Right	WF-05132020-000337	1/7/2021	FT-FY21-012021-000337-A	<1	FT-FY21-012021-000337-B	<1
WS-000340	9/30/2020	9/30/2021	Basement	Combo Faucet	In classroom 014	Left	WF-09302020-000340	1/7/2021	FT-FY21-012021-000340-A	<1	FT-FY21-012021-000340-B	<1
WS-000343	5/13/2020	5/13/2021	Basement	Combo Fountain	In classroom 014	Right	WF-05132020-000343	1/7/2021	FT-FY21-012021-000343-A	<1	FT-FY21-012021-000343-B	<1
WS-000345	9/30/2020	9/30/2021	Basement	Combo Faucet	In classroom 016	Left	WF-09302020-000345	1/7/2021	FT-FY21-012021-000345-A	<1	FT-FY21-012021-000345-B	<1
WS-000348	5/13/2020	5/13/2021	Basement	Combo Fountain	In classroom 016	Right	WF-05132020-000348	1/7/2021	FT-FY21-012021-000348-A	<1	FT-FY21-012021-000348-B	<1
WS-000351	9/30/2020	9/30/2021	Basement	Combo Faucet	In classroom 018	Left	WF-09302020-000351	1/7/2021	FT-FY21-012021-000351-A	<1	FT-FY21-012021-000351-B	<1
WS-000354	5/13/2020	5/13/2021	Basement	Combo Fountain	In classroom 018	Right	WF-05132020-000354	1/7/2021	FT-FY21-012021-000354-A	<1	FT-FY21-012021-000354-B	<1
WS-000356	5/13/2020	5/13/2021	1	Cooler	In multi-purpose room	WF-05132020-000356	1/7/2021	FT-FY21-012021-000356-A	<1	FT-FY21-012021-000356-B	<1	
WS-000361	5/13/2020	5/13/2021	1	Health Suite	In health suite 114	WF-05132020-000361	1/7/2021	FT-FY21-012021-000361-A	<1	FT-FY21-012021-000361-B	<1	
WS-000363	5/13/2020	5/13/2021	1	Cooler	Annex, adjacent to boys' restroom	High Left	WF-05132020-000363	1/7/2021	FT-FY21-012021-000363-A	<1	FT-FY21-012021-000363-B	<1
WS-000365	5/13/2020	5/13/2021	1	Cooler	Annex, adjacent to boys' restroom	Low Right	WF-05132020-000365	1/7/2021	FT-FY21-012021-000365-A	<1	FT-FY21-012021-000365-B	<1

WS- 000463	5/13/2020	5/13/2021	2	Cooler	Double annex, in hallway adjacent to M202	High	Left	WF-05132020-000463	1/7/2021	FT-FY21-012021-000463-A	<1	FT-FY21-012021-000463-B	<1
WS- 000464	5/13/2020	5/13/2021	2	Cooler	Double annex, in hallway adjacent to M202	Low	Right	WF-05132020-000464	1/7/2021	FT-FY21-012021-000464-A	<1	FT-FY21-012021-000464-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000347	2/27/2020	2/27/2021	1	Food Prep Sink	In kitchen second clockwise from entry door	High		WF-02272020-000347	1/7/2021	FT-FY21-012021-000347-A	3.3	FT-FY21-012021-000347-B	<1

### Food Prep Sink

Greater than 5ppb - Devices requiring remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000350	2/27/2020	2/27/2021	1	Food Prep Sink	In kitchen third clockwise from entry door			WF-02272020-000350	1/7/2021	FT-FY21-012021-000350-A	7.8	FT-FY21-012021-000350-B	<1