Leckie ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000285	3/21/2025	3/21/2026	3	Cooler	In hallway adjacent to room 310	WF-03212025-000285	11/24/2025	FT-FY26-10172025-000285-A	<2	FT-FY26-10172025-000285-B	<2
WS- 000296	3/10/2025	3/10/2026	2	Break Room	In staff lounge 207	WF-03102025-000296	11/24/2025	FT-FY26-10172025-000296-A	<2	FT-FY26-10172025-000296-B	<2
WS- 000298	3/10/2025	3/10/2026	2	Cooler	In hallway adjacent to custodial closet	WF-03102025-000298	11/24/2025	FT-FY26-10172025-000298-A	<2	FT-FY26-10172025-000298-B	<2
WS- 000299	3/10/2025	3/10/2026	1	Combo Fountain	In classroom 122	WF-03102025-000299	11/24/2025	FT-FY26-10172025-000299-A	<2	FT-FY26-10172025-000299-B	<2
WS- 000303	8/26/2025	8/26/2026	1	Combo Faucet	In classroom 122	WF-08262025-000303	11/24/2025	FT-FY26-10172025-000303-A	<2	FT-FY26-10172025-000303-B	<2
WS- 000307	3/10/2025	3/10/2026	1	Cooler	In hallway adjacent to room 115 High Left	WF-03102025-000307	11/24/2025	FT-FY26-10172025-000307-A	<2	FT-FY26-10172025-000307-B	<2
WS- 000308	3/10/2025	3/10/2026	1	Cooler	In hallway adjacent to room 115 Low Right	WF-03102025-000308	11/24/2025	FT-FY26-10172025-000308-A	<2	FT-FY26-10172025-000308-B	<2
WS- 000309	3/10/2025	3/10/2026	1	Combo Fountain	In classroom 115	WF-03102025-000309	11/24/2025	FT-FY26-10172025-000309-A	<2	FT-FY26-10172025-000309-B	<2
WS- 000310	8/26/2025	8/26/2026	1	Combo Faucet	In classroom 115	WF-08262025-000310	11/24/2025	FT-FY26-10172025-000310-A	<2	FT-FY26-10172025-000310-B	<2
WS- 000313	3/10/2025	3/10/2026	1	Combo Glass Filler	In classroom 120	WF-03102025-000313	11/24/2025	FT-FY26-10172025-000313-A	<2	FT-FY26-10172025-000313-B	<2
WS- 000315	8/26/2025	8/26/2026	1	Combo Faucet	In classroom 120	WF-08262025-000315	11/24/2025	FT-FY26-10172025-000315-A	<2	FT-FY26-10172025-000315-B	<2
WS- 000316	3/10/2025	3/10/2026	1	Combo Fountain	In classroom 113	WF-03102025-000316	11/24/2025	FT-FY26-10172025-000316-A	<2	FT-FY26-10172025-000316-B	<2
WS- 000318	8/26/2025	8/26/2026	1	Combo Faucet	In classroom 113	WF-08262025-000318	11/24/2025	FT-FY26-10172025-000318-A	<2	FT-FY26-10172025-000318-B	<2
WS- 000323	3/10/2025	3/10/2026	1	Combo Fountain	In classroom 111 Right	WF-03102025-000323	11/24/2025	FT-FY26-10172025-000323-A	<2	FT-FY26-10172025-000323-B	<2
WS- 000325	8/26/2025	8/26/2026	1	Combo Faucet	In classroom 111 Left	WF-08262025-000325	11/24/2025	FT-FY26-10172025-000325-A	<2	FT-FY26-10172025-000325-B	<2
WS- 000329	3/10/2025	3/10/2026	Basement	Cooler	In hallway adjacent to staff restroom High Left	WF-03102025-000329	11/24/2025	FT-FY26-10172025-000329-A	<2	FT-FY26-10172025-000329-B	<2
WS- 000330	3/10/2025	3/10/2026	1	Cooler	In hallway adjacent to staff restroom High Left	WF-03102025-000330	11/24/2025	FT-FY26-10172025-000330-A	<2	FT-FY26-10172025-000330-B	<2
WS- 000331	3/10/2025	3/10/2026	Basement	Cooler	In hallway adjacent to staff restroom Low Right	WF-03102025-000331	11/24/2025	FT-FY26-10172025-000331-A	<2	FT-FY26-10172025-000331-B	<2
WS- 000333	3/10/2025	3/10/2026	1	Cooler	In hallway adjacent to staff restroom Low Right	WF-03102025-000333	11/24/2025	FT-FY26-10172025-000333-A	<2	FT-FY26-10172025-000333-B	<2
WS- 000336	8/26/2025	8/26/2026	Basement	Combo Faucet	In classroom 012 Left	WF-08262025-000336	11/24/2025	FT-FY26-10172025-000336-A	<2	FT-FY26-10172025-000336-B	<2
WS- 000337	3/10/2025	3/10/2026	Basement	Combo Fountain	In classroom 012 Right	WF-03102025-000337	11/24/2025	FT-FY26-10172025-000337-A	<2	FT-FY26-10172025-000337-B	<2
WS- 000345	8/26/2025	8/26/2026	Basement	Combo Faucet	In classroom 016 Left	WF-08262025-000345	11/24/2025	FT-FY26-10172025-000345-A	<2	FT-FY26-10172025-000345-B	<2
WS- 000348	3/10/2025	3/10/2026	Basement	Combo Glass Filler	In classroom 016 Right	WF-03102025-000348	11/24/2025	FT-FY26-10172025-000348-A	<2	FT-FY26-10172025-000348-B	<2
WS- 000351	8/26/2025	8/26/2026	Basement	Combo Faucet	In classroom 018 Left	WF-08262025-000351	11/24/2025	FT-FY26-10172025-000351-A	<2	FT-FY26-10172025-000351-B	<2
WS- 000354	3/10/2025	3/10/2026	Basement	Combo Glass Filler	In classroom 018 Right	WF-03102025-000354	11/24/2025	FT-FY26-10172025-000354-A	<2	FT-FY26-10172025-000354-B	<2
WS- 000356	3/10/2025	3/10/2026	1	Cooler	In multi-purpose room	WF-03102025-000356	11/24/2025	FT-FY26-10172025-000356-A	<2	FT-FY26-10172025-000356-B	<2
WS- 000361	3/10/2025	3/10/2026	1	Health Suite	In health suite 114	WF-03102025-000361	11/24/2025	FT-FY26-10172025-000361-A	<2	FT-FY26-10172025-000361-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000347	12/9/2024	12/9/2025	1	Food Prep Sink	In kitchen second clockwise from entry door High	WF-12092024-000347	11/24/2025	FT-FY26-10172025-000347-A	<2	FT-FY26-10172025-000347-B	<2
WS- 000350	12/9/2024	12/9/2025	1	Food Prep Sink	In kitchen third clockwise from entry door	WF-12092024-000350	11/24/2025	FT-FY26-10172025-000350-A	<2	FT-FY26-10172025-000350-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.