



Leckie Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000285	3/28/2023	3/28/2024	3	Cooler	In hallway adjacent to room 310	WF-03282023-000285	11/27/2023	FT-FY24-10102023-000285-A	<1	FT-FY24-10102023-000285-B	<1	
WS-000296	3/28/2023	3/28/2024	2	Break Room	In staff lounge 207	WF-03282023-000296	11/27/2023	FT-FY24-10102023-000296-A	2.4	FT-FY24-10102023-000296-B	<1	
WS-000299	3/28/2023	3/28/2024	1	Combo Fountain	In classroom 122	WF-03282023-000299	11/27/2023	FT-FY24-10102023-000299-A	<1	FT-FY24-10102023-000299-B	<1	
WS-000303	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 122	WF-09052023-000303	11/27/2023	FT-FY24-10102023-000303-A	3.5	FT-FY24-10102023-000303-B	<1	
WS-000308	3/28/2023	3/28/2024	1	Cooler	In hallway adjacent to room 115	Low Right	WF-03282023-000308	11/27/2023	FT-FY24-10102023-000308-A	<1	FT-FY24-10102023-000308-B	<1
WS-000309	3/28/2023	3/28/2024	1	Combo Fountain	In classroom 115	WF-03282023-000309	11/27/2023	FT-FY24-10102023-000309-A	<1	FT-FY24-10102023-000309-B	<1	
WS-000310	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 115	WF-09052023-000310	11/27/2023	FT-FY24-10102023-000310-A	1.2	FT-FY24-10102023-000310-B	<1	
WS-000313	3/28/2023	3/28/2024	1	Combo Fountain	In classroom 120	WF-03282023-000313	11/27/2023	FT-FY24-10102023-000313-A	<1	FT-FY24-10102023-000313-B	<1	
WS-000315	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 120	WF-09052023-000315	11/27/2023	FT-FY24-10102023-000315-A	<1	FT-FY24-10102023-000315-B	<1	
WS-000316	3/28/2023	3/28/2024	1	Combo Fountain	In classroom 113	WF-03282023-000316	11/27/2023	FT-FY24-10102023-000316-A	<1	FT-FY24-10102023-000316-B	<1	
WS-000318	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 113	WF-09052023-000318	11/27/2023	FT-FY24-10102023-000318-A	<1	FT-FY24-10102023-000318-B	<1	
WS-000323	3/28/2023	3/28/2024	1	Combo Fountain	In classroom 111	Right	WF-03282023-000323	11/27/2023	FT-FY24-10102023-000323-A	<1	FT-FY24-10102023-000323-B	<1
WS-000325	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 111	Left	WF-09052023-000325	11/27/2023	FT-FY24-10102023-000325-A	<1	FT-FY24-10102023-000325-B	<1
WS-000329	3/28/2023	3/28/2024	Basement	Cooler	In hallway adjacent to staff restroom	High Left	WF-03282023-000329	11/27/2023	FT-FY24-10102023-000329-A	<1	FT-FY24-10102023-000329-B	<1
WS-000330	3/28/2023	3/28/2024	1	Cooler	In hallway adjacent to staff restroom	High Left	WF-03282023-000330	11/27/2023	FT-FY24-10102023-000330-A	<1	FT-FY24-10102023-000330-B	<1
WS-000331	3/28/2023	3/28/2024	Basement	Cooler	In hallway adjacent to staff restroom	Low Right	WF-03282023-000331	11/27/2023	FT-FY24-10102023-000331-A	<1	FT-FY24-10102023-000331-B	<1
WS-000333	3/28/2023	3/28/2024	1	Cooler	In hallway adjacent to staff restroom	Low Right	WF-03282023-000333	11/27/2023	FT-FY24-10102023-000333-A	<1	FT-FY24-10102023-000333-B	<1
WS-000336	9/5/2023	9/5/2024	Basement	Combo Faucet	In classroom 012	Left	WF-09052023-000336	11/27/2023	FT-FY24-10102023-000336-A	1.3	FT-FY24-10102023-000336-B	<1
WS-000337	3/28/2023	3/28/2024	Basement	Combo Fountain	In classroom 012	Right	WF-03282023-000337	11/27/2023	FT-FY24-10102023-000337-A	<1	FT-FY24-10102023-000337-B	<1
WS-000340	9/5/2023	9/5/2024	Basement	Combo Faucet	In classroom 014	Left	WF-09052023-000340	11/27/2023	FT-FY24-10102023-000340-A	1.4	FT-FY24-10102023-000340-B	<1
WS-000343	3/28/2023	3/28/2024	Basement	Combo Fountain	In classroom 014	Right	WF-03282023-000343	11/27/2023	FT-FY24-10102023-000343-A	<1	FT-FY24-10102023-000343-B	<1
WS-000345	9/5/2023	9/5/2024	Basement	Combo Faucet	In classroom 016	Left	WF-09052023-000345	11/27/2023	FT-FY24-10102023-000345-A	2.0	FT-FY24-10102023-000345-B	<1
WS-000348	3/28/2023	3/28/2024	Basement	Combo Fountain	In classroom 016	Right	WF-03282023-000348	11/27/2023	FT-FY24-10102023-000348-A	<1	FT-FY24-10102023-000348-B	<1
WS-000351	9/5/2023	9/5/2024	Basement	Combo Faucet	In classroom 018	Left	WF-09052023-000351	11/27/2023	FT-FY24-10102023-000351-A	<1	FT-FY24-10102023-000351-B	<1
WS-000354	3/28/2023	3/28/2024	Basement	Combo Fountain	In classroom 018	Right	WF-03282023-000354	11/27/2023	FT-FY24-10102023-000354-A	<1	FT-FY24-10102023-000354-B	<1
WS-000361	3/28/2023	3/28/2024	1	Health Suite	In health suite 114	WF-03282023-000361	11/27/2023	FT-FY24-10102023-000361-A	<1	FT-FY24-10102023-000361-B	<1	
WS-000363	3/28/2023	3/28/2024	1	Cooler	Annex, adjacent to boys' restroom	High Left	WF-03282023-000363	11/27/2023	FT-FY24-10102023-000363-A	<1	FT-FY24-10102023-000363-B	<1
WS-000365	3/28/2023	3/28/2024	1	Cooler	Annex, adjacent to boys' restroom	Low Right	WF-03282023-000365	11/27/2023	FT-FY24-10102023-000365-A	<1	FT-FY24-10102023-000365-B	<1
WS-000463	3/28/2023	3/28/2024	2	Cooler	Double annex, in hallway adjacent to M202	High Left	WF-03282023-000463	11/27/2023	FT-FY24-10102023-000463-A	<1	FT-FY24-10102023-000463-B	<1
WS-000464	3/28/2023	3/28/2024	2	Cooler	Double annex, in hallway adjacent to M202	Low Right	WF-03282023-000464	11/27/2023	FT-FY24-10102023-000464-A	<1	FT-FY24-10102023-000464-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000347	1/10/2023	1/10/2024	1	Food Prep Sink	In kitchen second clockwise from entry door	High	WF-01102023-000347	11/27/2023	FT-FY24-10102023-000347-A	<1	FT-FY24-10102023-000347-B	<1
WS-000350	1/10/2023	1/10/2024	1	Food Prep Sink	In kitchen third clockwise from entry door	WF-01102023-000350	11/27/2023	FT-FY24-10102023-000350-A	1.5	FT-FY24-10102023-000350-B	<1	