



LECKIE ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	LECKIE ELEMENTARY SCHOOL	WS- 000285	8/22/2016	3	Cooler	In hallway adjacent to room 310	FT-72016-000285-A	< 1	FT-72016-000285-B	< 1
2	LECKIE ELEMENTARY SCHOOL	WS- 000289	8/22/2016	3	Cooler	In hallway adjacent to custodial closet 303	FT-72016-000289-A	< 1	FT-72016-000289-B	< 1
3	LECKIE ELEMENTARY SCHOOL	WS- 000294	8/22/2016	2	Cooler	In hallway adjacent to room 213	FT-72016-000294-A	< 1	FT-72016-000294-B	< 1
4	LECKIE ELEMENTARY SCHOOL	WS- 000298	8/22/2016	2	Cooler	In hallway adjacent to custodial closet	FT-72016-000298-A	< 1	FT-72016-000298-B	< 1
5	LECKIE ELEMENTARY SCHOOL	WS- 000299	8/22/2016	1	Fountain	In classroom 122	FT-72016-000299-A	< 1	FT-72016-000299-B	< 1
6	LECKIE ELEMENTARY SCHOOL	WS- 000307	8/22/2016	1	Cooler	In hallway adjacent to room 115 High Left	FT-72016-000307-A	< 1	FT-72016-000307-B	< 1
7	LECKIE ELEMENTARY SCHOOL	WS- 000308	8/22/2016	1	Cooler	In hallway adjacent to room 115 Low Right	FT-72016-000308-A	< 1	FT-72016-000308-B	< 1
8	LECKIE ELEMENTARY SCHOOL	WS- 000309	8/22/2016	1	Fountain	In classroom 115	FT-72016-000309-A	< 1	FT-72016-000309-B	< 1
9	LECKIE ELEMENTARY SCHOOL	WS- 000313	8/22/2016	1	Fountain	In classroom 120	FT-72016-000313-A	< 1	FT-72016-000313-B	< 1
10	LECKIE ELEMENTARY SCHOOL	WS- 000316	8/22/2016	1	Fountain	In classroom 113	FT-72016-000316-A	< 1	FT-72016-000316-B	< 1
11	LECKIE ELEMENTARY SCHOOL	WS- 000323	8/22/2016	1	Fountain	In classroom 111 Right	FT-72016-000323-A	< 1	FT-72016-000323-B	< 1
12	LECKIE ELEMENTARY SCHOOL	WS- 000329	8/22/2016	Basement	Cooler	In hallway adjacent to staff restroom High Left	FT-72016-000329-A	< 1	FT-72016-000329-B	< 1
13	LECKIE ELEMENTARY SCHOOL	WS- 000330	8/22/2016	1	Cooler	In hallway adjacent to staff restroom High Left	FT-72016-000330-A	< 1	FT-72016-000330-B	< 1
14	LECKIE ELEMENTARY SCHOOL	WS- 000331	8/22/2016	Basement	Cooler	In hallway adjacent to staff restroom Low Right	FT-72016-000331-A	< 1	FT-72016-000331-B	< 1
15	LECKIE ELEMENTARY SCHOOL	WS- 000333	8/22/2016	1	Cooler	In hallway adjacent to staff restroom Low Right	FT-72016-000333-A	< 1	FT-72016-000333-B	< 1
16	LECKIE ELEMENTARY SCHOOL	WS- 000337	8/22/2016	Basement	Fountain	In classroom 012 Right	FT-72016-000337-A	< 1	FT-72016-000337-B	< 1
17	LECKIE ELEMENTARY SCHOOL	WS- 000343	8/22/2016	Basement	Fountain	In classroom 014 Right	FT-72016-000343-A	< 1	FT-72016-000343-B	< 1
18	LECKIE ELEMENTARY SCHOOL	WS- 000347	8/22/2016	1	Food Prep Sink	In kitchen second clockwise from entry door High	FT-72016-000347-A	< 1	FT-72016-000347-B	< 1
19	LECKIE ELEMENTARY SCHOOL	WS- 000348	8/22/2016	Basement	Fountain	In classroom 016 Right	FT-72016-000348-A	< 1	FT-72016-000348-B	< 1
20	LECKIE ELEMENTARY SCHOOL	WS- 000354	8/22/2016	Basement	Fountain	In classroom 018 Right	FT-72016-000354-A	< 1	FT-72016-000354-B	< 1
21	LECKIE ELEMENTARY SCHOOL	WS- 000356	8/22/2016	1	Cooler	In multi-purpose room	FT-72016-000356-A	< 1	FT-72016-000356-B	< 1
22	LECKIE ELEMENTARY SCHOOL	WS- 000361	8/22/2016	1	Health Suite	In health suite 114	FT-82016-000361-A	< 1	FT-82016-000361-B	< 1
23	LECKIE ELEMENTARY SCHOOL	WS- 000363	8/22/2016	1	Cooler	Annex, adjacent to boys' restroom Low Left	FT-72016-000363-A	< 1	FT-72016-000363-B	< 1
24	LECKIE ELEMENTARY SCHOOL	WS- 000365	8/22/2016	1	Cooler	Annex, adjacent to boys' restroom High Right	FT-82016-000365-A	< 1	FT-82016-000365-B	< 1