



LECKIE LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000285	Cooler	3	In hallway between classroom 310 and stair 2	WT-042816-302- A	< 1	WT-042816-302- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000289	Cooler	3	In hallway adjacent to custodial closet 303	WT-042816-306- A	< 1	WT-042816-306- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000294	Cooler	2	In hallway adjacent to stair 2	WT-042816-311- A	< 1	WT-042816-311- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000296	Break Room	2	In staff lounge room 207	WT-042816-313- A	< 1	WT-042816-313- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000298	Cooler	2	In hallway adjacent to custodial closet	WT-042816-315- A	< 1	WT-042816-315- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000299	Fountain	1	In classroom 122	WT-042816-316- A	< 1	WT-042816-316- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000303	Classroom	1	In classroom 122	WT-042816-320- A	< 1	WT-042816-320- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000307	Cooler	1	In hallway between classrooms 115 and stair 2 Left High	WT-042816-324- A	< 1	WT-042816-324- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000308	Cooler	1	In hallway between classrooms 115 and stair 2 Right Low	WT-042816-325- A	< 1	WT-042816-325- B	1.4				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000309	Fountain	1	In classroom 115	WT-042816-326- A	< 1	WT-042816-326- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000310	Classroom	1	In classroom 115	WT-042816-327- A	< 1	WT-042816-327- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000313	Fountain	1	In classroom 120	WT-042816-330- A	< 1	WT-042816-330- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000315	Classroom	1	In classroom 120	WT-042816-332- A	1.6	WT-042816-332- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000316	Fountain	1	In classroom 113	WT-042816-333- A	< 1	WT-042816-333- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000318	Classroom	1	In classroom 113	WT-042816-335- A	< 1	WT-042816-335- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000323	Fountain	1	In classroom 111	WT-042816-340- A	< 1	WT-042816-340- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000324	Utility	Basement	Main water source point in boiler room 034	WT-042816-341- A	3.4	WT-042816-341- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000325	Classroom	1	In classroom 111	WT-042816-342- A	< 1	WT-042816-342- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000329	Cooler	Basement	In hallway between staff bathroom and custodial closet Left High	WT-042816-346- A	< 1	WT-042816-346- B	1.7				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000330	Cooler	1	In hallway between staff restroom and custodial closet Right High	WT-042816-347- A	< 1	WT-042816-347- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000331	Cooler	Basement	In hallway between staff bathroom and custodial closet Right Low	WT-042816-348- A	< 1	WT-042816-348- B	1.8				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000333	Cooler	Basement	In hallway between staff restroom and custodial closet Right Low	WT-042816-350- A	< 1	WT-042816-350- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000336	Classroom	Basement	In room 012 Left	WT-042816-353- A	< 1	WT-042816-353- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000337	Fountain	Basement	In room 012 Right	WT-042816-354- A	< 1	WT-042816-354- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000340	Classroom	Basement	In room 014 Left	WT-042816-357- A	< 1	WT-042816-357- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000343	Fountain	Basement	In room 014 Right	WT-042816-360- A	< 1	WT-042816-360- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000344	Kitchen	1	In kitchen south wall Low	WT-042816-361- A	< 1	WT-042816-361- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000345	Classroom	Basement	In room 016 Left	WT-042816-362- A	< 1	WT-042816-362- B	1.2				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000347	Kitchen	1	In kitchen south wall facing north High	WT-042816-364- A	< 1	WT-042816-364- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000348	Fountain	Basement	In room 016 Right	WT-042816-365- A	2.1	WT-042816-365- B	1.3				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000350	Kitchen	1	In kitchen wall facing south	WT-042816-367- A	1	WT-042816-367- B	1.4				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000351	Classroom	Basement	In room 018 Left	WT-042816-368- A	< 1	WT-042816-368- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000353	Kitchen	1	First floor kitchen dish room hose	WT-042816-370- A	108	WT-042816-370- B	60.5	Filter will be installed and then retested			
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000354	Fountain	Basement	In room 018 Right	WT-042816-371- A	< 1	WT-042816-371- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000356	Cooler	1	In multi-purpose room	WT-042816-373- A	< 1	WT-042816-373- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000361	Health Suite	1	Across from room 111	WT-042816-378- A	< 1	WT-042816-378- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000363	Cooler	1	Annex adjacent to men's bathroom Left Low	WT-042816-380- A	< 1	WT-042816-380- B	< 1				
LECKIE ELEMENTARY SCHOOL	4/29/2016	WS- 000365	Cooler	1	Annex adjacent to men's bathroom Right High	WT-042816-382- A	1.1	WT-042816-382- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.