



Leckie ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation													
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000307	6/19/2017	6/19/2018	1	Cooler	In hallway adjacent to room 115	Left	High	WF-62017-000307	11/21/2017	FT-FY18-62017-000307-A	<1	FT-FY18-62017-000307-B	<1
WS-000313	6/19/2017	6/19/2018	1	Combo Fountain	In classroom 120			WF-62017-000313	11/21/2017	FT-FY18-62017-000313-A	<1	FT-FY18-62017-000313-B	<1
WS-000316	6/19/2017	6/19/2018	1	Combo Fountain	In classroom 113			WF-62017-000316	11/21/2017	FT-FY18-62017-000316-A	<1	FT-FY18-62017-000316-B	<1
WS-000330	6/19/2017	6/19/2018	1	Cooler	In hallway adjacent to staff restroom	Left	High	WF-62017-000330	11/21/2017	FT-FY18-62017-000330-A	<1	FT-FY18-62017-000330-B	<1
WS-000340	11/6/2017	11/6/2018	Basement	Combo Faucet	In classroom 014	Left		WF-112017-000340	11/21/2017	FT-FY18-112017-000340-A	<1	FT-FY18-112017-000340-B	<1
WS-000348	6/19/2017	6/19/2018	Basement	Combo Fountain	In classroom 016	Right		WF-62017-000348	11/21/2017	FT-FY18-62017-000348-A	<1	FT-FY18-62017-000348-B	<1
WS-000351	11/6/2017	11/6/2018	Basement	Combo Faucet	In classroom 018	Left		WF-112017-000351	11/21/2017	FT-FY18-112017-000351-A	<1	FT-FY18-112017-000351-B	<1
WS-000354	6/19/2017	6/19/2018	Basement	Combo Fountain	In classroom 018	Right		WF-62017-000354	11/21/2017	FT-FY18-62017-000354-A	<1	FT-FY18-62017-000354-B	<1
WS-000356	6/19/2017	6/19/2018	1	Cooler	In multi-purpose room			WF-62017-000356	11/21/2017	FT-FY18-62017-000356-A	<1	FT-FY18-62017-000356-B	<1
WS-000363	6/19/2017	6/19/2018	1	Cooler	Annex, adjacent to boys' restroom	Left	High	WF-62017-000363	11/21/2017	FT-FY18-62017-000363-A	<1	FT-FY18-62017-000363-B	<1
WS-000365	6/19/2017	6/19/2018	1	Cooler	Annex, adjacent to boys' restroom	Right	Low	WF-62017-000365	11/21/2017	FT-FY18-62017-000365-A	<1	FT-FY18-62017-000365-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000347	1	Food Prep Sink	In kitchen second clockwise from entry door			High	11/21/2017	FT-FY18-102017-000347-A	<1	FT-FY18-102017-000347-B	<1	