



Leckie EC Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000285	5/29/2018	5/29/2019	3	Cooler	In hallway adjacent to room 310	WF-05292018-000285	12/3/2018	FT-FY19-112018-000285-A	<1	FT-FY19-112018-000285-B	<1	
WS- 000289	5/29/2018	5/29/2019	3	Cooler	In hallway adjacent to custodial closet 303	WF-05292018-000289	12/3/2018	FT-FY19-112018-000289-A	<1	FT-FY19-112018-000289-B	<1	
WS- 000294	5/29/2018	5/29/2019	2	Cooler	In hallway adjacent to room 213	WF-05292018-000294	12/3/2018	FT-FY19-112018-000294-A	<1	FT-FY19-112018-000294-B	<1	
WS- 000296	5/29/2018	5/29/2019	2	Break Room	In staff lounge 207	WF-05292018-000296	12/3/2018	FT-FY19-112018-000296-A	<1	FT-FY19-112018-000296-B	<1	
WS- 000298	5/29/2018	5/29/2019	2	Cooler	In hallway adjacent to custodial closet	WF-05292018-000298	12/3/2018	FT-FY19-112018-000298-A	<1	FT-FY19-112018-000298-B	<1	
WS- 000299	5/29/2018	5/29/2019	1	Combo Fountain	In classroom 122	WF-05292018-000299	12/3/2018	FT-FY19-112018-000299-A	<1	FT-FY19-112018-000299-B	<1	
WS- 000303	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 122	WF-10162018-000303	12/3/2018	FT-FY19-112018-000303-A	<1	FT-FY19-112018-000303-B	<1	
WS- 000307	5/29/2018	5/29/2019	1	Cooler	In hallway adjacent to room 115	High Left	WF-05292018-000307	12/3/2018	FT-FY19-112018-000307-A	<1	FT-FY19-112018-000307-B	<1
WS- 000308	5/29/2018	5/29/2019	1	Cooler	In hallway adjacent to room 115	Low Right	WF-05292018-000308	12/3/2018	FT-FY19-112018-000308-A	<1	FT-FY19-112018-000308-B	<1
WS- 000309	5/29/2018	5/29/2019	1	Combo Fountain	In classroom 115		WF-05292018-000309	12/3/2018	FT-FY19-112018-000309-A	<1	FT-FY19-112018-000309-B	<1
WS- 000310	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 115		WF-10162018-000310	12/3/2018	FT-FY19-112018-000310-A	<1	FT-FY19-112018-000310-B	<1
WS- 000313	5/29/2018	5/29/2019	1	Combo Fountain	In classroom 120		WF-05292018-000313	12/3/2018	FT-FY19-112018-000313-A	<1	FT-FY19-112018-000313-B	<1
WS- 000315	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 120		WF-10162018-000315	12/3/2018	FT-FY19-112018-000315-A	<1	FT-FY19-112018-000315-B	<1
WS- 000316	5/29/2018	5/29/2019	1	Combo Fountain	In classroom 113		WF-05292018-000316	12/3/2018	FT-FY19-112018-000316-A	<1	FT-FY19-112018-000316-B	<1
WS- 000318	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 113		WF-10162018-000318	12/3/2018	FT-FY19-112018-000318-A	<1	FT-FY19-112018-000318-B	<1
WS- 000323	5/29/2018	5/29/2019	1	Combo Fountain	In classroom 111	Right	WF-05292018-000323	12/3/2018	FT-FY19-112018-000323-A	<1	FT-FY19-112018-000323-B	<1
WS- 000325	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 111	Left	WF-10162018-000325	12/3/2018	FT-FY19-112018-000325-A	<1	FT-FY19-112018-000325-B	<1
WS- 000330	5/29/2018	5/29/2019	1	Cooler	In hallway adjacent to staff restroom	High Left	WF-05292018-000330	12/3/2018	FT-FY19-112018-000330-A	<1	FT-FY19-112018-000330-B	<1
WS- 000331	5/29/2018	5/29/2019	Basement	Cooler	In hallway adjacent to staff restroom	Low Right	WF-05292018-000331	12/3/2018	FT-FY19-112018-000331-A	<1	FT-FY19-112018-000331-B	<1
WS- 000333	5/29/2018	5/29/2019	1	Cooler	In hallway adjacent to staff restroom	Low Right	WF-05292018-000333	12/3/2018	FT-FY19-112018-000333-A	<1	FT-FY19-112018-000333-B	<1
WS- 000336	10/16/2018	10/16/2019	Basement	Combo Faucet	In classroom 012	Left	WF-10162018-000336	12/3/2018	FT-FY19-112018-000336-A	<1	FT-FY19-112018-000336-B	<1
WS- 000337	5/29/2018	5/29/2019	Basement	Combo Fountain	In classroom 012	Right	WF-05292018-000337	12/3/2018	FT-FY19-112018-000337-A	<1	FT-FY19-112018-000337-B	<1
WS- 000340	10/16/2018	10/16/2019	Basement	Combo Faucet	In classroom 014	Left	WF-10162018-000340	12/3/2018	FT-FY19-112018-000340-A	<1	FT-FY19-112018-000340-B	<1
WS- 000343	5/29/2018	5/29/2019	Basement	Combo Fountain	In classroom 014	Right	WF-05292018-000343	12/3/2018	FT-FY19-112018-000343-A	<1	FT-FY19-112018-000343-B	<1
WS- 000345	10/16/2018	10/16/2019	Basement	Combo Faucet	In classroom 016	Left	WF-10162018-000345	12/3/2018	FT-FY19-112018-000345-A	<1	FT-FY19-112018-000345-B	<1
WS- 000348	5/29/2018	5/29/2019	Basement	Combo Fountain	In classroom 016	Right	WF-05292018-000348	12/3/2018	FT-FY19-112018-000348-A	<1	FT-FY19-112018-000348-B	<1
WS- 000351	10/16/2018	10/16/2019	Basement	Combo Faucet	In classroom 018	Left	WF-10162018-000351	12/3/2018	FT-FY19-112018-000351-A	<1	FT-FY19-112018-000351-B	<1
WS- 000354	5/29/2018	5/29/2019	Basement	Combo Fountain	In classroom 018	Right	WF-05292018-000354	12/3/2018	FT-FY19-112018-000354-A	<1	FT-FY19-112018-000354-B	<1
WS- 000356	5/29/2018	5/29/2019	1	Cooler	In multi-purpose room		WF-05292018-000356	12/3/2018	FT-FY19-112018-000356-A	<1	FT-FY19-112018-000356-B	<1
WS- 000361	5/29/2018	5/29/2019	1	Health Suite	In health suite 114		WF-05292018-000361	12/3/2018	FT-FY19-112018-000361-A	<1	FT-FY19-112018-000361-B	<1

WS- 000363	5/29/2018	5/29/2019	1	Cooler	Annex, adjacent to boys' restroom	High	Left	WF-05292018-000363	12/3/2018	FT-FY19-112018-000363-A	<1	FT-FY19-112018-000363-B	<1
WS- 000365	5/29/2018	5/29/2019	1	Cooler	Annex, adjacent to boys' restroom	Low	Right	WF-05292018-000365	12/3/2018	FT-FY19-112018-000365-A	<1	FT-FY19-112018-000365-B	<1
WS- 000463	5/29/2018	5/29/2019	2	Cooler	Double annex, in hallway adjacent to M202	High	Left	WF-05292018-000463	12/3/2018	FT-FY19-112018-000463-A	<1	FT-FY19-112018-000463-B	<1
WS- 000464	5/29/2018	5/29/2019	2	Cooler	Double annex, in hallway adjacent to M202	Low	Right	WF-05292018-000464	12/3/2018	FT-FY19-112018-000464-A	<1	FT-FY19-112018-000464-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000347	1	Food Prep Sink	In kitchen second clockwise from entry door	High			12/3/2018	FT-FY19-112018-000347-A	<1	FT-FY19-112018-000347-B	<1