



# LUDLOW-TAYLOR ES LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003348	12/15/2016	3	Combo Faucet	In classroom 314	FT-112016-003348-A	< 1	FT-112016-003348-B	< 1
2	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003283	12/15/2016	1	Classroom Faucet	In classroom 102 High Right	FT-112016-003283-A	< 1	FT-112016-003283-B	< 1
3	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003282	12/15/2016	1	Combo Faucet	In classroom 100 Low Left	FT-112016-003282-A	< 1	FT-112016-003282-B	< 1
4	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003287	12/15/2016	1	Combo Faucet	In classroom 104 Low	FT-112016-003287-A	< 1	FT-112016-003287-B	< 1
5	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003289	12/15/2016	1	Classroom Faucet	In classroom 106 High	FT-112016-003289-A	< 1	FT-112016-003289-B	< 1
6	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 001391	12/15/2016	3	Combo Faucet	In classroom 306	FT-112016-001391-A	< 1	FT-112016-001391-B	< 1
7	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003350	12/15/2016	3	Combo Faucet	In classroom 325	FT-112016-003350-A	< 1	FT-112016-003350-B	< 1
8	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003291	12/15/2016	1	Combo Faucet	In classroom 106 Low	FT-112016-003291-A	< 1	FT-112016-003291-B	< 1
9	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003313	12/15/2016	2	Combo Faucet	In classroom 200 Left	FT-112016-003313-A	< 1	FT-112016-003313-B	< 1
10	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003285	12/15/2016	1	Combo Faucet	In classroom 102 Low Left	FT-112016-003285-A	< 1	FT-112016-003285-B	< 1
11	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003274	12/15/2016	1	Combo Faucet	In classroom 105 Low Right	FT-112016-003274-A	< 1	FT-112016-003274-B	< 1
12	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003272	12/15/2016	1	Classroom Faucet	In classroom 105 High Left	FT-112016-003272-A	< 1	FT-112016-003272-B	< 1
13	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003318	12/15/2016	2	Combo Faucet	In classroom 204	FT-112016-003318-A	< 1	FT-112016-003318-B	< 1
14	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003277	12/15/2016	1	Classroom Faucet	In classroom 101 High Left	FT-112016-003277-A	< 1	FT-112016-003277-B	< 1
15	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003322	12/15/2016	2	Classroom Faucet	In classroom 210 High	FT-112016-003322-A	< 1	FT-112016-003322-B	< 1
16	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003326	12/15/2016	2	Classroom Faucet	In classroom 212 High	FT-112016-003326-A	< 1	FT-112016-003326-B	< 1
17	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003299	12/15/2016	1	Combo Faucet	In classroom 117 Low Left	FT-112016-003299-A	< 1	FT-112016-003299-B	< 1
18	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003301	12/15/2016	1	Classroom Faucet	In classroom 117 High Right	FT-112016-003301-A	< 1	FT-112016-003301-B	< 1
19	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003292	12/15/2016	1	Classroom Faucet	In classroom 108 High	FT-112016-003292-A	< 1	FT-112016-003292-B	< 1
20	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003294	12/15/2016	1	Combo Faucet	In classroom 108 Low	FT-112016-003294-A	< 1	FT-112016-003294-B	< 1
21	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003316	12/15/2016	2	Combo Faucet	In classroom 207	FT-112016-003316-A	< 1	FT-112016-003316-B	< 1
22	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003334	12/15/2016	2	Combo Faucet	In classroom 223	FT-112016-003334-A	< 1	FT-112016-003334-B	< 1
23	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003278	12/15/2016	1	Combo Faucet	In classroom 101 Low Right	FT-112016-003278-A	< 1	FT-112016-003278-B	< 1
24	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003328	12/15/2016	2	Combo Faucet	In classroom 212 Low	FT-112016-003328-A	< 1	FT-112016-003328-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003320	12/15/2016	2	Combo Faucet	In classroom 206	FT-112016-003320-A	1.5	FT-112016-003320-B	< 1
2	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003336	12/15/2016	2	Combo Faucet	In classroom 217	FT-112016-003336-A	1.7	FT-112016-003336-B	< 1
3	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003346	12/15/2016	3	Combo Faucet	In classroom 304	FT-112016-003346-A	1.9	FT-112016-003346-B	< 1
4	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003286	12/15/2016	1	Classroom Faucet	In classroom 104 High	FT-112016-003286-A	2.2	FT-112016-003286-B	< 1
5	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003314	12/15/2016	2	Combo Faucet	In classroom 200 Right	FT-112016-003314-A	2.2	FT-112016-003314-B	< 1
6	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003330	12/15/2016	2	Combo Faucet	In classroom 216	FT-112016-003330-A	2.3	FT-112016-003330-B	< 1
7	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003342	12/15/2016	3	Combo Faucet	In classroom 301	FT-112016-003342-A	2.4	FT-112016-003342-B	< 1
8	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003356	12/15/2016	3	Combo Faucet	In classroom 321	FT-112016-003356-A	2.6	FT-112016-003356-B	< 1
9	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003352	12/15/2016	3	Combo Faucet	In classroom 323	FT-112016-003352-A	2.7	FT-112016-003352-B	< 1
10	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003360	12/15/2016	3	Combo Faucet	In classroom 307	FT-112016-003360-A	2.8	FT-112016-003360-B	< 1
11	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003340	12/15/2016	2	Combo Faucet	In classroom 201	FT-112016-003340-A	4.4	FT-112016-003340-B	< 1
12	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003297	12/15/2016	1	Break Room	In parents' waiting room	FT-112016-003297-A	4.9	FT-112016-003297-B	< 1
13	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003280	12/15/2016	1	Classroom Faucet	In classroom 100 High Right	FT-112016-003280-A	15	FT-112016-003280-B	< 1
14	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003325	12/15/2016	2	Combo Faucet	In classroom 210 Low	FT-112016-003325-A	4.2	FT-112016-003325-B	< 1

### First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Less than 1 ppb - Device Returned to Service											
1	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003346	1/25/2017	3	Combo Faucet	In classroom 304		FT-112016-003346-A	< 1	FT-112016-003346-B	< 1
2	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003356	1/25/2017	3	Combo Faucet	In classroom 321		FT-112016-003356-A	< 1	FT-112016-003356-B	< 1
3	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003314	1/25/2017	2	Combo Faucet	In classroom 200	Right	FT-112016-003314-A	< 1	FT-112016-003314-B	< 1
4	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003280	1/25/2017	1	Classroom Faucet	In classroom 100	High Right	FT-112016-003280-A	< 1	FT-112016-003280-B	< 1
5	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003325	1/25/2017	2	Combo Faucet	In classroom 210	Low	FT-112016-003325-A	< 1	FT-112016-003325-B	< 1

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation											
1	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003352	1/25/2017	3	Combo Faucet	In classroom 323		FT-112016-003352-A	1.7	FT-112016-003352-B	< 1
2	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003286	1/25/2017	1	Classroom Faucet	In classroom 104	High	FT-112016-003286-A	1	FT-112016-003286-B	< 1
3	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003342	1/25/2017	3	Combo Faucet	In classroom 301		FT-112016-003342-A	7.4	FT-112016-003342-B	1.1
4	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003340	1/25/2017	2	Combo Faucet	In classroom 201		FT-112016-003340-A	2.3	FT-112016-003340-B	< 1
5	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003360	1/25/2017	3	Combo Faucet	In classroom 307		FT-112016-003360-A	1.8	FT-112016-003360-B	< 1
6	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003297	1/25/2017	1	Break Room	In parents' waiting room		FT-112016-003297-A	1.2	FT-112016-003297-B	< 1
7	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003330	1/25/2017	2	Combo Faucet	In classroom 216		FT-112016-003330-A	2.2	FT-112016-003330-B	< 1
8	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003320	1/25/2017	2	Combo Faucet	In classroom 206		FT-112016-003320-A	2.8	FT-112016-003320-B	< 1
9	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003336	1/25/2017	2	Combo Faucet	In classroom 217		FT-112016-003336-A	1.5	FT-112016-003336-B	< 1

### Second Filter Re-Test (After Device Replacement)

Less than 1 ppb - Device Returned to Service											
1	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003342	3/14/2017	3	Combo Faucet	In classroom 301		FT-112016-003342-A	< 1	FT-112016-003342-B	< 1
2	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003336	3/14/2017	2	Combo Faucet	In classroom 217		FT-112016-003336-A	< 1	FT-112016-003336-B	< 1

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation											
1	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003352	3/14/2017	3	Combo Faucet	In classroom 323		FT-112016-003352-A	1.4	FT-112016-003352-B	< 1
2	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003286	3/14/2017	1	Classroom Faucet	In classroom 104	High	FT-112016-003286-A	3.9	FT-112016-003286-B	< 1
3	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003340	3/14/2017	2	Combo Faucet	In classroom 201		FT-112016-003340-A	2.8	FT-112016-003340-B	< 1
4	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003360	3/14/2017	3	Combo Faucet	In classroom 307		FT-112016-003360-A	3.3	FT-112016-003360-B	< 1
5	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003297	3/14/2017	1	Break Room	In parents' waiting room		FT-112016-003297-A	5.6	FT-112016-003297-B	< 1
6	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003330	3/14/2017	2	Combo Faucet	In classroom 216		FT-112016-003330-A	2	FT-112016-003330-B	< 1
7	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003320	3/14/2017	2	Combo Faucet	In classroom 206		FT-112016-003320-A	1.9	FT-112016-003320-B	< 1

### Filter Re-Test (h # After Dual Supply Faucet Installation)

Less than 1 ppb - Devices Returned to Service											
1	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003352	/2017	3	Combo Faucet	In classroom 323		FT-112016-003352-A	< 1	FT-112016-003352-B	< 1
2	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003286	/2017	1	Classroom Faucet	In classroom 104	High	FT-112016-003286-A	< 1	FT-112016-003286-B	< 1
3	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003340	/2017	2	Combo Faucet	In classroom 201		FT-112016-003340-A	< 1	FT-112016-003340-B	< 1
4	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003360	/2017	3	Combo Faucet	In classroom 307		FT-112016-003360-A	< 1	FT-112016-003360-B	< 1
5	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003297	/2017	1	Break Room	In parents' waiting room		FT-112016-003297-A	< 1	FT-112016-003297-B	< 1
6	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003330	/2017	2	Combo Faucet	In classroom 216		FT-112016-003330-A	< 1	FT-112016-003330-B	< 1
7	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003320	/2017	2	Combo Faucet	In classroom 206		FT-112016-003320-A	< 1	FT-112016-003320-B	< 1