



Ludlow Taylor ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001391	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 306	WF-09092019-001391	12/17/2019	FT-FY20-112019-001391-A	<1	FT-FY20-112019-001391-B	<1
WS-001392	6/4/2019	6/4/2020	3	Combo Fountain	In classroom 306	WF-06042019-001392	12/17/2019	FT-FY20-112019-001392-A	<1	FT-FY20-112019-001392-B	<1
WS-003272	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 105 High Left	WF-09092019-003272	12/17/2019	FT-FY20-112019-003272-A	<1	FT-FY20-112019-003272-B	<1
WS-003273	6/4/2019	6/4/2020	1	Combo Fountain	In classroom 105	WF-06042019-003273	12/17/2019	FT-FY20-112019-003273-A	<1	FT-FY20-112019-003273-B	<1
WS-003274	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 105 Low Right	WF-09092019-003274	12/17/2019	FT-FY20-112019-003274-A	<1	FT-FY20-112019-003274-B	<1
WS-003275	6/4/2019	6/4/2020	1	Cooler	In hallway adjacent to stairwell B High Left	WF-06042019-003275	12/17/2019	FT-FY20-112019-003275-A	<1	FT-FY20-112019-003275-B	<1
WS-003276	6/4/2019	6/4/2020	1	Cooler	In hallway adjacent to stairwell B Low Right	WF-06042019-003276	12/17/2019	FT-FY20-112019-003276-A	<1	FT-FY20-112019-003276-B	<1
WS-003277	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 101 High Left	WF-09092019-003277	12/17/2019	FT-FY20-112019-003277-A	<1	FT-FY20-112019-003277-B	<1
WS-003278	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 101 Low Right	WF-09092019-003278	12/17/2019	FT-FY20-112019-003278-A	<1	FT-FY20-112019-003278-B	<1
WS-003279	6/4/2019	6/4/2020	1	Combo Fountain	In classroom 101	WF-06042019-003279	12/17/2019	FT-FY20-112019-003279-A	<1	FT-FY20-112019-003279-B	<1
WS-003280	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 100 High Right	WF-09092019-003280	12/17/2019	FT-FY20-112019-003280-A	<1	FT-FY20-112019-003280-B	<1
WS-003281	6/4/2019	6/4/2020	1	Combo Fountain	In classroom 100	WF-06042019-003281	12/17/2019	FT-FY20-112019-003281-A	<1	FT-FY20-112019-003281-B	<1
WS-003282	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 100 Low Left	WF-09092019-003282	12/17/2019	FT-FY20-112019-003282-A	<1	FT-FY20-112019-003282-B	<1
WS-003283	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 102 High Right	WF-09092019-003283	12/17/2019	FT-FY20-112019-003283-A	<1	FT-FY20-112019-003283-B	<1
WS-003284	6/4/2019	6/4/2020	1	Combo Fountain	In classroom 102	WF-06042019-003284	12/17/2019	FT-FY20-112019-003284-A	<1	FT-FY20-112019-003284-B	<1
WS-003285	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 102 Low Left	WF-09092019-003285	12/17/2019	FT-FY20-112019-003285-A	<1	FT-FY20-112019-003285-B	<1
WS-003286	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 104 High	WF-09092019-003286	12/17/2019	FT-FY20-112019-003286-A	<1	FT-FY20-112019-003286-B	<1
WS-003287	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 104 Low	WF-09092019-003287	12/17/2019	FT-FY20-112019-003287-A	<1	FT-FY20-112019-003287-B	<1
WS-003288	6/4/2019	6/4/2020	1	Combo Fountain	In classroom 104	WF-06042019-003288	12/17/2019	FT-FY20-112019-003288-A	<1	FT-FY20-112019-003288-B	<1
WS-003289	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 106 High	WF-09092019-003289	12/17/2019	FT-FY20-112019-003289-A	<1	FT-FY20-112019-003289-B	<1
WS-003290	6/4/2019	6/4/2020	1	Combo Fountain	In classroom 106	WF-06042019-003290	12/17/2019	FT-FY20-112019-003290-A	<1	FT-FY20-112019-003290-B	<1
WS-003291	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 106 Low	WF-09092019-003291	12/17/2019	FT-FY20-112019-003291-A	<1	FT-FY20-112019-003291-B	<1
WS-003292	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 108 High	WF-09092019-003292	12/17/2019	FT-FY20-112019-003292-A	<1	FT-FY20-112019-003292-B	<1
WS-003293	6/4/2019	6/4/2020	1	Combo Fountain	In bathroom in room 108	WF-06042019-003293	12/17/2019	FT-FY20-112019-003293-A	<1	FT-FY20-112019-003293-B	<1
WS-003294	9/9/2019	9/9/2020	1	Combo Faucet	In bathroom in room 108 Low	WF-09092019-003294	12/17/2019	FT-FY20-112019-003294-A	<1	FT-FY20-112019-003294-B	<1
WS-003295	6/4/2019	6/4/2020	1	Cooler	In hallway adjacent to stairwell A High Left	WF-06042019-003295	12/17/2019	FT-FY20-112019-003295-A	<1	FT-FY20-112019-003295-B	<1
WS-003296	6/4/2019	6/4/2020	1	Cooler	In hallway adjacent to stairwell A Low Right	WF-06042019-003296	12/17/2019	FT-FY20-112019-003296-A	<1	FT-FY20-112019-003296-B	<1
WS-003297	9/9/2019	9/9/2020	1	Combo Faucet	In parents' waiting room	WF-09092019-003297	12/17/2019	FT-FY20-112019-003297-A	<1	FT-FY20-112019-003297-B	<1
WS-003298	6/4/2019	6/4/2020	1	Combo Fountain	In parents' waiting room	WF-06042019-003298	12/17/2019	FT-FY20-112019-003298-A	<1	FT-FY20-112019-003298-B	<1
WS-003299	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 117 Low Left	WF-09092019-003299	12/17/2019	FT-FY20-112019-003299-A	<1	FT-FY20-112019-003299-B	<1
WS-003300	6/4/2019	6/4/2020	1	Combo Fountain	In classroom 117	WF-06042019-003300	12/17/2019	FT-FY20-112019-003300-A	<1	FT-FY20-112019-003300-B	<1

WS- 003301	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 117	High	Right	WF-09092019-003301	12/17/2019	FT-FY20-112019-003301-A	<1	FT-FY20-112019-003301-B	<1
WS- 003302	6/4/2019	6/4/2020	1	Health Suite	In health suite			WF-06042019-003302	12/17/2019	FT-FY20-112019-003302-A	<1	FT-FY20-112019-003302-B	<1
WS- 003303	6/4/2019	6/4/2020	1	Combo Fountain	In health suite			WF-06042019-003303	12/17/2019	FT-FY20-112019-003303-A	<1	FT-FY20-112019-003303-B	<1
WS- 003304	6/4/2019	6/4/2020	1	Cooler	In hallway adjacent to janitor closet			WF-06042019-003304	12/17/2019	FT-FY20-112019-003304-A	<1	FT-FY20-112019-003304-B	<1
WS- 003305	6/4/2019	6/4/2020	1	Cooler	In cafeteria			WF-06042019-003305	12/17/2019	FT-FY20-112019-003305-A	<1	FT-FY20-112019-003305-B	<1
WS- 003310	6/4/2019	6/4/2020	2	Cooler	In hallway adjacent to stairwell B	High	Left	WF-06042019-003310	12/17/2019	FT-FY20-112019-003310-A	<1	FT-FY20-112019-003310-B	<1
WS- 003311	6/4/2019	6/4/2020	2	Cooler	In hallway adjacent to stairwell B	Low	Right	WF-06042019-003311	12/17/2019	FT-FY20-112019-003311-A	<1	FT-FY20-112019-003311-B	<1
WS- 003312	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 200		Left	WF-06042019-003312	12/17/2019	FT-FY20-112019-003312-A	<1	FT-FY20-112019-003312-B	<1
WS- 003313	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 200		Left	WF-09092019-003313	12/17/2019	FT-FY20-112019-003313-A	<1	FT-FY20-112019-003313-B	<1
WS- 003314	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 200		Right	WF-09092019-003314	12/17/2019	FT-FY20-112019-003314-A	<1	FT-FY20-112019-003314-B	<1
WS- 003315	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 200		Right	WF-06042019-003315	12/17/2019	FT-FY20-112019-003315-A	<1	FT-FY20-112019-003315-B	<1
WS- 003316	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 207			WF-09092019-003316	12/17/2019	FT-FY20-112019-003316-A	<1	FT-FY20-112019-003316-B	<1
WS- 003317	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 207			WF-06042019-003317	12/17/2019	FT-FY20-112019-003317-A	<1	FT-FY20-112019-003317-B	<1
WS- 003318	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 204			WF-09092019-003318	12/17/2019	FT-FY20-112019-003318-A	<1	FT-FY20-112019-003318-B	<1
WS- 003319	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 204			WF-06042019-003319	12/17/2019	FT-FY20-112019-003319-A	<1	FT-FY20-112019-003319-B	<1
WS- 003320	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 206			WF-09092019-003320	12/17/2019	FT-FY20-112019-003320-A	<1	FT-FY20-112019-003320-B	<1
WS- 003321	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 206			WF-06042019-003321	12/17/2019	FT-FY20-112019-003321-A	<1	FT-FY20-112019-003321-B	<1
WS- 003322	9/9/2019	9/9/2020	2	Classroom Faucet	In classroom 210	High		WF-09092019-003322	12/17/2019	FT-FY20-112019-003322-A	<1	FT-FY20-112019-003322-B	<1
WS- 003324	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 210			WF-06042019-003324	12/17/2019	FT-FY20-112019-003324-A	<1	FT-FY20-112019-003324-B	<1
WS- 003325	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 210	Low		WF-09092019-003325	12/17/2019	FT-FY20-112019-003325-A	<1	FT-FY20-112019-003325-B	<1
WS- 003326	9/9/2019	9/9/2020	2	Classroom Faucet	In classroom 212	High		WF-09092019-003326	12/17/2019	FT-FY20-112019-003326-A	<1	FT-FY20-112019-003326-B	<1
WS- 003327	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 212			WF-06042019-003327	12/17/2019	FT-FY20-112019-003327-A	<1	FT-FY20-112019-003327-B	<1
WS- 003328	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 212	Low		WF-09092019-003328	12/17/2019	FT-FY20-112019-003328-A	<1	FT-FY20-112019-003328-B	<1
WS- 003329	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 216			WF-06042019-003329	12/17/2019	FT-FY20-112019-003329-A	<1	FT-FY20-112019-003329-B	<1
WS- 003330	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 216			WF-09092019-003330	12/17/2019	FT-FY20-112019-003330-A	<1	FT-FY20-112019-003330-B	<1
WS- 003332	6/4/2019	6/4/2020	2	Cooler	In hallway adjacent to stairwell A	High	Left	WF-06042019-003332	12/17/2019	FT-FY20-112019-003332-A	<1	FT-FY20-112019-003332-B	<1
WS- 003333	6/4/2019	6/4/2020	2	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-06042019-003333	12/17/2019	FT-FY20-112019-003333-A	<1	FT-FY20-112019-003333-B	<1
WS- 003334	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 223			WF-09092019-003334	12/17/2019	FT-FY20-112019-003334-A	<1	FT-FY20-112019-003334-B	<1
WS- 003335	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 223			WF-06042019-003335	12/17/2019	FT-FY20-112019-003335-A	<1	FT-FY20-112019-003335-B	<1
WS- 003336	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 217			WF-09092019-003336	12/17/2019	FT-FY20-112019-003336-A	<1	FT-FY20-112019-003336-B	<1
WS- 003337	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 217			WF-06042019-003337	12/17/2019	FT-FY20-112019-003337-A	<1	FT-FY20-112019-003337-B	<1
WS- 003338	6/4/2019	6/4/2020	2	Classroom Faucet	In Spanish room 215			WF-06042019-003338	12/17/2019	FT-FY20-112019-003338-A	<1	FT-FY20-112019-003338-B	<1
WS- 003339	6/4/2019	6/4/2020	2	Combo Fountain	In spanish room 215			WF-06042019-003339	12/17/2019	FT-FY20-112019-003339-A	<1	FT-FY20-112019-003339-B	<1
WS- 003340	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 201			WF-09092019-003340	12/17/2019	FT-FY20-112019-003340-A	<1	FT-FY20-112019-003340-B	<1
WS- 003341	6/4/2019	6/4/2020	2	Combo Fountain	In classroom 201			WF-06042019-003341	12/17/2019	FT-FY20-112019-003341-A	<1	FT-FY20-112019-003341-B	<1
WS- 003342	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 301			WF-09092019-003342	12/17/2019	FT-FY20-112019-003342-A	2	FT-FY20-112019-003342-B	<1
WS- 003343	6/4/2019	6/4/2020	3	Combo Fountain	In classroom 301			WF-06042019-003343	12/17/2019	FT-FY20-112019-003343-A	<1	FT-FY20-112019-003343-B	<1

WS- 003344	6/4/2019	6/4/2020	3	Cooler	In hallway adjacent to stairwell B	High	Left	WF-06042019-003344	12/17/2019	FT-FY20-112019-003344-A	<1	FT-FY20-112019-003344-B	<1
WS- 003345	6/4/2019	6/4/2020	3	Cooler	In hallway adjacent to stairwell B	Low	Right	WF-06042019-003345	12/17/2019	FT-FY20-112019-003345-A	<1	FT-FY20-112019-003345-B	<1
WS- 003346	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 304			WF-09092019-003346	12/17/2019	FT-FY20-112019-003346-A	1.1	FT-FY20-112019-003346-B	<1
WS- 003347	6/4/2019	6/4/2020	3	Combo Fountain	In classroom 304			WF-06042019-003347	12/17/2019	FT-FY20-112019-003347-A	<1	FT-FY20-112019-003347-B	<1
WS- 003348	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 314			WF-09092019-003348	12/17/2019	FT-FY20-112019-003348-A	<1	FT-FY20-112019-003348-B	<1
WS- 003349	6/4/2019	6/4/2020	3	Combo Fountain	In classroom 314			WF-06042019-003349	12/17/2019	FT-FY20-112019-003349-A	<1	FT-FY20-112019-003349-B	<1
WS- 003350	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 325			WF-09092019-003350	12/17/2019	FT-FY20-112019-003350-A	<1	FT-FY20-112019-003350-B	<1
WS- 003351	6/4/2019	6/4/2020	3	Combo Fountain	In classroom 325			WF-06042019-003351	12/17/2019	FT-FY20-112019-003351-A	<1	FT-FY20-112019-003351-B	<1
WS- 003352	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 323			WF-09092019-003352	12/17/2019	FT-FY20-112019-003352-A	<1	FT-FY20-112019-003352-B	<1
WS- 003353	6/4/2019	6/4/2020	3	Combo Fountain	In classroom 323			WF-06042019-003353	12/17/2019	FT-FY20-112019-003353-A	<1	FT-FY20-112019-003353-B	<1
WS- 003354	6/4/2019	6/4/2020	3	Cooler	In hallway adjacent to stairwell A	High	Left	WF-06042019-003354	12/17/2019	FT-FY20-112019-003354-A	<1	FT-FY20-112019-003354-B	<1
WS- 003355	6/4/2019	6/4/2020	3	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-06042019-003355	12/17/2019	FT-FY20-112019-003355-A	<1	FT-FY20-112019-003355-B	<1
WS- 003356	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 321			WF-09092019-003356	12/17/2019	FT-FY20-112019-003356-A	<1	FT-FY20-112019-003356-B	<1
WS- 003357	6/4/2019	6/4/2020	3	Combo Fountain	In classroom 321			WF-06042019-003357	12/17/2019	FT-FY20-112019-003357-A	<1	FT-FY20-112019-003357-B	<1
WS- 003358	6/4/2019	6/4/2020	3	Break Room	In breakroom 317			WF-06042019-003358	12/17/2019	FT-FY20-112019-003358-A	<1	FT-FY20-112019-003358-B	<1
WS- 003359	6/4/2019	6/4/2020	3	Combo Fountain	In break room 317			WF-06042019-003359	12/17/2019	FT-FY20-112019-003359-A	<1	FT-FY20-112019-003359-B	<1
WS- 003360	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 307			WF-09092019-003360	12/17/2019	FT-FY20-112019-003360-A	<1	FT-FY20-112019-003360-B	<1
WS- 003361	6/4/2019	6/4/2020	3	Combo Fountain	In classroom 307			WF-06042019-003361	12/17/2019	FT-FY20-112019-003361-A	<1	FT-FY20-112019-003361-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003307	7/3/2019	7/3/2020	1	Food Prep Sink	In kitchen on east wall	Right	WF-07032019-003307	12/17/2019	FT-FY20-112019-003307-A	<1	FT-FY20-112019-003307-B	<1