



# Ludlow-Taylor Elementary School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001391	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 306	WF-08312020-001391	3/13/2021	FT-FY21-032021-001391-A	<1	FT-FY21-032021-001391-B	<1
WS-001392	5/27/2020	5/27/2021	3	Combo Fountain	In classroom 306	WF-05272020-001392	3/13/2021	FT-FY21-032021-001392-A	<1	FT-FY21-032021-001392-B	<1
WS-003272	8/31/2020	8/31/2021	1	Classroom Faucet	In classroom 105 High Left	WF-08312020-003272	3/13/2021	FT-FY21-032021-003272-A	<1	FT-FY21-032021-003272-B	<1
WS-003273	5/27/2020	5/27/2021	1	Combo Fountain	In classroom 105	WF-05272020-003273	3/13/2021	FT-FY21-032021-003273-A	<1	FT-FY21-032021-003273-B	<1
WS-003274	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 105 Low Right	WF-08312020-003274	3/13/2021	FT-FY21-032021-003274-A	<1	FT-FY21-032021-003274-B	<1
WS-003275	5/27/2020	5/27/2021	1	Cooler	In hallway adjacent to stairwell B High Left	WF-05272020-003275	3/13/2021	FT-FY21-032021-003275-A	<1	FT-FY21-032021-003275-B	2.0
WS-003276	5/27/2020	5/27/2021	1	Cooler	In hallway adjacent to stairwell B Low Right	WF-05272020-003276	3/13/2021	FT-FY21-032021-003276-A	<1	FT-FY21-032021-003276-B	<1
WS-003277	8/31/2020	8/31/2021	1	Classroom Faucet	In classroom 101 High Left	WF-08312020-003277	3/13/2021	FT-FY21-032021-003277-A	<1	FT-FY21-032021-003277-B	<1
WS-003278	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 101 Low Right	WF-08312020-003278	3/13/2021	FT-FY21-032021-003278-A	<1	FT-FY21-032021-003278-B	<1
WS-003279	5/27/2020	5/27/2021	1	Combo Fountain	In classroom 101	WF-05272020-003279	3/13/2021	FT-FY21-032021-003279-A	<1	FT-FY21-032021-003279-B	<1
WS-003280	8/31/2020	8/31/2021	1	Classroom Faucet	In classroom 100 High Right	WF-08312020-003280	3/13/2021	FT-FY21-032021-003280-A	<1	FT-FY21-032021-003280-B	<1
WS-003281	5/27/2020	5/27/2021	1	Combo Fountain	In classroom 100	WF-05272020-003281	3/13/2021	FT-FY21-032021-003281-A	<1	FT-FY21-032021-003281-B	<1
WS-003282	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 100 Low Left	WF-08312020-003282	3/13/2021	FT-FY21-032021-003282-A	1.5	FT-FY21-032021-003282-B	<1
WS-003283	8/31/2020	8/31/2021	1	Classroom Faucet	In classroom 102 High Right	WF-08312020-003283	3/13/2021	FT-FY21-032021-003283-A	1.6	FT-FY21-032021-003283-B	<1
WS-003284	5/27/2020	5/27/2021	1	Combo Fountain	In classroom 102	WF-05272020-003284	3/13/2021	FT-FY21-032021-003284-A	<1	FT-FY21-032021-003284-B	<1
WS-003285	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 102 Low Left	WF-08312020-003285	3/13/2021	FT-FY21-032021-003285-A	<1	FT-FY21-032021-003285-B	<1
WS-003286	8/31/2020	8/31/2021	1	Classroom Faucet	In classroom 104 High	WF-08312020-003286	3/13/2021	FT-FY21-032021-003286-A	<1	FT-FY21-032021-003286-B	<1
WS-003287	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 104 Low	WF-08312020-003287	3/13/2021	FT-FY21-032021-003287-A	<1	FT-FY21-032021-003287-B	<1
WS-003288	5/27/2020	5/27/2021	1	Combo Fountain	In classroom 104	WF-05272020-003288	3/13/2021	FT-FY21-032021-003288-A	<1	FT-FY21-032021-003288-B	<1
WS-003289	8/31/2020	8/31/2021	1	Classroom Faucet	In classroom 106 High	WF-08312020-003289	3/13/2021	FT-FY21-032021-003289-A	1.1	FT-FY21-032021-003289-B	<1
WS-003290	5/27/2020	5/27/2021	1	Combo Fountain	In classroom 106	WF-05272020-003290	3/13/2021	FT-FY21-032021-003290-A	<1	FT-FY21-032021-003290-B	<1
WS-003291	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 106 Low	WF-08312020-003291	3/13/2021	FT-FY21-032021-003291-A	<1	FT-FY21-032021-003291-B	<1
WS-003292	8/31/2020	8/31/2021	1	Classroom Faucet	In classroom 108 High	WF-08312020-003292	3/13/2021	FT-FY21-032021-003292-A	<1	FT-FY21-032021-003292-B	<1
WS-003293	5/27/2020	5/27/2021	1	Combo Fountain	In bathroom in room 108	WF-05272020-003293	3/13/2021	FT-FY21-032021-003293-A	<1	FT-FY21-032021-003293-B	<1
WS-003294	8/31/2020	8/31/2021	1	Combo Faucet	In bathroom in room 108 Low	WF-08312020-003294	3/13/2021	FT-FY21-032021-003294-A	<1	FT-FY21-032021-003294-B	<1
WS-003295	5/27/2020	5/27/2021	1	Cooler	In hallway adjacent to stairwell A High Left	WF-05272020-003295	3/13/2021	FT-FY21-032021-003295-A	<1	FT-FY21-032021-003295-B	<1
WS-003296	5/27/2020	5/27/2021	1	Cooler	In hallway adjacent to stairwell A Low Right	WF-05272020-003296	3/13/2021	FT-FY21-032021-003296-A	<1	FT-FY21-032021-003296-B	<1
WS-003297	8/31/2020	8/31/2021	1	Combo Faucet	In parents' waiting room	WF-08312020-003297	3/13/2021	FT-FY21-032021-003297-A	<1	FT-FY21-032021-003297-B	<1
WS-003298	5/27/2020	5/27/2021	1	Combo Fountain	In parents' waiting room	WF-05272020-003298	3/13/2021	FT-FY21-032021-003298-A	<1	FT-FY21-032021-003298-B	<1
WS-003299	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 117 Low Left	WF-08312020-003299	3/13/2021	FT-FY21-032021-003299-A	<1	FT-FY21-032021-003299-B	<1
WS-003300	5/27/2020	5/27/2021	1	Combo Fountain	In classroom 117	WF-05272020-003300	3/13/2021	FT-FY21-032021-003300-A	<1	FT-FY21-032021-003300-B	<1
WS-003301	8/31/2020	8/31/2021	1	Classroom Faucet	In classroom 117 High Right	WF-08312020-003301	3/13/2021	FT-FY21-032021-003301-A	<1	FT-FY21-032021-003301-B	<1

WS-003302	5/27/2020	5/27/2021	1	Health Suite	In health suite			WF-05272020-003302	3/13/2021	FT-FY21-032021-003302-A	<1	FT-FY21-032021-003302-B	<1
WS-003303	5/27/2020	5/27/2021	1	Combo Fountain	In health suite			WF-05272020-003303	3/13/2021	FT-FY21-032021-003303-A	<1	FT-FY21-032021-003303-B	<1
WS-003304	5/27/2020	5/27/2021	1	Cooler	In hallway adjacent to janitor closet			WF-05272020-003304	3/13/2021	FT-FY21-032021-003304-A	<1	FT-FY21-032021-003304-B	<1
WS-003305	5/27/2020	5/27/2021	1	Cooler	In cafeteria			WF-05272020-003305	3/13/2021	FT-FY21-032021-003305-A	<1	FT-FY21-032021-003305-B	<1
WS-003310	5/27/2020	5/27/2021	2	Cooler	In hallway adjacent to stairwell B	High	Left	WF-05272020-003310	3/13/2021	FT-FY21-032021-003310-A	<1	FT-FY21-032021-003310-B	<1
WS-003311	5/27/2020	5/27/2021	2	Cooler	In hallway adjacent to stairwell B	Low	Right	WF-05272020-003311	3/13/2021	FT-FY21-032021-003311-A	<1	FT-FY21-032021-003311-B	<1
WS-003312	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 200		Left	WF-05272020-003312	3/13/2021	FT-FY21-032021-003312-A	<1	FT-FY21-032021-003312-B	<1
WS-003313	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 200		Left	WF-08312020-003313	3/13/2021	FT-FY21-032021-003313-A	<1	FT-FY21-032021-003313-B	<1
WS-003314	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 200		Right	WF-08312020-003314	3/13/2021	FT-FY21-032021-003314-A	<1	FT-FY21-032021-003314-B	<1
WS-003315	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 200		Right	WF-05272020-003315	3/13/2021	FT-FY21-032021-003315-A	<1	FT-FY21-032021-003315-B	<1
WS-003316	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 207			WF-08312020-003316	3/13/2021	FT-FY21-032021-003316-A	<1	FT-FY21-032021-003316-B	<1
WS-003317	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 207			WF-05272020-003317	3/13/2021	FT-FY21-032021-003317-A	<1	FT-FY21-032021-003317-B	<1
WS-003318	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 204			WF-08312020-003318	3/13/2021	FT-FY21-032021-003318-A	<1	FT-FY21-032021-003318-B	<1
WS-003319	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 204			WF-05272020-003319	3/13/2021	FT-FY21-032021-003319-A	<1	FT-FY21-032021-003319-B	<1
WS-003320	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 206			WF-08312020-003320	3/13/2021	FT-FY21-032021-003320-A	<1	FT-FY21-032021-003320-B	<1
WS-003321	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 206			WF-05272020-003321	3/13/2021	FT-FY21-032021-003321-A	<1	FT-FY21-032021-003321-B	<1
WS-003322	8/31/2020	8/31/2021	2	Classroom Faucet	In classroom 210	High		WF-08312020-003322	3/13/2021	FT-FY21-032021-003322-A	<1	FT-FY21-032021-003322-B	<1
WS-003324	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 210			WF-05272020-003324	3/13/2021	FT-FY21-032021-003324-A	<1	FT-FY21-032021-003324-B	<1
WS-003325	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 210	Low		WF-08312020-003325	3/13/2021	FT-FY21-032021-003325-A	<1	FT-FY21-032021-003325-B	<1
WS-003327	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 212			WF-05272020-003327	3/13/2021	FT-FY21-032021-003327-A	<1	FT-FY21-032021-003327-B	<1
WS-003328	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 212	Low		WF-08312020-003328	3/13/2021	FT-FY21-032021-003328-A	<1	FT-FY21-032021-003328-B	<1
WS-003329	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 216			WF-05272020-003329	3/13/2021	FT-FY21-032021-003329-A	<1	FT-FY21-032021-003329-B	<1
WS-003330	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 216			WF-08312020-003330	3/13/2021	FT-FY21-032021-003330-A	<1	FT-FY21-032021-003330-B	<1
WS-003332	5/27/2020	5/27/2021	2	Cooler	In hallway adjacent to stairwell A	High	Left	WF-05272020-003332	3/13/2021	FT-FY21-032021-003332-A	<1	FT-FY21-032021-003332-B	<1
WS-003333	5/27/2020	5/27/2021	2	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-05272020-003333	3/13/2021	FT-FY21-032021-003333-A	<1	FT-FY21-032021-003333-B	<1
WS-003334	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 223			WF-08312020-003334	3/13/2021	FT-FY21-032021-003334-A	<1	FT-FY21-032021-003334-B	<1
WS-003335	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 223			WF-05272020-003335	3/13/2021	FT-FY21-032021-003335-A	<1	FT-FY21-032021-003335-B	<1
WS-003336	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 217			WF-08312020-003336	3/13/2021	FT-FY21-032021-003336-A	<1	FT-FY21-032021-003336-B	<1
WS-003337	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 217			WF-05272020-003337	3/13/2021	FT-FY21-032021-003337-A	<1	FT-FY21-032021-003337-B	<1
WS-003338	5/27/2020	5/27/2021	2	Classroom Faucet	In Spanish room 215			WF-05272020-003338	3/13/2021	FT-FY21-032021-003338-A	<1	FT-FY21-032021-003338-B	<1
WS-003339	5/27/2020	5/27/2021	2	Combo Fountain	In spanish room 215			WF-05272020-003339	3/13/2021	FT-FY21-032021-003339-A	<1	FT-FY21-032021-003339-B	<1
WS-003340	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 201			WF-08312020-003340	3/13/2021	FT-FY21-032021-003340-A	<1	FT-FY21-032021-003340-B	<1
WS-003341	5/27/2020	5/27/2021	2	Combo Fountain	In classroom 201			WF-05272020-003341	3/13/2021	FT-FY21-032021-003341-A	<1	FT-FY21-032021-003341-B	<1
WS-003342	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 301			WF-08312020-003342	3/13/2021	FT-FY21-032021-003342-A	<1	FT-FY21-032021-003342-B	<1
WS-003343	5/27/2020	5/27/2021	3	Combo Fountain	In classroom 301			WF-05272020-003343	3/13/2021	FT-FY21-032021-003343-A	<1	FT-FY21-032021-003343-B	<1
WS-003344	5/27/2020	5/27/2021	3	Cooler	In hallway adjacent to stairwell B	High	Left	WF-05272020-003344	3/13/2021	FT-FY21-032021-003344-A	<1	FT-FY21-032021-003344-B	1.5
WS-003345	5/27/2020	5/27/2021	3	Cooler	In hallway adjacent to stairwell B	Low	Right	WF-05272020-003345	3/13/2021	FT-FY21-032021-003345-A	<1	FT-FY21-032021-003345-B	<1
WS-003346	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 304			WF-08312020-003346	3/13/2021	FT-FY21-032021-003346-A	<1	FT-FY21-032021-003346-B	<1

WS- 003347	5/27/2020	5/27/2021	3	Combo Fountain	In classroom 304		WF-05272020-003347	3/13/2021	FT-FY21-032021-003347-A	<1	FT-FY21-032021-003347-B	<1
WS- 003348	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 314		WF-08312020-003348	3/13/2021	FT-FY21-032021-003348-A	<1	FT-FY21-032021-003348-B	<1
WS- 003349	5/27/2020	5/27/2021	3	Combo Fountain	In classroom 314		WF-05272020-003349	3/13/2021	FT-FY21-032021-003349-A	<1	FT-FY21-032021-003349-B	<1
WS- 003350	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 325		WF-08312020-003350	3/13/2021	FT-FY21-032021-003350-A	<1	FT-FY21-032021-003350-B	<1
WS- 003351	5/27/2020	5/27/2021	3	Combo Fountain	In classroom 325		WF-05272020-003351	3/13/2021	FT-FY21-032021-003351-A	<1	FT-FY21-032021-003351-B	<1
WS- 003352	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 323		WF-08312020-003352	3/13/2021	FT-FY21-032021-003352-A	<1	FT-FY21-032021-003352-B	<1
WS- 003353	5/27/2020	5/27/2021	3	Combo Fountain	In classroom 323		WF-05272020-003353	3/13/2021	FT-FY21-032021-003353-A	1.2	FT-FY21-032021-003353-B	<1
WS- 003354	5/27/2020	5/27/2021	3	Cooler	In hallway adjacent to stairwell A	High Left	WF-05272020-003354	3/13/2021	FT-FY21-032021-003354-A	<1	FT-FY21-032021-003354-B	<1
WS- 003355	5/27/2020	5/27/2021	3	Cooler	In hallway adjacent to stairwell A	Low Right	WF-05272020-003355	3/13/2021	FT-FY21-032021-003355-A	<1	FT-FY21-032021-003355-B	<1
WS- 003356	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 321		WF-08312020-003356	3/13/2021	FT-FY21-032021-003356-A	<1	FT-FY21-032021-003356-B	<1
WS- 003357	5/27/2020	5/27/2021	3	Combo Fountain	In classroom 321		WF-05272020-003357	3/13/2021	FT-FY21-032021-003357-A	<1	FT-FY21-032021-003357-B	<1
WS- 003358	5/27/2020	5/27/2021	3	Break Room	In breakroom 317		WF-05272020-003358	3/13/2021	FT-FY21-032021-003358-A	1.0	FT-FY21-032021-003358-B	<1
WS- 003359	5/27/2020	5/27/2021	3	Combo Fountain	In break room 317		WF-05272020-003359	3/13/2021	FT-FY21-032021-003359-A	<1	FT-FY21-032021-003359-B	<1
WS- 003360	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 307		WF-08312020-003360	3/13/2021	FT-FY21-032021-003360-A	<1	FT-FY21-032021-003360-B	<1
WS- 003361	5/27/2020	5/27/2021	3	Combo Fountain	In classroom 307		WF-05272020-003361	3/13/2021	FT-FY21-032021-003361-A	<1	FT-FY21-032021-003361-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003307	2/16/2021	2/16/2022	1	Food Prep Sink	In kitchen on east wall	Right	WF-02162021-003307	3/13/2021	FT-FY21-032021-003307-A	<1	FT-FY21-032021-003307-B	<1