



# Ludlow-Taylor Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001391	8/15/2022	8/15/2023	3	Combo Faucet	In classroom 306	WF-08152022-001391	11/22/2022	FT-FY23-11042022-001391-A	<1	FT-FY23-11042022-001391-B	<1
WS- 001392	4/18/2022	4/18/2023	3	Combo Fountain	In classroom 306	WF-04182022-001392	11/22/2022	FT-FY23-11042022-001392-A	<1	FT-FY23-11042022-001392-B	<1
WS- 003272	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 105 High Left	WF-08152022-003272	11/22/2022	FT-FY23-11042022-003272-A	<1	FT-FY23-11042022-003272-B	<1
WS- 003273	4/18/2022	4/18/2023	1	Combo Fountain	In classroom 105	WF-04182022-003273	11/22/2022	FT-FY23-11042022-003273-A	<1	FT-FY23-11042022-003273-B	<1
WS- 003274	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 105 Low Right	WF-08152022-003274	11/22/2022	FT-FY23-11042022-003274-A	<1	FT-FY23-11042022-003274-B	<1
WS- 003275	4/18/2022	4/18/2023	1	Cooler	In hallway adjacent to stairwell B High Left	WF-04182022-003275	11/22/2022	FT-FY23-11042022-003275-A	<1	FT-FY23-11042022-003275-B	<1
WS- 003276	4/18/2022	4/18/2023	1	Cooler	In hallway adjacent to stairwell B Low Right	WF-04182022-003276	11/22/2022	FT-FY23-11042022-003276-A	<1	FT-FY23-11042022-003276-B	<1
WS- 003277	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 101 High Left	WF-08152022-003277	11/22/2022	FT-FY23-11042022-003277-A	<1	FT-FY23-11042022-003277-B	<1
WS- 003278	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 101 Low Right	WF-08152022-003278	11/22/2022	FT-FY23-11042022-003278-A	<1	FT-FY23-11042022-003278-B	<1
WS- 003279	4/18/2022	4/18/2023	1	Combo Fountain	In classroom 101	WF-04182022-003279	11/22/2022	FT-FY23-11042022-003279-A	<1	FT-FY23-11042022-003279-B	<1
WS- 003280	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 100 High Right	WF-08152022-003280	11/22/2022	FT-FY23-11042022-003280-A	<1	FT-FY23-11042022-003280-B	<1
WS- 003281	4/18/2022	4/18/2023	1	Combo Fountain	In classroom 100	WF-04182022-003281	11/22/2022	FT-FY23-11042022-003281-A	<1	FT-FY23-11042022-003281-B	<1
WS- 003282	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 100 Low Left	WF-08152022-003282	11/22/2022	FT-FY23-11042022-003282-A	<1	FT-FY23-11042022-003282-B	<1
WS- 003283	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 102 High Right	WF-08152022-003283	11/22/2022	FT-FY23-11042022-003283-A	<1	FT-FY23-11042022-003283-B	<1
WS- 003284	4/18/2022	4/18/2023	1	Combo Fountain	In classroom 102	WF-04182022-003284	11/22/2022	FT-FY23-11042022-003284-A	<1	FT-FY23-11042022-003284-B	<1
WS- 003285	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 102 Low Left	WF-08152022-003285	11/22/2022	FT-FY23-11042022-003285-A	<1	FT-FY23-11042022-003285-B	<1
WS- 003286	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 104 High	WF-08152022-003286	11/22/2022	FT-FY23-11042022-003286-A	<1	FT-FY23-11042022-003286-B	<1
WS- 003287	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 104 Low	WF-08152022-003287	11/22/2022	FT-FY23-11042022-003287-A	<1	FT-FY23-11042022-003287-B	<1
WS- 003288	4/18/2022	4/18/2023	1	Combo Fountain	In classroom 104	WF-04182022-003288	11/22/2022	FT-FY23-11042022-003288-A	<1	FT-FY23-11042022-003288-B	<1
WS- 003289	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 106 High	WF-08152022-003289	11/22/2022	FT-FY23-11042022-003289-A	<1	FT-FY23-11042022-003289-B	<1
WS- 003290	4/18/2022	4/18/2023	1	Combo Fountain	In classroom 106	WF-04182022-003290	11/22/2022	FT-FY23-11042022-003290-A	<1	FT-FY23-11042022-003290-B	<1
WS- 003291	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 106 Low	WF-08152022-003291	11/22/2022	FT-FY23-11042022-003291-A	<1	FT-FY23-11042022-003291-B	<1
WS- 003292	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 108 High	WF-08152022-003292	11/22/2022	FT-FY23-11042022-003292-A	<1	FT-FY23-11042022-003292-B	<1
WS- 003293	4/18/2022	4/18/2023	1	Combo Fountain	In bathroom in room 108	WF-04182022-003293	11/22/2022	FT-FY23-11042022-003293-A	<1	FT-FY23-11042022-003293-B	<1
WS- 003294	8/15/2022	8/15/2023	1	Combo Faucet	In bathroom in room 108 Low	WF-08152022-003294	11/22/2022	FT-FY23-11042022-003294-A	<1	FT-FY23-11042022-003294-B	<1
WS- 003295	4/18/2022	4/18/2023	1	Cooler	In hallway adjacent to stairwell A High Left	WF-04182022-003295	11/22/2022	FT-FY23-11042022-003295-A	<1	FT-FY23-11042022-003295-B	<1
WS- 003296	4/18/2022	4/18/2023	1	Cooler	In hallway adjacent to stairwell A Low Right	WF-04182022-003296	11/22/2022	FT-FY23-11042022-003296-A	<1	FT-FY23-11042022-003296-B	<1
WS- 003297	8/15/2022	8/15/2023	1	Combo Faucet	In parents' waiting room	WF-08152022-003297	11/22/2022	FT-FY23-11042022-003297-A	<1	FT-FY23-11042022-003297-B	<1
WS- 003298	4/18/2022	4/18/2023	1	Combo Fountain	In parents' waiting room	WF-04182022-003298	11/22/2022	FT-FY23-11042022-003298-A	<1	FT-FY23-11042022-003298-B	<1
WS- 003299	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 117 Low Left	WF-08152022-003299	11/22/2022	FT-FY23-11042022-003299-A	<1	FT-FY23-11042022-003299-B	<1
WS- 003300	4/18/2022	4/18/2023	1	Combo Fountain	In classroom 117	WF-04182022-003300	11/22/2022	FT-FY23-11042022-003300-A	<1	FT-FY23-11042022-003300-B	<1
WS- 003301	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 117 High Right	WF-08152022-003301	11/22/2022	FT-FY23-11042022-003301-A	<1	FT-FY23-11042022-003301-B	<1
WS- 003302	4/18/2022	4/18/2023	1	Health Suite	In health suite	WF-04182022-003302	11/22/2022	FT-FY23-11042022-003302-A	<1	FT-FY23-11042022-003302-B	<1
WS- 003303	4/18/2022	4/18/2023	1	Combo Fountain	In health suite	WF-04182022-003303	11/22/2022	FT-FY23-11042022-003303-A	<1	FT-FY23-11042022-003303-B	<1

WS- 003304	4/18/2022	4/18/2023	1	Cooler	In hallway adjacent to janitor closet		WF-04182022-003304	11/22/2022	FT-FY23-11042022-003304-A	<1	FT-FY23-11042022-003304-B	<1
WS- 003305	4/18/2022	4/18/2023	1	Cooler	In cafeteria		WF-04182022-003305	11/22/2022	FT-FY23-11042022-003305-A	<1	FT-FY23-11042022-003305-B	<1
WS- 003310	4/18/2022	4/18/2023	2	Cooler	In hallway adjacent to stairwell B	High Left	WF-04182022-003310	11/22/2022	FT-FY23-11042022-003310-A	<1	FT-FY23-11042022-003310-B	<1
WS- 003311	4/18/2022	4/18/2023	2	Cooler	In hallway adjacent to stairwell B	Low Right	WF-04182022-003311	11/22/2022	FT-FY23-11042022-003311-A	<1	FT-FY23-11042022-003311-B	<1
WS- 003312	4/18/2022	4/18/2023	2	Combo Fountain	In classroom 200	Left	WF-04182022-003312	11/22/2022	FT-FY23-11042022-003312-A	<1	FT-FY23-11042022-003312-B	<1
WS- 003313	8/15/2022	8/15/2023	2	Combo Faucet	In classroom 200	Left	WF-08152022-003313	11/22/2022	FT-FY23-11042022-003313-A	<1	FT-FY23-11042022-003313-B	<1
WS- 003314	8/15/2022	8/15/2023	2	Combo Faucet	In classroom 200	Right	WF-08152022-003314	11/22/2022	FT-FY23-11042022-003314-A	<1	FT-FY23-11042022-003314-B	<1
WS- 003315	4/18/2022	4/18/2023	2	Combo Fountain	In classroom 200	Right	WF-04182022-003315	11/22/2022	FT-FY23-11042022-003315-A	<1	FT-FY23-11042022-003315-B	<1
WS- 003316	8/15/2022	8/15/2023	2	Combo Faucet	In classroom 207		WF-08152022-003316	11/22/2022	FT-FY23-11042022-003316-A	<1	FT-FY23-11042022-003316-B	<1
WS- 003317	4/18/2022	4/18/2023	2	Combo Fountain	In classroom 207		WF-04182022-003317	11/22/2022	FT-FY23-11042022-003317-A	<1	FT-FY23-11042022-003317-B	<1
WS- 003318	8/15/2022	8/15/2023	2	Combo Faucet	In classroom 204		WF-08152022-003318	11/22/2022	FT-FY23-11042022-003318-A	<1	FT-FY23-11042022-003318-B	<1
WS- 003319	4/18/2022	4/18/2023	2	Combo Fountain	In classroom 204		WF-04182022-003319	11/22/2022	FT-FY23-11042022-003319-A	<1	FT-FY23-11042022-003319-B	<1
WS- 003320	8/15/2022	8/15/2023	2	Combo Faucet	In classroom 206		WF-08152022-003320	11/22/2022	FT-FY23-11042022-003320-A	<1	FT-FY23-11042022-003320-B	<1
WS- 003321	4/18/2022	4/18/2023	2	Combo Fountain	In classroom 206		WF-04182022-003321	11/22/2022	FT-FY23-11042022-003321-A	<1	FT-FY23-11042022-003321-B	<1
WS- 003322	8/15/2022	8/15/2023	2	Classroom Faucet	In classroom 210	High	WF-08152022-003322	11/22/2022	FT-FY23-11042022-003322-A	<1	FT-FY23-11042022-003322-B	<1
WS- 003324	4/18/2022	4/18/2023	2	Combo Fountain	In classroom 210		WF-04182022-003324	11/22/2022	FT-FY23-11042022-003324-A	<1	FT-FY23-11042022-003324-B	<1
WS- 003325	8/15/2022	8/15/2023	2	Combo Faucet	In classroom 210	Low	WF-08152022-003325	11/22/2022	FT-FY23-11042022-003325-A	<1	FT-FY23-11042022-003325-B	<1
WS- 003326	8/15/2022	8/15/2023	2	Classroom Faucet	In classroom 212	High	WF-08152022-003326	11/22/2022	FT-FY23-11042022-003326-A	<1	FT-FY23-11042022-003326-B	<1
WS- 003327	4/18/2022	4/18/2023	2	Combo Fountain	In classroom 212		WF-04182022-003327	11/22/2022	FT-FY23-11042022-003327-A	<1	FT-FY23-11042022-003327-B	<1
WS- 003328	8/15/2022	8/15/2023	2	Combo Faucet	In classroom 212	Low	WF-08152022-003328	11/22/2022	FT-FY23-11042022-003328-A	<1	FT-FY23-11042022-003328-B	<1
WS- 003329	4/18/2022	4/18/2023	2	Combo Fountain	In classroom 216		WF-04182022-003329	11/22/2022	FT-FY23-11042022-003329-A	<1	FT-FY23-11042022-003329-B	<1
WS- 003330	8/15/2022	8/15/2023	2	Combo Faucet	In classroom 216		WF-08152022-003330	11/22/2022	FT-FY23-11042022-003330-A	<1	FT-FY23-11042022-003330-B	<1
WS- 003332	4/18/2022	4/18/2023	2	Cooler	In hallway adjacent to stairwell A	High Left	WF-04182022-003332	11/22/2022	FT-FY23-11042022-003332-A	<1	FT-FY23-11042022-003332-B	<1
WS- 003333	4/18/2022	4/18/2023	2	Cooler	In hallway adjacent to stairwell A	Low Right	WF-04182022-003333	11/22/2022	FT-FY23-11042022-003333-A	<1	FT-FY23-11042022-003333-B	<1
WS- 003336	8/15/2022	8/15/2023	2	Combo Faucet	In classroom 217		WF-08152022-003336	11/22/2022	FT-FY23-11042022-003336-A	<1	FT-FY23-11042022-003336-B	<1
WS- 003337	4/18/2022	4/18/2023	2	Combo Fountain	In classroom 217		WF-04182022-003337	11/22/2022	FT-FY23-11042022-003337-A	<1	FT-FY23-11042022-003337-B	<1
WS- 003338	4/18/2022	4/18/2023	2	Classroom Faucet	In Spanish room 215		WF-04182022-003338	11/22/2022	FT-FY23-11042022-003338-A	<1	FT-FY23-11042022-003338-B	<1
WS- 003339	4/18/2022	4/18/2023	2	Combo Fountain	In spanish room 215		WF-04182022-003339	11/22/2022	FT-FY23-11042022-003339-A	<1	FT-FY23-11042022-003339-B	<1
WS- 003340	8/15/2022	8/15/2023	2	Combo Faucet	In classroom 201		WF-08152022-003340	11/22/2022	FT-FY23-11042022-003340-A	<1	FT-FY23-11042022-003340-B	<1
WS- 003341	4/18/2022	4/18/2023	2	Combo Fountain	In classroom 201		WF-04182022-003341	11/22/2022	FT-FY23-11042022-003341-A	<1	FT-FY23-11042022-003341-B	<1
WS- 003342	8/15/2022	8/15/2023	3	Combo Faucet	In classroom 301		WF-08152022-003342	11/22/2022	FT-FY23-11042022-003342-A	<1	FT-FY23-11042022-003342-B	<1
WS- 003343	4/18/2022	4/18/2023	3	Combo Fountain	In classroom 301		WF-04182022-003343	11/22/2022	FT-FY23-11042022-003343-A	<1	FT-FY23-11042022-003343-B	<1
WS- 003344	4/18/2022	4/18/2023	3	Cooler	In hallway adjacent to stairwell B	High Left	WF-04182022-003344	11/22/2022	FT-FY23-11042022-003344-A	<1	FT-FY23-11042022-003344-B	<1
WS- 003345	4/18/2022	4/18/2023	3	Cooler	In hallway adjacent to stairwell B	Low Right	WF-04182022-003345	11/22/2022	FT-FY23-11042022-003345-A	<1	FT-FY23-11042022-003345-B	<1
WS- 003346	8/15/2022	8/15/2023	3	Combo Faucet	In classroom 304		WF-08152022-003346	11/22/2022	FT-FY23-11042022-003346-A	<1	FT-FY23-11042022-003346-B	<1
WS- 003347	4/18/2022	4/18/2023	3	Combo Fountain	In classroom 304		WF-04182022-003347	11/22/2022	FT-FY23-11042022-003347-A	<1	FT-FY23-11042022-003347-B	<1
WS- 003348	8/15/2022	8/15/2023	3	Combo Faucet	In classroom 314		WF-08152022-003348	11/22/2022	FT-FY23-11042022-003348-A	<1	FT-FY23-11042022-003348-B	<1
WS- 003349	4/18/2022	4/18/2023	3	Combo Fountain	In classroom 314		WF-04182022-003349	11/22/2022	FT-FY23-11042022-003349-A	<1	FT-FY23-11042022-003349-B	<1
WS- 003350	8/15/2022	8/15/2023	3	Combo Faucet	In classroom 325		WF-08152022-003350	11/22/2022	FT-FY23-11042022-003350-A	<1	FT-FY23-11042022-003350-B	<1
WS- 003351	4/18/2022	4/18/2023	3	Combo Fountain	In classroom 325		WF-04182022-003351	11/22/2022	FT-FY23-11042022-003351-A	<1	FT-FY23-11042022-003351-B	<1

WS- 003352	8/15/2022	8/15/2023	3	Combo Faucet	In classroom 323		WF-08152022-003352	11/22/2022	FT-FY23-11042022-003352-A	<1	FT-FY23-11042022-003352-B	<1
WS- 003353	4/18/2022	4/18/2023	3	Combo Fountain	In classroom 323		WF-04182022-003353	11/22/2022	FT-FY23-11042022-003353-A	<1	FT-FY23-11042022-003353-B	<1
WS- 003354	4/18/2022	4/18/2023	3	Cooler	In hallway adjacent to stairwell A	High Left	WF-04182022-003354	11/22/2022	FT-FY23-11042022-003354-A	<1	FT-FY23-11042022-003354-B	<1
WS- 003355	4/18/2022	4/18/2023	3	Cooler	In hallway adjacent to stairwell A	Low Right	WF-04182022-003355	11/22/2022	FT-FY23-11042022-003355-A	<1	FT-FY23-11042022-003355-B	<1
WS- 003356	8/15/2022	8/15/2023	3	Combo Faucet	In classroom 321		WF-08152022-003356	11/22/2022	FT-FY23-11042022-003356-A	<1	FT-FY23-11042022-003356-B	<1
WS- 003357	4/18/2022	4/18/2023	3	Combo Fountain	In classroom 321		WF-04182022-003357	11/22/2022	FT-FY23-11042022-003357-A	<1	FT-FY23-11042022-003357-B	<1
WS- 003358	4/18/2022	4/18/2023	3	Break Room	In breakroom 317		WF-04182022-003358	11/22/2022	FT-FY23-11042022-003358-A	<1	FT-FY23-11042022-003358-B	<1
WS- 003359	4/18/2022	4/18/2023	3	Combo Fountain	In break room 317		WF-04182022-003359	11/22/2022	FT-FY23-11042022-003359-A	<1	FT-FY23-11042022-003359-B	<1
WS- 003360	8/15/2022	8/15/2023	3	Combo Faucet	In classroom 307		WF-08152022-003360	11/22/2022	FT-FY23-11042022-003360-A	<1	FT-FY23-11042022-003360-B	<1
WS- 003361	4/18/2022	4/18/2023	3	Combo Fountain	In classroom 307		WF-04182022-003361	11/22/2022	FT-FY23-11042022-003361-A	<1	FT-FY23-11042022-003361-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003307	2/9/2022	2/9/2023	1	Food Prep Sink	In kitchen on east wall	Right	WF-02092022-003307	11/22/2022	FT-FY23-11042022-003307-A	<1	FT-FY23-11042022-003307-B	<1