



LUDLOW-TAYLOR ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 001392	8/20/2016	3	Fountain	In classroom 306	FT-82016-001392-A	< 1	FT-82016-001392-B	< 1
2	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003273	8/20/2016	1	Fountain	In classroom 105	FT-82016-003273-A	< 1	FT-82016-003273-B	< 1
3	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003275	8/20/2016	1	Cooler	In hallway adjacent to stairwell B High Left	FT-82016-003275-A	< 1	FT-82016-003275-B	< 1
4	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003276	8/20/2016	1	Cooler	In hallway adjacent to stairwell B Low Right	FT-82016-003276-A	< 1	FT-82016-003276-B	< 1
5	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003279	8/20/2016	1	Fountain	In classroom 101	FT-82016-003279-A	< 1	FT-82016-003279-B	< 1
6	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003281	8/20/2016	1	Fountain	In classroom 100	FT-82016-003281-A	< 1	FT-82016-003281-B	< 1
7	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003284	8/20/2016	1	Fountain	In classroom 102	FT-82016-003284-A	< 1	FT-82016-003284-B	< 1
8	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003288	8/20/2016	1	Fountain	In classroom 104	FT-82016-003288-A	< 1	FT-82016-003288-B	< 1
9	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003290	8/20/2016	1	Fountain	In classroom 106	FT-82016-003290-A	< 1	FT-82016-003290-B	< 1
10	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003293	8/20/2016	1	Fountain	In classroom 108	FT-82016-003293-A	< 1	FT-82016-003293-B	< 1
11	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003295	8/20/2016	1	Cooler	In hallway adjacent to stairwell A High Left	FT-82016-003295-A	< 1	FT-82016-003295-B	< 1
12	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003296	8/20/2016	1	Cooler	In hallway adjacent to stairwell A Low Right	FT-82016-003296-A	< 1	FT-82016-003296-B	< 1
13	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003298	8/20/2016	1	Fountain	In parents' waiting room	FT-82016-003298-A	< 1	FT-82016-003298-B	< 1
14	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003300	8/20/2016	1	Fountain	In classroom 117	FT-82016-003300-A	< 1	FT-82016-003300-B	< 1
15	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003302	8/20/2016	1	Health Suite	In health suite	FT-82016-003302-A	< 1	FT-82016-003302-B	< 1
16	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003303	8/20/2016	1	Fountain	In health suite	FT-82016-003303-A	< 1	FT-82016-003303-B	< 1
17	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003304	8/20/2016	1	Cooler	In hallway adjacent to janitor closet	FT-82016-003304-A	< 1	FT-82016-003304-B	< 1
18	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003305	8/20/2016	1	Cooler	In cafeteria	FT-82016-003305-A	< 1	FT-82016-003305-B	< 1
19	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003307	8/20/2016	1	Food Prep Sink	In kitchen on east wall Right	FT-82016-003307-A	< 1	FT-82016-003307-B	< 1
20	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003310	8/20/2016	2	Cooler	In hallway adjacent to stairwell B High Left	FT-82016-003310-A	< 1	FT-82016-003310-B	< 1
21	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003311	8/20/2016	2	Cooler	In hallway adjacent to stairwell B Low Right	FT-82016-003311-A	< 1	FT-82016-003311-B	< 1
22	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003312	8/20/2016	2	Fountain	In classroom 200 Left	FT-82016-003312-A	< 1	FT-82016-003312-B	< 1
23	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003315	8/20/2016	2	Fountain	In classroom 200 Right	FT-82016-003315-A	< 1	FT-82016-003315-B	< 1
24	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003317	8/20/2016	2	Fountain	In classroom 207	FT-82016-003317-A	< 1	FT-82016-003317-B	< 1
25	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003319	8/20/2016	2	Fountain	In classroom 204	FT-82016-003319-A	< 1	FT-82016-003319-B	< 1
26	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003321	8/20/2016	2	Fountain	In classroom 206	FT-82016-003321-A	< 1	FT-82016-003321-B	< 1
27	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003324	8/20/2016	2	Fountain	In classroom 210	FT-82016-003324-A	< 1	FT-82016-003324-B	< 1
28	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003327	8/20/2016	2	Fountain	In classroom 212	FT-82016-003327-A	< 1	FT-82016-003327-B	< 1
29	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003329	8/20/2016	2	Fountain	In classroom 216	FT-82016-003329-A	< 1	FT-82016-003329-B	< 1
30	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003332	8/20/2016	2	Fountain	In hallway adjacent to room 219 High Left	FT-82016-003332-A	< 1	FT-82016-003332-B	< 1
31	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003333	8/20/2016	2	Fountain	In hallway adjacent to room 219 Low Right	FT-82016-003333-A	< 1	FT-82016-003333-B	< 1
32	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003335	8/20/2016	2	Fountain	In classroom 223	FT-82016-003335-A	< 1	FT-82016-003335-B	< 1
33	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003337	8/20/2016	2	Fountain	In classroom 217	FT-82016-003337-A	< 1	FT-82016-003337-B	< 1
34	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003339	8/20/2016	2	Fountain	In break room	FT-82016-003339-A	< 1	FT-82016-003339-B	< 1
35	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003341	8/20/2016	2	Fountain	In classroom 201	FT-82016-003341-A	< 1	FT-82016-003341-B	< 1
36	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003343	8/20/2016	3	Fountain	In classroom 301	FT-82016-003343-A	< 1	FT-82016-003343-B	< 1
37	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003344	8/20/2016	3	Cooler	In hallway adjacent to stairwell B High Left	FT-82016-003344-A	< 1	FT-82016-003344-B	< 1
38	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003345	8/20/2016	3	Cooler	In hallway adjacent to stairwell B Low Right	FT-82016-003345-A	< 1	FT-82016-003345-B	< 1
39	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003347	8/20/2016	3	Fountain	In classroom 304	FT-82016-003347-A	< 1	FT-82016-003347-B	< 1
40	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003349	8/20/2016	3	Fountain	In classroom 314	FT-82016-003349-A	< 1	FT-82016-003349-B	< 1
41	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003351	8/20/2016	3	Fountain	In classroom 325	FT-82016-003351-A	< 1	FT-82016-003351-B	< 1
42	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003353	8/20/2016	3	Fountain	In classroom 323	FT-82016-003353-A	< 1	FT-82016-003353-B	< 1
43	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003354	8/20/2016	3	Cooler	In hallway adjacent to stairwell A High Left	FT-82016-003354-A	< 1	FT-82016-003354-B	< 1
44	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003355	8/20/2016	3	Cooler	In hallway adjacent to stairwell A Low Right	FT-82016-003355-A	< 1	FT-82016-003355-B	< 1
45	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003357	8/20/2016	3	Fountain	In classroom 321	FT-82016-003357-A	< 1	FT-82016-003357-B	< 1
46	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003359	8/20/2016	3	Fountain	In break room 317	FT-82016-003359-A	< 1	FT-82016-003359-B	< 1
47	LUDLOW-TAYLOR ELEMENTARY SCHOOL	WS- 003361	8/20/2016	3	Fountain	In classroom 307	FT-82016-003361-A	< 1	FT-82016-003361-B	< 1