



LUDLOW TAYLOR LEAD WATER TEST RESULTS

May 15, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003361	Fountain	3	In room 307	WT-042916-3378- A	2.9	WT-042916-3378- B	< 1				
2	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003360	Classroom	3	In room 307	WT-042916-3377- A	2.5	WT-042916-3377- B	< 1				
3	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003359	Fountain	3	In break room	WT-042916-3376- A	1	WT-042916-3376- B	< 1				
4	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003358	Break Room	3	In room 317	WT-042916-3375- A	< 1	WT-042916-3375- B	< 1				
5	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003357	Fountain	3	In room 321	WT-042916-3374- A	< 1	WT-042916-3374- B	< 1				
6	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003356	Classroom	3	In room 321	WT-042916-3373- A	< 1	WT-042916-3373- B	< 1				
7	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003355	Cooler	3	Adjacent to stairwell A	WT-042916-3372- A	< 1	WT-042916-3372- B	< 1				
8	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003354	Cooler	3	Adjacent to stairwell A	WT-042916-3371- A	< 1	WT-042916-3371- B	< 1				
9	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003353	Fountain	3	In room 323	WT-042916-3370- A	< 1	WT-042916-3370- B	< 1				
10	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003352	Classroom	3	In room 323	WT-042916-3369- A	< 1	WT-042916-3369- B	< 1				
11	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003351	Classroom	3	In room 325	WT-042916-3368- A	< 1	WT-042916-3368- B	< 1				
12	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003350	Classroom	3	In room 325	WT-042916-3367- A	2	WT-042916-3367- B	< 1				
13	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003349	Fountain	3	In room 314	WT-042916-3366- A	< 1	WT-042916-3366- B	< 1				
14	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003348	Classroom	3	In room 314	WT-042916-3365- A	< 1	WT-042916-3365- B	< 1				
15	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003347	Fountain	3	In room 304	WT-042916-3364- A	< 1	WT-042916-3364- B	< 1				
16	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003346	Classroom	3	In classroom 304	WT-042916-3363- A	< 1	WT-042916-3363- B	< 1				
17	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003345	Cooler	3	Adjacent to stairwell B	WT-042916-3362- A	< 1	WT-042916-3362- B	< 1				
18	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003344	Cooler	3	Adjacent to stairwell B	WT-042916-3361- A	< 1	WT-042916-3361- B	< 1				
19	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003343	Fountain	3	I'm room 301	WT-042916-3360- A	< 1	WT-042916-3360- B	< 1				
20	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003342	Classroom	3	In room 301	WT-042916-3359- A	2.2	WT-042916-3359- B	< 1				
21	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003341	Fountain	2	In room 201	WT-042916-3358- A	< 1	WT-042916-3358- B	< 1				
22	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003340	Classroom	2	In room 201	WT-042916-3357- A	2.4	WT-042916-3357- B	< 1				
23	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003339	Fountain	2	Break room	WT-042916-3356- A	1.9	WT-042916-3356- B	< 1				
24	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003338	Break Room	2	Sink in break room	WT-042916-3355- A	< 1	WT-042916-3355- B	< 1				
25	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003337	Fountain	2	In room 217	WT-042916-3354- A	< 1	WT-042916-3354- B	< 1				
26	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003336	Classroom	2	In room 217	WT-042916-3353- A	< 1	WT-042916-3353- B	1.3				
27	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003335	Fountain	2	In room 223	WT-042916-3352- A	< 1	WT-042916-3352- B	< 1				
28	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003334	Classroom	2	In room 223	WT-042916-3351- A	< 1	WT-042916-3351- B	< 1				
29	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003333	Fountain	2	In hallway adjacent to room 219	WT-042916-3350- A	< 1	WT-042916-3350- B	< 1				
30	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003332	Fountain	2	In hallway adjacent room 219	WT-042916-3349- A	< 1	WT-042916-3349- B	< 1				
31	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003330	Classroom	2	In room 216	WT-042916-3347- A	< 1	WT-042916-3347- B	< 1				
32	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003329	Fountain	2	In room 216	WT-042916-3346- A	< 1	WT-042916-3346- B	< 1				
33	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003328	Classroom	2	In room 212	WT-042916-3345- A	< 1	WT-042916-3345- B	< 1				
34	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003327	Fountain	2	In room 212	WT-042916-3344- A	< 1	WT-042916-3344- B	< 1				
35	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003326	Classroom	2	In room 212	WT-042916-3343- A	< 1	WT-042916-3343- B	< 1				
36	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003325	Classroom	2	In room 210	WT-042916-3342- A	4.2	WT-042916-3342- B	< 1				
37	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003324	Fountain	2	In room 210	WT-042916-3341- A	< 1	WT-042916-3341- B	< 1				
38	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003322	Classroom	2	In room 210	WT-042916-3339- A	< 1	WT-042916-3339- B	< 1				
39	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003321	Fountain	2	In room 206	WT-042916-3338- A	< 1	WT-042916-3338- B	< 1				
40	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003320	Classroom	2	In room 206	WT-042916-3337- A	1.9	WT-042916-3337- B	< 1				
41	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003319	Fountain	2	In room 204	WT-042916-3336- A	1	WT-042916-3336- B	< 1				
42	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003318	Classroom	2	In room 204	WT-042916-3335- A	< 1	WT-042916-3335- B	< 1				
43	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003317	Fountain	2	In room 207	WT-042916-3334- A	< 1	WT-042916-3334- B	< 1				
44	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003316	Classroom	2	In room 207	WT-042916-3333- A	< 1	WT-042916-3333- B	1.1				
45	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003315	Fountain	2	In room 200	WT-042916-3332- A	< 1	WT-042916-3332- B	1.7				
46	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003314	Classroom	2	In room 200	WT-042916-3331- A	3.4	WT-042916-3331- B	< 1				
47	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003313	Classroom	2	In room 200	WT-042916-3330- A	9.4	WT-042916-3330- B	< 1				
48	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003312	Fountain	2	In room 200	WT-042916-3329- A	1.2	WT-042916-3329- B	< 1				
49	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003311	Cooler	2	Adjacent to stairwell B	WT-042916-3328- A	< 1	WT-042916-3328- B	< 1				
50	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003310	Cooler	2	Adjacent to stairwell B	WT-042916-3327- A	< 1	WT-042916-3327- B	< 1				
51	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003309	Kitchen	1	In west wall	WT-042916-3326- A	< 1	WT-042916-3326- B	< 1				
52	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003308	Kitchen	1	In west wall	WT-042916-3325- A	202	WT-042916-3325- B	21.4	Filter will be installed and then retested			
53	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003307	Kitchen	1	Sink on east wall	WT-042916-3324- A	< 1	WT-042916-3324- B	< 1				
54	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003306	Kitchen	1	Sink on east wall	WT-042916-3323- A	4.8	WT-042916-3323- B	< 1				
55	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003305	Cooler	1	In cafeteria	WT-042916-3322- A	1.1	WT-042916-3322- B	< 1				
56	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003304	Cooler	1	Adjacent to janitor closet	WT-042916-3321- A	< 1	WT-042916-3321- B	< 1				
57	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003303	Fountain	1	In health suite	WT-042916-3320- A	1	WT-042916-3320- B	< 1				



LUDLOW TAYLOR LEAD WATER TEST RESULTS

May 15, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
58	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003302	Classroom	1	In health suite	WT-042916-3319- A	< 1	WT-042916-3319- B	< 1				
59	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003301	Classroom	1	In room 117	WT-042916-3318- A	< 1	WT-042916-3318- B	< 1				
60	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003300	Classroom	1	In room 117	High WT-042916-3317- A	< 1	WT-042916-3317- B	< 1				
61	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003299	Classroom	1	In room 117	Left Low WT-042916-3316- A	< 1	WT-042916-3316- B	< 1				
62	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003298	Fountain	1	In parents waiting room	WT-042916-3315- A	< 1	WT-042916-3315- B	< 1				
63	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003297	Break Room	1	In parents waiting room	WT-042916-3314- A	< 1	WT-042916-3314- B	< 1				
64	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003296	Cooler	1	Adjacent to stairwell A	Right Low WT-042916-3313- A	< 1	WT-042916-3313- B	< 1				
65	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003295	Cooler	1	Adjacent to stairwell A	Left High WT-042916-3312- A	< 1	WT-042916-3312- B	< 1				
66	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003294	Classroom	1	In room 108	WT-042916-3311- A	< 1	WT-042916-3311- B	< 1				
67	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003293	Fountain	1	In room 108	WT-042916-3310- A	< 1	WT-042916-3310- B	< 1				
68	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003292	Classroom	1	In room 108	High WT-042916-3309- A	< 1	WT-042916-3309- B	< 1				
69	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003291	Classroom	1	In room 106	Low WT-042916-3308- A	< 1	WT-042916-3308- B	< 1				
70	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003290	Fountain	1	In room 106	WT-042916-3307- A	< 1	WT-042916-3307- B	< 1				
71	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003289	Classroom	1	In room 106	High WT-042916-3306- A	< 1	WT-042916-3306- B	< 1				
72	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003288	Fountain	1	In room 104	WT-042916-3305- A	< 1	WT-042916-3305- B	< 1				
73	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003287	Classroom	1	In room 104	Low WT-042916-3304- A	< 1	WT-042916-3304- B	< 1				
74	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003286	Classroom	1	In room 104	High WT-042916-3303- A	< 1	WT-042916-3303- B	< 1				
75	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003285	Classroom	1	In room 102	Low WT-042916-3302- A	< 1	WT-042916-3302- B	< 1				
76	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003284	Fountain	1	In room 102	WT-042916-3301- A	< 1	WT-042916-3301- B	< 1				
77	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003283	Classroom	1	In room 102	High WT-042916-3300- A	< 1	WT-042916-3300- B	< 1				
78	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003282	Classroom	1	In room 100	Left Low WT-042916-3299- A	< 1	WT-042916-3299- B	< 1				
79	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003281	Fountain	1	In room 100	WT-042916-3298- A	< 1	WT-042916-3298- B	< 1				
80	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003280	Classroom	1	In room 100	High WT-042916-3297- A	< 1	WT-042916-3297- B	< 1				
81	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003279	Fountain	1	In room 101	WT-042916-3296- A	< 1	WT-042916-3296- B	< 1				
82	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003278	Classroom	1	In room 101	Right Low WT-042916-3295- A	< 1	WT-042916-3295- B	< 1				
83	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003277	Classroom	1	In room 101	Left High WT-042916-3294- A	< 1	WT-042916-3294- B	< 1				
84	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003276	Cooler	1	Adjacent to stairwell B	Right Low WT-042916-3293- A	< 1	WT-042916-3293- B	< 1				
85	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003275	Cooler	1	Adjacent to stairwell B	Left High WT-042916-3292- A	< 1	WT-042916-3292- B	< 1				
86	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003274	Classroom	1	In room 105	WT-042916-3291- A	< 1	WT-042916-3291- B	< 1				
87	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003273	Fountain	1	In room 105	Right Low WT-042916-3290- A	< 1	WT-042916-3290- B	< 1				
88	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003272	Classroom	1	In room 105	Left High WT-042916-3289- A	< 1	WT-042916-3289- B	< 1				
89	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 003271	Utility	1	In Boiler room	WT-042916-3288- A	< 1	WT-042916-3288- B	< 1				
90	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 001392	Fountain	3	In room 306	WT-042916-1409- A	< 1	WT-042916-1409- B	< 1				
91	LUDLOW-TAYLOR ELEMENTARY SCHOOL	5/4/2016	WS- 001391	Classroom	3	In room 306	WT-042916-1408- A	< 1	WT-042916-1408- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.