



Ludlow Taylor ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001391	9/18/2018	9/18/2019	3	Combo Faucet	In classroom 306	WF-09182018-001391	12/10/2018	FT-FY19-112018-001391-A	<1	FT-FY19-112018-001391-B	<1
WS- 001392	6/11/2018	6/11/2019	3	Combo Fountain	In classroom 306	WF-06112018-001392	12/10/2018	FT-FY19-112018-001392-A	<1	FT-FY19-112018-001392-B	<1
WS- 003272	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 105 High Left	WF-09182018-003272	12/10/2018	FT-FY19-112018-003272-A	1.7	FT-FY19-112018-003272-B	<1
WS- 003273	6/11/2018	6/11/2019	1	Combo Fountain	In classroom 105	WF-06112018-003273	12/10/2018	FT-FY19-112018-003273-A	<1	FT-FY19-112018-003273-B	<1
WS- 003274	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 105 Low Right	WF-09182018-003274	12/10/2018	FT-FY19-112018-003274-A	<1	FT-FY19-112018-003274-B	<1
WS- 003275	6/11/2018	6/11/2019	1	Cooler	In hallway adjacent to stairwell B High Left	WF-06112018-003275	12/10/2018	FT-FY19-112018-003275-A	<1	FT-FY19-112018-003275-B	<1
WS- 003276	6/11/2018	6/11/2019	1	Cooler	In hallway adjacent to stairwell B Low Right	WF-06112018-003276	12/10/2018	FT-FY19-112018-003276-A	<1	FT-FY19-112018-003276-B	<1
WS- 003277	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 101 High Left	WF-09182018-003277	12/10/2018	FT-FY19-112018-003277-A	2.1	FT-FY19-112018-003277-B	<1
WS- 003278	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 101 Low Right	WF-09182018-003278	12/10/2018	FT-FY19-112018-003278-A	<1	FT-FY19-112018-003278-B	<1
WS- 003279	6/11/2018	6/11/2019	1	Combo Fountain	In classroom 101	WF-06112018-003279	12/10/2018	FT-FY19-112018-003279-A	<1	FT-FY19-112018-003279-B	<1
WS- 003280	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 100 High Right	WF-09182018-003280	12/10/2018	FT-FY19-112018-003280-A	<1	FT-FY19-112018-003280-B	<1
WS- 003281	6/11/2018	6/11/2019	1	Combo Fountain	In classroom 100	WF-06112018-003281	12/10/2018	FT-FY19-112018-003281-A	<1	FT-FY19-112018-003281-B	<1
WS- 003282	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 100 Low Left	WF-09182018-003282	12/10/2018	FT-FY19-112018-003282-A	<1	FT-FY19-112018-003282-B	<1
WS- 003283	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 102 High Right	WF-09182018-003283	12/10/2018	FT-FY19-112018-003283-A	<1	FT-FY19-112018-003283-B	<1
WS- 003284	6/11/2018	6/11/2019	1	Combo Fountain	In classroom 102	WF-06112018-003284	12/10/2018	FT-FY19-112018-003284-A	<1	FT-FY19-112018-003284-B	<1
WS- 003285	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 102 Low Left	WF-09182018-003285	12/10/2018	FT-FY19-112018-003285-A	<1	FT-FY19-112018-003285-B	<1
WS- 003286	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 104 High	WF-09182018-003286	12/10/2018	FT-FY19-112018-003286-A	<1	FT-FY19-112018-003286-B	<1
WS- 003287	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 104 Low	WF-09182018-003287	12/10/2018	FT-FY19-112018-003287-A	<1	FT-FY19-112018-003287-B	<1
WS- 003288	6/11/2018	6/11/2019	1	Combo Fountain	In classroom 104	WF-06112018-003288	12/10/2018	FT-FY19-112018-003288-A	<1	FT-FY19-112018-003288-B	<1
WS- 003289	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 106 High	WF-09182018-003289	12/10/2018	FT-FY19-112018-003289-A	<1	FT-FY19-112018-003289-B	<1
WS- 003290	6/11/2018	6/11/2019	1	Combo Fountain	In classroom 106	WF-06112018-003290	12/10/2018	FT-FY19-112018-003290-A	<1	FT-FY19-112018-003290-B	<1
WS- 003291	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 106 Low	WF-09182018-003291	12/10/2018	FT-FY19-112018-003291-A	<1	FT-FY19-112018-003291-B	<1
WS- 003292	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 108 High	WF-09182018-003292	12/10/2018	FT-FY19-112018-003292-A	<1	FT-FY19-112018-003292-B	<1
WS- 003293	6/11/2018	6/11/2019	1	Combo Fountain	In bathroom in room 108	WF-06112018-003293	12/10/2018	FT-FY19-112018-003293-A	<1	FT-FY19-112018-003293-B	<1
WS- 003294	9/18/2018	9/18/2019	1	Combo Faucet	In bathroom in room 108 Low	WF-09182018-003294	12/10/2018	FT-FY19-112018-003294-A	<1	FT-FY19-112018-003294-B	<1
WS- 003295	6/11/2018	6/11/2019	1	Cooler	In hallway adjacent to stairwell A High Left	WF-06112018-003295	12/10/2018	FT-FY19-112018-003295-A	<1	FT-FY19-112018-003295-B	<1
WS- 003296	6/11/2018	6/11/2019	1	Cooler	In hallway adjacent to stairwell A Low Right	WF-06112018-003296	12/10/2018	FT-FY19-112018-003296-A	<1	FT-FY19-112018-003296-B	<1
WS- 003297	9/18/2018	9/18/2019	1	Combo Faucet	In parents' waiting room	WF-09182018-003297	12/10/2018	FT-FY19-112018-003297-A	<1	FT-FY19-112018-003297-B	<1
WS- 003298	6/11/2018	6/11/2019	1	Combo Fountain	In parents' waiting room	WF-06112018-003298	12/10/2018	FT-FY19-112018-003298-A	<1	FT-FY19-112018-003298-B	<1
WS- 003299	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 117 Low Left	WF-09182018-003299	12/10/2018	FT-FY19-112018-003299-A	<1	FT-FY19-112018-003299-B	<1
WS- 003300	6/11/2018	6/11/2019	1	Combo Fountain	In classroom 117	WF-06112018-003300	12/10/2018	FT-FY19-112018-003300-A	<1	FT-FY19-112018-003300-B	<1
WS- 003301	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 117 High Right	WF-09182018-003301	12/10/2018	FT-FY19-112018-003301-A	<1	FT-FY19-112018-003301-B	<1
WS- 003302	6/11/2018	6/11/2019	1	Health Suite	In health suite	WF-06112018-003302	12/10/2018	FT-FY19-112018-003302-A	<1	FT-FY19-112018-003302-B	<1

WS-003303	6/11/2018	6/11/2019	1	Combo Fountain	In health suite		WF-06112018-003303	12/10/2018	FT-FY19-112018-003303-A	<1	FT-FY19-112018-003303-B	<1
WS-003304	6/11/2018	6/11/2019	1	Cooler	In hallway adjacent to janitor closet		WF-06112018-003304	12/10/2018	FT-FY19-112018-003304-A	<1	FT-FY19-112018-003304-B	<1
WS-003305	6/11/2018	6/11/2019	1	Cooler	In cafeteria		WF-06112018-003305	12/10/2018	FT-FY19-112018-003305-A	<1	FT-FY19-112018-003305-B	<1
WS-003310	6/11/2018	6/11/2019	2	Cooler	In hallway adjacent to stairwell B	High Left	WF-06112018-003310	12/10/2018	FT-FY19-112018-003310-A	<1	FT-FY19-112018-003310-B	<1
WS-003311	6/11/2018	6/11/2019	2	Cooler	In hallway adjacent to stairwell B	Low Right	WF-06112018-003311	12/10/2018	FT-FY19-112018-003311-A	<1	FT-FY19-112018-003311-B	<1
WS-003312	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 200	Left	WF-06112018-003312	12/10/2018	FT-FY19-112018-003312-A	<1	FT-FY19-112018-003312-B	<1
WS-003313	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 200	Left	WF-09182018-003313	12/10/2018	FT-FY19-112018-003313-A	1.1	FT-FY19-112018-003313-B	<1
WS-003314	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 200	Right	WF-09182018-003314	12/10/2018	FT-FY19-112018-003314-A	<1	FT-FY19-112018-003314-B	<1
WS-003315	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 200	Right	WF-06112018-003315	12/10/2018	FT-FY19-112018-003315-A	1	FT-FY19-112018-003315-B	<1
WS-003316	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 207		WF-09182018-003316	12/10/2018	FT-FY19-112018-003316-A	<1	FT-FY19-112018-003316-B	<1
WS-003317	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 207		WF-06112018-003317	12/10/2018	FT-FY19-112018-003317-A	<1	FT-FY19-112018-003317-B	<1
WS-003318	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 204		WF-09182018-003318	12/10/2018	FT-FY19-112018-003318-A	<1	FT-FY19-112018-003318-B	<1
WS-003319	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 204		WF-06112018-003319	12/10/2018	FT-FY19-112018-003319-A	<1	FT-FY19-112018-003319-B	<1
WS-003320	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 206		WF-09182018-003320	12/10/2018	FT-FY19-112018-003320-A	<1	FT-FY19-112018-003320-B	<1
WS-003321	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 206		WF-06112018-003321	12/10/2018	FT-FY19-112018-003321-A	<1	FT-FY19-112018-003321-B	<1
WS-003322	9/18/2018	9/18/2019	2	Classroom Faucet	In classroom 210	High	WF-09182018-003322	12/10/2018	FT-FY19-112018-003322-A	1.1	FT-FY19-112018-003322-B	<1
WS-003324	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 210		WF-06112018-003324	12/10/2018	FT-FY19-112018-003324-A	<1	FT-FY19-112018-003324-B	<1
WS-003325	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 210	Low	WF-09182018-003325	12/10/2018	FT-FY19-112018-003325-A	<1	FT-FY19-112018-003325-B	<1
WS-003326	9/18/2018	9/18/2019	2	Classroom Faucet	In classroom 212	High	WF-09182018-003326	12/10/2018	FT-FY19-112018-003326-A	<1	FT-FY19-112018-003326-B	<1
WS-003327	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 212		WF-06112018-003327	12/10/2018	FT-FY19-112018-003327-A	<1	FT-FY19-112018-003327-B	<1
WS-003328	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 212	Low	WF-09182018-003328	12/10/2018	FT-FY19-112018-003328-A	<1	FT-FY19-112018-003328-B	<1
WS-003329	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 216		WF-06112018-003329	12/10/2018	FT-FY19-112018-003329-A	<1	FT-FY19-112018-003329-B	<1
WS-003330	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 216		WF-09182018-003330	12/10/2018	FT-FY19-112018-003330-A	<1	FT-FY19-112018-003330-B	<1
WS-003332	6/11/2018	6/11/2019	2	Cooler	In hallway adjacent to stairwell A	High Left	WF-06112018-003332	12/10/2018	FT-FY19-112018-003332-A	<1	FT-FY19-112018-003332-B	<1
WS-003333	6/11/2018	6/11/2019	2	Cooler	In hallway adjacent to stairwell A	Low Right	WF-06112018-003333	12/10/2018	FT-FY19-112018-003333-A	<1	FT-FY19-112018-003333-B	<1
WS-003334	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 223		WF-09182018-003334	12/10/2018	FT-FY19-112018-003334-A	1.6	FT-FY19-112018-003334-B	<1
WS-003335	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 223		WF-06112018-003335	12/10/2018	FT-FY19-112018-003335-A	<1	FT-FY19-112018-003335-B	<1
WS-003336	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 217		WF-09182018-003336	12/10/2018	FT-FY19-112018-003336-A	<1	FT-FY19-112018-003336-B	<1
WS-003337	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 217		WF-06112018-003337	12/10/2018	FT-FY19-112018-003337-A	<1	FT-FY19-112018-003337-B	<1
WS-003338	6/11/2018	6/11/2019	2	Classroom Faucet	In Spanish room 215		WF-06112018-003338	12/10/2018	FT-FY19-112018-003338-A	<1	FT-FY19-112018-003338-B	<1
WS-003339	6/11/2018	6/11/2019	2	Combo Fountain	In spanish room 215		WF-06112018-003339	12/10/2018	FT-FY19-112018-003339-A	<1	FT-FY19-112018-003339-B	<1
WS-003340	9/18/2018	9/18/2019	2	Combo Faucet	In classroom 201		WF-09182018-003340	12/10/2018	FT-FY19-112018-003340-A	<1	FT-FY19-112018-003340-B	<1
WS-003341	6/11/2018	6/11/2019	2	Combo Fountain	In classroom 201		WF-06112018-003341	12/10/2018	FT-FY19-112018-003341-A	<1	FT-FY19-112018-003341-B	<1
WS-003342	9/18/2018	9/18/2019	3	Combo Faucet	In classroom 301		WF-09182018-003342	12/10/2018	FT-FY19-112018-003342-A	<1	FT-FY19-112018-003342-B	<1
WS-003343	6/11/2018	6/11/2019	3	Combo Fountain	In classroom 301		WF-06112018-003343	12/10/2018	FT-FY19-112018-003343-A	<1	FT-FY19-112018-003343-B	<1
WS-003344	6/11/2018	6/11/2019	3	Cooler	In hallway adjacent to stairwell B	High Left	WF-06112018-003344	12/10/2018	FT-FY19-112018-003344-A	<1	FT-FY19-112018-003344-B	<1
WS-003345	6/11/2018	6/11/2019	3	Cooler	In hallway adjacent to stairwell B	Low Right	WF-06112018-003345	12/10/2018	FT-FY19-112018-003345-A	<1	FT-FY19-112018-003345-B	<1
WS-003346	9/18/2018	9/18/2019	3	Combo Faucet	In classroom 304		WF-09182018-003346	12/10/2018	FT-FY19-112018-003346-A	<1	FT-FY19-112018-003346-B	<1
WS-003347	6/11/2018	6/11/2019	3	Combo Fountain	In classroom 304		WF-06112018-003347	12/10/2018	FT-FY19-112018-003347-A	<1	FT-FY19-112018-003347-B	<1

WS- 003348	9/18/2018	9/18/2019	3	Combo Faucet	In classroom 314	WF-09182018-003348	12/10/2018	FT-FY19-112018-003348-A	<1	FT-FY19-112018-003348-B	<1	
WS- 003349	6/11/2018	6/11/2019	3	Combo Fountain	In classroom 314	WF-06112018-003349	12/10/2018	FT-FY19-112018-003349-A	<1	FT-FY19-112018-003349-B	<1	
WS- 003350	9/18/2018	9/18/2019	3	Combo Faucet	In classroom 325	WF-09182018-003350	12/10/2018	FT-FY19-112018-003350-A	<1	FT-FY19-112018-003350-B	<1	
WS- 003351	6/11/2018	6/11/2019	3	Combo Fountain	In classroom 325	WF-06112018-003351	12/10/2018	FT-FY19-112018-003351-A	<1	FT-FY19-112018-003351-B	<1	
WS- 003352	9/18/2018	9/18/2019	3	Combo Faucet	In classroom 323	WF-09182018-003352	12/10/2018	FT-FY19-112018-003352-A	<1	FT-FY19-112018-003352-B	<1	
WS- 003353	6/11/2018	6/11/2019	3	Combo Fountain	In classroom 323	WF-06112018-003353	12/10/2018	FT-FY19-112018-003353-A	<1	FT-FY19-112018-003353-B	<1	
WS- 003354	6/11/2018	6/11/2019	3	Cooler	In hallway adjacent to stairwell A	High Left	WF-06112018-003354	12/10/2018	FT-FY19-112018-003354-A	<1	FT-FY19-112018-003354-B	<1
WS- 003355	6/11/2018	6/11/2019	3	Cooler	In hallway adjacent to stairwell A	Low Right	WF-06112018-003355	12/10/2018	FT-FY19-112018-003355-A	<1	FT-FY19-112018-003355-B	<1
WS- 003356	9/18/2018	9/18/2019	3	Combo Faucet	In classroom 321	WF-09182018-003356	12/10/2018	FT-FY19-112018-003356-A	<1	FT-FY19-112018-003356-B	<1	
WS- 003357	6/11/2018	6/11/2019	3	Combo Fountain	In classroom 321	WF-06112018-003357	12/10/2018	FT-FY19-112018-003357-A	<1	FT-FY19-112018-003357-B	<1	
WS- 003358	6/11/2018	6/11/2019	3	Break Room	In breakroom 317	WF-06112018-003358	12/10/2018	FT-FY19-112018-003358-A	<1	FT-FY19-112018-003358-B	<1	
WS- 003359	6/11/2018	6/11/2019	3	Combo Fountain	In break room 317	WF-06112018-003359	12/10/2018	FT-FY19-112018-003359-A	<1	FT-FY19-112018-003359-B	<1	
WS- 003360	9/18/2018	9/18/2019	3	Combo Faucet	In classroom 307	WF-09182018-003360	12/10/2018	FT-FY19-112018-003360-A	<1	FT-FY19-112018-003360-B	<1	
WS- 003361	6/11/2018	6/11/2019	3	Combo Fountain	In classroom 307	WF-06112018-003361	12/10/2018	FT-FY19-112018-003361-A	<1	FT-FY19-112018-003361-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003307	1	Food Prep Sink	In kitchen on east wall Right	12/10/2018	FT-FY19-112018-003307-A	<1	FT-FY19-112018-003307-B	<1