



LUKE C MOORE HS LEAD WATER TEST RESULTS



| | Building Location: Building Name | RECORD ID | Date Analyzed | Floor | Device Type | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) |
|----|----------------------------------|------------|---------------|----------|----------------|---|----------------------|--------------------------------|----------------------|--------------------------------|
| 1 | LUKE C. MOORE HIGH SCHOOL | WS- 011830 | 8/19/2016 | Basement | Cooler | In hallway adjacent to room B22 High Left | FT-82016-011830-A | < 1 | FT-82016-011830-B | < 1 |
| 2 | LUKE C. MOORE HIGH SCHOOL | WS- 011831 | 8/19/2016 | Basement | Cooler | In hallway adjacent to room B22 Low Right | FT-82016-011831-A | < 1 | FT-82016-011831-B | < 1 |
| 3 | LUKE C. MOORE HIGH SCHOOL | WS- 011853 | 8/19/2016 | 1 | Health Suite | In health suite 108 | FT-72016-011853-A | < 1 | FT-72016-011853-B | < 1 |
| 4 | LUKE C. MOORE HIGH SCHOOL | WS- 011854 | 8/19/2016 | 1 | Cooler | In hallway adjacent to room 112 High Left | FT-82016-011854-A | < 1 | FT-82016-011854-B | < 1 |
| 5 | LUKE C. MOORE HIGH SCHOOL | WS- 011855 | 8/19/2016 | 1 | Cooler | In hallway adjacent to room 112 Low Right | FT-82016-011855-A | < 1 | FT-82016-011855-B | < 1 |
| 6 | LUKE C. MOORE HIGH SCHOOL | WS- 011860 | 8/19/2016 | 1 | Food Prep Sink | In kitchen fourth clockwise from entry door | FT-82016-011860-A | < 1 | FT-82016-011860-B | < 1 |
| 7 | LUKE C. MOORE HIGH SCHOOL | WS- 011862 | 8/19/2016 | 1 | Food Prep Sink | In kitchen on island | FT-72016-011862-A | < 1 | FT-72016-011862-B | < 1 |
| 8 | LUKE C. MOORE HIGH SCHOOL | WS- 011863 | 8/19/2016 | 1 | Ice Maker | In kitchen (ice maker) | FT-82016-011863-A | < 1 | FT-82016-011863-B | < 1 |
| 9 | LUKE C. MOORE HIGH SCHOOL | WS- 011866 | 8/19/2016 | 2 | Cooler | In hallway adjacent to boys' restroom | FT-82016-011866-A | < 1 | FT-82016-011866-B | < 1 |
| 10 | LUKE C. MOORE HIGH SCHOOL | WS- 011868 | 8/19/2016 | 2 | Cooler | In hallway adjacent to girls' restroom | FT-82016-011868-A | < 1 | FT-82016-011868-B | < 1 |