



Luke C. Moore High School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011830	2/28/2022	2/28/2023	Basement	Cooler	In hallway adjacent to room B22 High Left	WF-02282022-011830	2/14/2023	FT-FY23-01262023-011830-A	<1	FT-FY23-01262023-011830-B	<1	
WS- 011831	2/28/2022	2/28/2023	Basement	Cooler	In hallway adjacent to room B22 Low Right	WF-02282022-011831	2/14/2023	FT-FY23-01262023-011831-A	<1	FT-FY23-01262023-011831-B	<1	
WS- 011833	2/28/2022	2/28/2023	1	Break Room	In work room 101C	WF-02282022-011833	2/14/2023	FT-FY23-01262023-011833-A	<1	FT-FY23-01262023-011833-B	<1	
WS- 011853	2/28/2022	2/28/2023	1	Health Suite	In health suite 108	WF-02282022-011853	2/14/2023	FT-FY23-01262023-011853-A	<1	FT-FY23-01262023-011853-B	<1	
WS- 011854	2/28/2022	2/28/2023	1	Cooler	In hallway adjacent to room 112 High Left	WF-02282022-011854	2/14/2023	FT-FY23-01262023-011854-A	<1	FT-FY23-01262023-011854-B	<1	
WS- 011855	2/28/2022	2/28/2023	1	Cooler	In hallway adjacent to room 112 Low Right	WF-02282022-011855	2/14/2023	FT-FY23-01262023-011855-A	<1	FT-FY23-01262023-011855-B	<1	
WS- 011863	2/28/2022	2/28/2023	1	Ice Maker	In kitchen (ice maker)	WF-02282022-011863	2/14/2023	FT-FY23-01262023-011863-A	<1	FT-FY23-01262023-011863-B	<1	
WS- 011866	2/28/2022	2/28/2023	2	Cooler	In hallway adjacent to boys' restroom	WF-02282022-011866	2/14/2023	FT-FY23-01262023-011866-A	<1	FT-FY23-01262023-011866-B	<1	
WS- 011867	2/28/2022	2/28/2023	2	Break Room	In staff work room 216	WF-02282022-011867	2/14/2023	FT-FY23-01262023-011867-A	<1	FT-FY23-01262023-011867-B	<1	
WS- 011868	2/28/2022	2/28/2023	2	Cooler	In hallway adjacent to girls' restroom	WF-02282022-011868	2/14/2023	FT-FY23-01262023-011868-A	<1	FT-FY23-01262023-011868-B	<1	
WS- 011870	9/12/2022	9/12/2023	1	Classroom Faucet	In day care center 115	WF-09122022-011870	2/14/2023	FT-FY23-01262023-011870-A	2.2	FT-FY23-01262023-011870-B	<1	
WS- 011871	9/12/2022	9/12/2023	1	Classroom Faucet	In office room in day care center 115	WF-09122022-011871	2/14/2023	FT-FY23-01262023-011871-A	2.2	FT-FY23-01262023-011871-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011862	1/11/2023	1/11/2024	1	Food Prep Sink	In kitchen on island	WF-01112023-011862	2/14/2023	FT-FY23-01262023-011862-A	<1	FT-FY23-01262023-011862-B	<1	