



Luke C. Moore High School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011830	3/8/2021	3/8/2022	Basement	Cooler	In hallway adjacent to room B22	High Left	WF-03082021-011830	4/7/2021	FT-FY21-032021-011830-A	<1	FT-FY21-032021-011830-B	<1
WS- 011831	3/8/2021	3/8/2022	Basement	Cooler	In hallway adjacent to room B22	Low Right	WF-03082021-011831	4/7/2021	FT-FY21-032021-011831-A	<1	FT-FY21-032021-011831-B	<1
WS- 011833	3/8/2021	3/8/2022	1	Break Room	In work room 101C		WF-03082021-011833	4/7/2021	FT-FY21-032021-011833-A	<1	FT-FY21-032021-011833-B	<1
WS- 011853	3/8/2021	3/8/2022	1	Health Suite	In health suite 108		WF-03082021-011853	4/7/2021	FT-FY21-032021-011853-A	<1	FT-FY21-032021-011853-B	<1
WS- 011854	3/8/2021	3/8/2022	1	Cooler	In hallway adjacent to room 112	High Left	WF-03082021-011854	4/7/2021	FT-FY21-032021-011854-A	<1	FT-FY21-032021-011854-B	<1
WS- 011855	3/8/2021	3/8/2022	1	Cooler	In hallway adjacent to room 112	Low Right	WF-03082021-011855	4/7/2021	FT-FY21-032021-011855-A	<1	FT-FY21-032021-011855-B	<1
WS- 011866	3/8/2021	3/8/2022	2	Cooler	In hallway adjacent to boys' restroom		WF-03082021-011866	4/7/2021	FT-FY21-032021-011866-A	<1	FT-FY21-032021-011866-B	<1
WS- 011867	3/8/2021	3/8/2022	2	Break Room	In staff work room 216		WF-03082021-011867	4/7/2021	FT-FY21-032021-011867-A	<1	FT-FY21-032021-011867-B	<1
WS- 011868	3/8/2021	3/8/2022	2	Cooler	In hallway adjacent to girls' restroom		WF-03082021-011868	4/7/2021	FT-FY21-032021-011868-A	<1	FT-FY21-032021-011868-B	<1
WS- 011870	10/7/2020	10/7/2021	1	Classroom Faucet	In day care center 115		WF-10072020-011870	4/7/2021	FT-FY21-032021-011870-A	<1	FT-FY21-032021-011870-B	<1
WS- 011871	10/7/2020	10/7/2021	1	Classroom Faucet	In office room in day care center 115		WF-10072020-011871	4/7/2021	FT-FY21-032021-011871-A	<1	FT-FY21-032021-011871-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011862	2/10/2021	2/10/2022	1	Food Prep Sink	In kitchen on island		WF-02102021-011862	4/7/2021	FT-FY21-032021-011862-A	<1	FT-FY21-032021-011862-B	<1