



# LUKE C MOORE LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	LUKE C. MOORE SHS	5/17/2016	WS- 011829	Utility	Basement	In boiler room	WT-042916-11846- A	< 1	WT-042916-11846- B	< 1			
2	LUKE C. MOORE SHS	5/17/2016	WS- 011830	Cooler	Basement	In hallway adjacent to room B22 Left High	WT-042916-11847- A	< 1	WT-042916-11847- B	< 1			
3	LUKE C. MOORE SHS	5/17/2016	WS- 011831	Cooler	Basement	In hallway adjacent to room B22 Right Low	WT-042916-11848- A	< 1	WT-042916-11848- B	< 1			
4	LUKE C. MOORE SHS	5/17/2016	WS- 011832	Classroom	Basement	In classroom B18 music room	WT-042916-11849- A	3.4	WT-042916-11849- B	< 1			
5	LUKE C. MOORE SHS	5/17/2016	WS- 011833	Classroom	1	In room 101 C workroom	WT-042916-11850- A	< 1	WT-042916-11850- B	< 1			
6	LUKE C. MOORE SHS	5/17/2016	WS- 011834	Classroom	1	In classroom 106	WT-042916-11851- A	< 1	WT-042916-11851- B	< 1			
7	LUKE C. MOORE SHS	5/17/2016	WS- 011835	Classroom	1	In classroom 105 table 1 Left	WT-042916-11852- A	3.1	WT-042916-11852- B	< 1			
8	LUKE C. MOORE SHS	5/17/2016	WS- 011836	Classroom	1	In classroom 105 table 1 Right	WT-042916-11853- A	36.8	WT-042916-11853- B	< 1	Filter will be installed and then retested		
9	LUKE C. MOORE SHS	5/17/2016	WS- 011837	Classroom	1	In classroom 105 table 2 Left	WT-042916-11854- A	2.9	WT-042916-11854- B	< 1			
10	LUKE C. MOORE SHS	5/17/2016	WS- 011838	Classroom	1	In classroom 105 table 2 Right	WT-042916-11855- A	6.1	WT-042916-11855- B	< 1			
11	LUKE C. MOORE SHS	5/17/2016	WS- 011839	Classroom	1	In classroom 105 middle table	WT-042916-11856- A	5.2	WT-042916-11856- B	< 1			
12	LUKE C. MOORE SHS	5/17/2016	WS- 011840	Classroom	1	In classroom 105 table 3 Left	WT-042916-11857- A	1.5	WT-042916-11857- B	< 1			
13	LUKE C. MOORE SHS	5/17/2016	WS- 011841	Classroom	1	In classroom 105 table 3 Right	WT-042916-11858- A	1.9	WT-042916-11858- B	< 1			
14	LUKE C. MOORE SHS	5/17/2016	WS- 011842	Classroom	1	In classroom 105 table 4 Left	WT-042916-11859- A	< 1	WT-042916-11859- B	< 1			
15	LUKE C. MOORE SHS	5/17/2016	WS- 011843	Classroom	1	In classroom 105 table 4 Right	WT-042916-11860- A	21	WT-042916-11860- B	< 1	Filter will be installed and then retested		
16	LUKE C. MOORE SHS	5/17/2016	WS- 011844	Classroom	1	In classroom 107 table 1 Left	WT-042916-11861- A	34.4	WT-042916-11861- B	< 1	Filter will be installed and then retested		
17	LUKE C. MOORE SHS	5/17/2016	WS- 011845	Classroom	1	In classroom 107 table 1 Right	WT-042916-11862- A	12.7	WT-042916-11862- B	1.1			
18	LUKE C. MOORE SHS	5/17/2016	WS- 011846	Classroom	1	In classroom 107 table 2 Left	WT-042916-11863- A	4.1	WT-042916-11863- B	< 1			
19	LUKE C. MOORE SHS	5/17/2016	WS- 011847	Classroom	1	In classroom 107 table 2 Right	WT-042916-11864- A	< 1	WT-042916-11864- B	< 1			
20	LUKE C. MOORE SHS	5/17/2016	WS- 011848	Classroom	1	In classroom 107 middle table	WT-042916-11865- A	3.6	WT-042916-11865- B	< 1			
21	LUKE C. MOORE SHS	5/17/2016	WS- 011849	Classroom	1	In classroom 107 table 3 Left	WT-042916-11866- A	2.6	WT-042916-11866- B	< 1			
22	LUKE C. MOORE SHS	5/17/2016	WS- 011850	Classroom	1	In classroom 107 table 3 Right	WT-042916-11867- A	3.2	WT-042916-11867- B	< 1			
23	LUKE C. MOORE SHS	5/17/2016	WS- 011851	Classroom	1	In classroom 107 table 4 Left	WT-042916-11868- A	29	WT-042916-11868- B	< 1	Filter will be installed and then retested		
24	LUKE C. MOORE SHS	5/17/2016	WS- 011852	Classroom	1	In classroom 107 table 4 Right	WT-042916-11869- A	33.3	WT-042916-11869- B	3.9	Filter will be installed and then retested		
25	LUKE C. MOORE SHS	5/17/2016	WS- 011853	Health Suite	1	In room 108	WT-042916-11870- A	< 1	WT-042916-11870- B	< 1			
26	LUKE C. MOORE SHS	5/17/2016	WS- 011854	Cooler	1	In hallway adjacent to room 112 Left	WT-042916-11871- A	< 1	WT-042916-11871- B	< 1			
27	LUKE C. MOORE SHS	5/17/2016	WS- 011855	Cooler	1	In hallway adjacent to room 112 Right Low	WT-042916-11872- A	< 1	WT-042916-11872- B	< 1			
28	LUKE C. MOORE SHS	5/17/2016	WS- 011856	Classroom	1	In conference room 120A	WT-042916-11873- A	< 1	WT-042916-11873- B	< 1			
29	LUKE C. MOORE SHS	5/17/2016	WS- 011857	Kitchen	1	In kitchen first from left	WT-042916-11874- A	< 1	WT-042916-11874- B	< 1			
30	LUKE C. MOORE SHS	5/17/2016	WS- 011858	Kitchen	1	In kitchen second from left	WT-042916-11875- A	< 1	WT-042916-11875- B	< 1			
31	LUKE C. MOORE SHS	5/17/2016	WS- 011859	Kitchen	1	In kitchen third from left	WT-042916-11876- A	< 1	WT-042916-11876- B	< 1			
32	LUKE C. MOORE SHS	5/17/2016	WS- 011860	Kitchen	1	In kitchen fourth from left	WT-042916-11877- A	< 1	WT-042916-11877- B	< 1			
33	LUKE C. MOORE SHS	5/17/2016	WS- 011861	Kitchen	1	In kitchen last from left	WT-042916-11878- A	< 1	WT-042916-11878- B	< 1			
34	LUKE C. MOORE SHS	5/17/2016	WS- 011862	Kitchen	1	In kitchen middle table	WT-042916-11879- A	< 1	WT-042916-11879- B	< 1			
35	LUKE C. MOORE SHS	5/17/2016	WS- 011863	Kitchen	1	In kitchen ice machine	WT-042916-11880- A	< 1	WT-042916-11880- B	1.5			
36	LUKE C. MOORE SHS	5/17/2016	WS- 011864	Classroom	2	In classroom 220 art room Left	WT-042916-11881- A	3.7	WT-042916-11881- B	< 1			
37	LUKE C. MOORE SHS	5/17/2016	WS- 011865	Classroom	2	In classroom 220 art room Right	WT-042916-11882- A	< 1	WT-042916-11882- B	< 1			
38	LUKE C. MOORE SHS	5/17/2016	WS- 011866	Cooler	2	In hallway adjacent to room 220	WT-042916-11883- A	< 1	WT-042916-11883- B	< 1			
39	LUKE C. MOORE SHS	5/17/2016	WS- 011867	Classroom	2	In teachers work room 216	WT-042916-11884- A	< 1	WT-042916-11884- B	< 1			
40	LUKE C. MOORE SHS	5/17/2016	WS- 011868	Cooler	2	In hallway adjacent to room 220	WT-042916-11885- A	< 1	WT-042916-11885- B	< 1			
41	LUKE C. MOORE SHS	5/17/2016	WS- 011869	Classroom	2	In room 205A1	WT-042916-11886- A	3.7	WT-042916-11886- B	< 1			
42	LUKE C. MOORE SHS	5/17/2016	WS- 011870	Classroom	1	In daycare center 115	WT-042916-11887- A	< 1	WT-042916-11887- B	< 1			
43	LUKE C. MOORE SHS	5/17/2016	WS- 011871	Classroom	1	In daycare center 115 inside room	WT-042916-11888- A	< 1	WT-042916-11888- B	< 1			
44	LUKE C. MOORE SHS	5/17/2016	WS- 011872	Classroom	1	In conference room 116A	WT-042916-11889- A	< 1	WT-042916-11889- B	< 1			



# LUKE C MOORE LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
-------------------	-----------------------	-----------------	-------------	-------	-----------------	----------------------	--------------------------------	----------------------	--------------------------------	-------------	-------------	-----------------	-----------------

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.