



Luke C Moore HS Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011830	4/2/2018	4/2/2019	Basement	Cooler	In hallway adjacent to room B22	High Left	WF-04022018-011830	1/5/2019	FT-FY19-122018-011830-A	<1	FT-FY19-122018-011830-B	<1
WS- 011831	4/2/2018	4/2/2019	Basement	Cooler	In hallway adjacent to room B22	Low Right	WF-04022018-011831	1/5/2019	FT-FY19-122018-011831-A	<1	FT-FY19-122018-011831-B	<1
WS- 011833	4/2/2018	4/2/2019	1	Break Room	In work room 101C		WF-04022018-011833	1/5/2019	FT-FY19-122018-011833-A	<1	FT-FY19-122018-011833-B	<1
WS- 011853	4/2/2018	4/2/2019	1	Health Suite	In health suite 108		WF-04022018-011853	1/5/2019	FT-FY19-122018-011853-A	<1	FT-FY19-122018-011853-B	<1
WS- 011854	4/2/2018	4/2/2019	1	Cooler	In hallway adjacent to room 112	High Left	WF-04022018-011854	1/5/2019	FT-FY19-122018-011854-A	<1	FT-FY19-122018-011854-B	<1
WS- 011855	4/2/2018	4/2/2019	1	Cooler	In hallway adjacent to room 112	Low Right	WF-04022018-011855	1/5/2019	FT-FY19-122018-011855-A	<1	FT-FY19-122018-011855-B	<1
WS- 011863	4/2/2018	4/2/2019	1	Ice Maker	In kitchen (ice maker)		WF-04022018-011863	1/5/2019	FT-FY19-122018-011863-A	<1	FT-FY19-122018-011863-B	<1
WS- 011866	4/2/2018	4/2/2019	2	Cooler	In hallway adjacent to boys' restroom		WF-04022018-011866	1/5/2019	FT-FY19-122018-011866-A	<1	FT-FY19-122018-011866-B	<1
WS- 011867	4/2/2018	4/2/2019	2	Break Room	In staff work room 216		WF-04022018-011867	1/5/2019	FT-FY19-122018-011867-A	<1	FT-FY19-122018-011867-B	<1
WS- 011870	10/23/2018	10/23/2019	1	Classroom Faucet	In day care center 115		WF-10232018-011870	1/5/2019	FT-FY19-122018-011870-A	<1	FT-FY19-122018-011870-B	<1
WS- 011871	10/23/2018	10/23/2019	1	Classroom Faucet	In office room in day care center 115		WF-10232018-011871	1/5/2019	FT-FY19-122018-011871-A	<1	FT-FY19-122018-011871-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011860	1	Food Prep Sink	In kitchen fourth clockwise from entry door			1/5/2019	FT-FY19-122018-011860-A	<1	FT-FY19-122018-011860-B	<1
WS- 011862	1	Food Prep Sink	In kitchen on island			1/5/2019	FT-FY19-122018-011862-A	<1	FT-FY19-122018-011862-B	<1