



# Luke C. Moore HS Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011831	2/11/2025	2/11/2026	Basement	Cooler	In hallway adjacent to room B22	WF-02112025-011831	12/17/2025	FT-FY26-12012025-011831-A	<2	FT-FY26-12012025-011831-B	<2	
WS- 011833	2/11/2025	2/11/2026	1	Break Room	In work room 101C	WF-02112025-011833	12/17/2025	FT-FY26-12012025-011833-A	<2	FT-FY26-12012025-011833-B	<2	
WS- 011853	2/11/2025	2/11/2026	1	Health Suite	In health suite 108	WF-02112025-011853	12/17/2025	FT-FY26-12012025-011853-A	<2	FT-FY26-12012025-011853-B	<2	
WS- 011854	2/11/2025	2/11/2026	1	Cooler	In hallway adjacent to room 112	WF-02112025-011854	12/17/2025	FT-FY26-12012025-011854-A	<2	FT-FY26-12012025-011854-B	<2	
WS- 011855	2/11/2025	2/11/2026	1	Cooler	In hallway adjacent to room 112	WF-02112025-011855	12/17/2025	FT-FY26-12012025-011855-A	<2	FT-FY26-12012025-011855-B	<2	
WS- 011863	2/11/2025	2/11/2026	1	Ice Maker	In kitchen (ice maker)	WF-02112025-011863	12/17/2025	FT-FY26-12012025-011863-A	<2	FT-FY26-12012025-011863-B	<2	
WS- 011866	2/11/2025	2/11/2026	2	Cooler	In hallway adjacent to boys' restroom	WF-02112025-011866	12/17/2025	FT-FY26-12012025-011866-A	<2	FT-FY26-12012025-011866-B	<2	
WS- 011867	2/11/2025	2/11/2026	2	Break Room	In staff work room 216	WF-02112025-011867	12/17/2025	FT-FY26-12012025-011867-A	<2	FT-FY26-12012025-011867-B	<2	
WS- 011868	2/11/2025	2/11/2026	2	Cooler	In hallway adjacent to girls' restroom	WF-02112025-011868	12/17/2025	FT-FY26-12012025-011868-A	<2	FT-FY26-12012025-011868-B	<2	
WS- 011870	8/27/2025	8/27/2026	1	Classroom Faucet	In day care center 115	WF-08272025-011870	12/17/2025	FT-FY26-12012025-011870-A	<2	FT-FY26-12012025-011870-B	<2	
WS- 011871	8/27/2025	8/27/2026	1	Classroom Faucet	In office room in day care center 115	WF-08272025-011871	12/17/2025	FT-FY26-12012025-011871-A	<2	FT-FY26-12012025-011871-B	<2	
WS- 011905	2/11/2025	2/11/2026	1	Bottle Filler	In hallway adjacent to room 112	WF-02112025-011905	12/17/2025	FT-FY26-12012025-011905-A	<2	FT-FY26-12012025-011905-B	<2	

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011862	11/24/2025	11/24/2026	1	Food Prep Sink	In kitchen on island	WF-11242025-011862	12/17/2025	FT-FY26-12012025-011862-A	<2	FT-FY26-12012025-011862-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.