



# MARIE REED ES LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

### Below Actionable Level - Devices Requiring No Remediation

Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000897	8/29/2017	4	Cooler	In hallway adjacent to room 439	FT-82017-000897-A	< 1	FT-82017-000897-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000899	8/29/2017	4	Combo Fountain	In classroom 467	FT-82017-000899-A	< 1	FT-82017-000899-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000900	8/29/2017	4	Cooler	In hallway adjacent to girls restroom	FT-82017-000900-A	< 1	FT-82017-000900-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000901	8/29/2017	4	Break Room	In staff lounge 472	FT-82017-000901-A	< 1	FT-82017-000901-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000902	8/29/2017	4	Cooler	In hallway adjacent to boys restroom	FT-82017-000902-A	< 1	FT-82017-000902-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000903	8/29/2017	4	Combo Fountain	In classroom 401	FT-82017-000903-A	< 1	FT-82017-000903-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000906	8/29/2017	4	Combo Fountain	In classroom 403	FT-82017-000906-A	< 1	FT-82017-000906-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000908	8/29/2017	4	Combo Fountain	In classroom 406	FT-82017-000908-A	< 1	FT-82017-000908-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000910	8/29/2017	4	Combo Fountain	In classroom 409	FT-82017-000910-A	< 1	FT-82017-000910-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000911	8/29/2017	4	Combo Fountain	In classroom 411	FT-82017-000911-A	< 1	FT-82017-000911-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000913	8/29/2017	4	Cooler	In hallway adjacent to girls restroom	FT-82017-000913-A	< 1	FT-82017-000913-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000915	8/29/2017	4	Combo Fountain	In classroom 415	FT-82017-000915-A	< 1	FT-82017-000915-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000916	8/29/2017	4	Combo Fountain	In library room 400	FT-82017-000916-A	< 1	FT-82017-000916-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000918	8/29/2017	4	Combo Fountain	In classroom 417	FT-82017-000918-A	< 1	FT-82017-000918-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000920	8/29/2017	4	Combo Fountain	In classroom 419	FT-82017-000920-A	< 1	FT-82017-000920-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000922	8/29/2017	3	Combo Faucet	In classroom 306	FT-82017-000922-A	< 1	FT-82017-000922-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000923	8/29/2017	3	Combo Fountain	In classroom 306	FT-82017-000923-A	< 1	FT-82017-000923-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000924	8/29/2017	3	Combo Faucet	In classroom 301	FT-82017-000924-A	1.7	FT-82017-000924-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000925	8/29/2017	3	Combo Fountain	In classroom 301	FT-82017-000925-A	< 1	FT-82017-000925-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000926	8/29/2017	3	Combo Faucet	In classroom 308	FT-82017-000926-A	2.1	FT-82017-000926-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000927	8/29/2017	3	Combo Fountain	In classroom 308	FT-82017-000927-A	< 1	FT-82017-000927-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000928	8/29/2017	3	Combo Faucet	In classroom 310	FT-82017-000928-A	1.5	FT-82017-000928-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000929	8/29/2017	3	Combo Fountain	In classroom 310	FT-82017-000929-A	< 1	FT-82017-000929-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000930	8/29/2017	3	Combo Faucet	In classroom 305	FT-82017-000930-A	1.7	FT-82017-000930-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000931	8/29/2017	3	Combo Fountain	In classroom 305	FT-82017-000931-A	< 1	FT-82017-000931-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000932	8/29/2017	3	Combo Faucet	In classroom 311	FT-82017-000932-A	< 1	FT-82017-000932-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000933	8/29/2017	3	Combo Fountain	In classroom 311	FT-82017-000933-A	< 1	FT-82017-000933-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000934	8/29/2017	3	Combo Faucet	In classroom 302	FT-82017-000934-A	< 1	FT-82017-000934-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000935	8/29/2017	3	Combo Fountain	In classroom 302	FT-82017-000935-A	< 1	FT-82017-000935-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000936	8/29/2017	3	Combo Faucet	In classroom 319	FT-82017-000936-A	1.1	FT-82017-000936-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000937	8/29/2017	3	Combo Fountain	In classroom 319	FT-82017-000937-A	2.4	FT-82017-000937-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000939	8/29/2017	3	Combo Fountain	In classroom 321	FT-82017-000939-A	< 1	FT-82017-000939-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000940	8/29/2017	3	Health Suite	In health suite 368D	FT-82017-000940-A	< 1	FT-82017-000940-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000941	8/29/2017	3	Break Room	In break room 372	FT-82017-000941-A	< 1	FT-82017-000941-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000942	8/29/2017	3	Bottle Filler	In cafeteria	High Right FT-82017-000942-A	< 1	FT-82017-000942-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000943	8/29/2017	3	Cooler	In cafeteria	Low Right FT-82017-000943-A	< 1	FT-82017-000943-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000944	8/29/2017	3	Cooler	In cafeteria	Left FT-82017-000944-A	< 1	FT-82017-000944-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000948	8/29/2017	4	Break Room	In staff lounge room 430	FT-82017-000948-A	< 1	FT-82017-000948-B	< 1
MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000959	8/29/2017	3	Break Room	In workroom 317	FT-82017-000959-A	< 1	FT-82017-000959-B	< 1

### Above Actionable Level - Devices Shut Off and Corrective Action to be Taken

MARIE REED RECREATION ELEMENTARY SCHOOL	WS- 000938	8/29/2017	3	Combo Faucet	In classroom 321	FT-82017-000938-A	13	FT-82017-000938-B	< 1
---	------------	-----------	---	--------------	------------------	-------------------	----	-------------------	-----