



MLK Jr. Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008505	3/15/2021	3/15/2022	1	Health Suite	In health suite 108	WF-03152021-008505	2/13/2022	FT-FY22-01182022-008505-A	<1	FT-FY22-01182022-008505-B	<1
WS-008506	8/24/2021	8/24/2022	1	Classroom Faucet	In classroom 109	WF-08242021-008506	2/13/2022	FT-FY22-01182022-008506-A	<1	FT-FY22-01182022-008506-B	<1
WS-008507	8/24/2021	8/24/2022	1	Classroom Faucet	In classroom 118	WF-08242021-008507	2/13/2022	FT-FY22-01182022-008507-A	<1	FT-FY22-01182022-008507-B	<1
WS-008508	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to boys' restroom High Left	WF-03152021-008508	2/13/2022	FT-FY22-01182022-008508-A	<1	FT-FY22-01182022-008508-B	<1
WS-008509	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to boys' restroom Low Right	WF-03152021-008509	2/13/2022	FT-FY22-01182022-008509-A	<1	FT-FY22-01182022-008509-B	<1
WS-008510	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to girls' restroom High Left	WF-03152021-008510	2/13/2022	FT-FY22-01182022-008510-A	<1	FT-FY22-01182022-008510-B	<1
WS-008511	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to girls' restroom Low Right	WF-03152021-008511	2/13/2022	FT-FY22-01182022-008511-A	<1	FT-FY22-01182022-008511-B	<1
WS-008512	8/24/2021	8/24/2022	1	Classroom Faucet	In classroom 117	WF-08242021-008512	2/13/2022	FT-FY22-01182022-008512-A	<1	FT-FY22-01182022-008512-B	<1
WS-008513	8/24/2021	8/24/2022	1	Classroom Faucet	In classroom 113	WF-08242021-008513	2/13/2022	FT-FY22-01182022-008513-A	<1	FT-FY22-01182022-008513-B	<1
WS-008514	8/24/2021	8/24/2022	1	Classroom Faucet	In classroom 114	WF-08242021-008514	2/13/2022	FT-FY22-01182022-008514-A	<1	FT-FY22-01182022-008514-B	<1
WS-008515	8/24/2021	8/24/2022	1	Classroom Faucet	In classroom 116	WF-08242021-008515	2/13/2022	FT-FY22-01182022-008515-A	<1	FT-FY22-01182022-008515-B	<1
WS-008516	8/24/2021	8/24/2022	1	Classroom Faucet	In classroom 115	WF-08242021-008516	2/13/2022	FT-FY22-01182022-008516-A	<1	FT-FY22-01182022-008516-B	<1
WS-008521	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to room 208 High Left	WF-03152021-008521	2/13/2022	FT-FY22-01182022-008521-A	<1	FT-FY22-01182022-008521-B	<1
WS-008522	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to room 208 Low Right	WF-03152021-008522	2/13/2022	FT-FY22-01182022-008522-A	<1	FT-FY22-01182022-008522-B	<1
WS-008524	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to boys' restroom 206 High Left	WF-03152021-008524	2/13/2022	FT-FY22-01182022-008524-A	<1	FT-FY22-01182022-008524-B	<1
WS-008525	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to boys' restroom 206 Low Right	WF-03152021-008525	2/13/2022	FT-FY22-01182022-008525-A	<1	FT-FY22-01182022-008525-B	<1
WS-008532	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to boys' restroom 305 High Left	WF-03152021-008532	2/13/2022	FT-FY22-01182022-008532-A	<1	FT-FY22-01182022-008532-B	<1
WS-008533	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to boys' restroom 305 Low Right	WF-03152021-008533	2/13/2022	FT-FY22-01182022-008533-A	<1	FT-FY22-01182022-008533-B	<1
WS-008534	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to room 307 High Right	WF-03152021-008534	2/13/2022	FT-FY22-01182022-008534-A	<1	FT-FY22-01182022-008534-B	<1
WS-008535	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to room 307 Low Right	WF-03152021-008535	2/13/2022	FT-FY22-01182022-008535-A	<1	FT-FY22-01182022-008535-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008502	1/10/2022	1/10/2023	1	Food Prep Sink	In kitchen second clockwise from entry door	WF-01102022-008502	2/13/2022	FT-FY22-01182022-008502-A	<1	FT-FY22-01182022-008502-B	<1
WS-008503	1/10/2022	1/10/2023	1	Food Prep Sink	In kitchen third clockwise from entry door	WF-01102022-008503	2/13/2022	FT-FY22-01182022-008503-A	<1	FT-FY22-01182022-008503-B	<1