Martin Luther King Jr. Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008504	3/7/2022	3/7/2023	1	Cooler	In gym/cafeteria	WF-03072022-008504	10/26/2022	FT-FY23-10102022-008504-A	<1	FT-FY23-10102022-008504-B	<1
WS- 008505	3/7/2022	3/7/2023	1	Health Suite	In health suite 108	WF-03072022-008505	10/26/2022	FT-FY23-10102022-008505-A	1.1	FT-FY23-10102022-008505-B	<1
WS- 008506	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 109	WF-08162022-008506	10/26/2022	FT-FY23-10102022-008506-A	<1	FT-FY23-10102022-008506-B	<1
WS- 008507	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 118	WF-08162022-008507	10/26/2022	FT-FY23-10102022-008507-A	1.5	FT-FY23-10102022-008507-B	<1
WS- 008508	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to boys' restroom High Left	WF-03072022-008508	10/26/2022	FT-FY23-10102022-008508-A	<1	FT-FY23-10102022-008508-B	<1
WS- 008509	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to boys' restroom Low Right	WF-03072022-008509	10/26/2022	FT-FY23-10102022-008509-A	<1	FT-FY23-10102022-008509-B	<1
WS- 008510	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to girls' restroom High Left	WF-03072022-008510	10/26/2022	FT-FY23-10102022-008510-A	<1	FT-FY23-10102022-008510-B	<1
WS- 008511	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to girls' restroom Low Right	WF-03072022-008511	10/26/2022	FT-FY23-10102022-008511-A	1.1	FT-FY23-10102022-008511-B	<1
WS- 008512	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 117	WF-08162022-008512	10/26/2022	FT-FY23-10102022-008512-A	<1	FT-FY23-10102022-008512-B	<1
WS- 008513	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 113	WF-08162022-008513	10/26/2022	FT-FY23-10102022-008513-A	<1	FT-FY23-10102022-008513-B	<1
WS- 008514	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 114	WF-08162022-008514	10/26/2022	FT-FY23-10102022-008514-A	1.9	FT-FY23-10102022-008514-B	<1
WS- 008515	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 116	WF-08162022-008515	10/26/2022	FT-FY23-10102022-008515-A	<1	FT-FY23-10102022-008515-B	<1
WS- 008516	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 115	WF-08162022-008516	10/26/2022	FT-FY23-10102022-008516-A	<1	FT-FY23-10102022-008516-B	<1
WS- 008521	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to room 208 High Left	WF-03072022-008521	10/26/2022	FT-FY23-10102022-008521-A	<1	FT-FY23-10102022-008521-B	<1
WS- 008522	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to room 208 Low Right	WF-03072022-008522	10/26/2022	FT-FY23-10102022-008522-A	<1	FT-FY23-10102022-008522-B	<1
WS- 008524	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to boys' restroom 206 High Left	WF-03072022-008524	10/26/2022	FT-FY23-10102022-008524-A	<1	FT-FY23-10102022-008524-B	<1
WS- 008525	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to boys' restroom 206 Low Right	WF-03072022-008525	10/26/2022	FT-FY23-10102022-008525-A	<1	FT-FY23-10102022-008525-B	<1
WS- 008532	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to boys' restroom 305 High Left	WF-03072022-008532	10/26/2022	FT-FY23-10102022-008532-A	<1	FT-FY23-10102022-008532-B	<1
WS- 008533	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to boys' restroom 305 Low Right	WF-03072022-008533	10/26/2022	FT-FY23-10102022-008533-A	<1	FT-FY23-10102022-008533-B	<1
WS- 008534	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to room 307 High Right	WF-03072022-008534	10/26/2022	FT-FY23-10102022-008534-A	<1	FT-FY23-10102022-008534-B	<1
WS- 008535	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to room 307 Low Right	WF-03072022-008535	10/26/2022	FT-FY23-10102022-008535-A	<1	FT-FY23-10102022-008535-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008502	1/10/2022	1/10/2023	1	Food Prep Sink	In kitchen second clockwise from entry door	WF-01102022-008502	10/26/2022	FT-FY23-10102022-008502-A	<1	FT-FY23-10102022-008502-B	<1
WS- 008503	1/10/2022	1/10/2023	1	Food Prep Sink	In kitchen third clockwise from entry door	WF-01102022-008503	10/26/2022	FT-FY23-10102022-008503-A	<1	FT-FY23-10102022-008503-B	<1