



MacArthur High School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-016250	8/15/2024	8/15/2025	3	Bottle Filler	In hallway opposite stairway 3	WF-08152024-016250	8/22/2024	FT-FY25-08152024-016250-A	<1	FT-FY25-08152024-016250-B	<1
WS-016251	8/15/2024	8/15/2025	3	Cooler	In hallway opposite stairway 3	WF-08152024-016251	8/22/2024	FT-FY25-08152024-016251-A	<1	FT-FY25-08152024-016251-B	<1
WS-016252	5/20/2024	5/20/2025	3	Health Suite	In health suite A309	WF-05202024-016252	8/22/2024	FT-FY25-08152024-016252-A	<1	FT-FY25-08152024-016252-B	<1
WS-016254	5/20/2024	5/20/2025	3	Bottle Filler	In hallway adjacent to room A312/ elevator	WF-05202024-016254	8/22/2024	FT-FY25-08152024-016254-A	<1	FT-FY25-08152024-016254-B	<1
WS-016255	5/20/2024	5/20/2025	3	Cooler	In hallway adjacent to room A312/ elevator	WF-05202024-016255	8/22/2024	FT-FY25-08152024-016255-A	<1	FT-FY25-08152024-016255-B	<1
WS-016269	5/20/2024	5/20/2025	3	Bottle Filler	In hallway adjacent to the gym B334	WF-05202024-016269	8/22/2024	FT-FY25-08152024-016269-A	<1	FT-FY25-08152024-016269-B	<1
WS-016270	5/20/2024	5/20/2025	3	Cooler	In hallway adjacent to the gym B334	WF-05202024-016270	8/22/2024	FT-FY25-08152024-016270-A	<1	FT-FY25-08152024-016270-B	<1
WS-016272	5/20/2024	5/20/2025	4	Break Room	In In break room B413	WF-05202024-016272	8/22/2024	FT-FY25-08152024-016272-A	<1	FT-FY25-08152024-016272-B	<1
WS-016273	5/20/2024	5/20/2025	4	Bottle Filler	In hallway adjacent to room B401	WF-05202024-016273	8/22/2024	FT-FY25-08152024-016273-A	<1	FT-FY25-08152024-016273-B	<1
WS-016274	5/20/2024	5/20/2025	4	Cooler	In In hallway adjacent to room B401	WF-05202024-016274	8/22/2024	FT-FY25-08152024-016274-A	<1	FT-FY25-08152024-016274-B	<1
WS-016295	5/20/2024	5/20/2025	3	Bottle Filler	In hallway in cafeteria	WF-05202024-016295	8/22/2024	FT-FY25-08152024-016295-A	<1	FT-FY25-08152024-016295-B	<1
WS-016296	5/20/2024	5/20/2025	3	Cooler	In hallway in cafeteria	WF-05202024-016296	8/22/2024	FT-FY25-08152024-016296-A	<1	FT-FY25-08152024-016296-B	2.9
WS-016297	5/20/2024	5/20/2025	3	Cooler	In hallway in cafeteria	WF-05202024-016297	8/22/2024	FT-FY25-08152024-016297-A	<1	FT-FY25-08152024-016297-B	<1
WS-016298	8/15/2024	8/15/2025	3	Bottle Filler	In cafeteria	WF-08152024-016298	8/22/2024	FT-FY25-08152024-016298-A	1.6	FT-FY25-08152024-016298-B	<1
WS-016299	8/15/2024	8/15/2025	3	Cooler	In cafeteria	WF-08152024-016299	8/22/2024	FT-FY25-08152024-016299-A	<1	FT-FY25-08152024-016299-B	<1
WS-016300	8/15/2024	8/15/2025	3	Cooler	In cafeteria	WF-08152024-016300	8/22/2024	FT-FY25-08152024-016300-A	<1	FT-FY25-08152024-016300-B	<1
WS- 006000	8/5/2024	8/5/2025	2	Bottle Filler	In hallway across from 2493	WF-08052024-006000	8/22/2024	FT-FY25-08152024-006000-A	1.5	FT-FY25-08152024-006000-B	1.0
WS- 006001	8/5/2024	8/5/2025	2	Cooler	In hallway across from 2493	WF-08052024-006001	8/22/2024	FT-FY25-08152024-006001-A	<1	FT-FY25-08152024-006001-B	<1
WS- 006002	8/5/2024	8/5/2025	2	Cooler	In hallway across from 2493	WF-08052024-006002	8/22/2024	FT-FY25-08152024-006002-A	<1	FT-FY25-08152024-006002-B	<1
WS- 006003	8/5/2024	8/5/2025	2	Bottle Filler	In hallway adjacent to stair F	WF-08052024-006003	8/22/2024	FT-FY25-08152024-006003-A	<1	FT-FY25-08152024-006003-B	<1
WS- 006004	8/5/2024	8/5/2025	2	Cooler	In hallway adjacent to stair F	WF-08052024-006004	8/22/2024	FT-FY25-08152024-006004-A	<1	FT-FY25-08152024-006004-B	<1
WS- 006005	8/5/2024	8/5/2025	2	Cooler	In hallway adjacent to stair F	WF-08052024-006005	8/22/2024	FT-FY25-08152024-006005-A	<1	FT-FY25-08152024-006005-B	<1
WS- 006008	8/5/2024	8/5/2025	2	Cooler	In hallway adjacent to 2356 electrical closet	WF-08052024-006008	8/22/2024	FT-FY25-08152024-006008-A	<1	FT-FY25-08152024-006008-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-016301	1/8/2024	1/8/2025	3	Food Prep Sink	In kitchen	WF-01082024-016301	8/22/2024	FT-FY25-08152024-016301-A	<1	FT-FY25-08152024-016301-B	<1