



Macfarland Middle School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014050	4/5/2021	4/5/2022	Basement	Break Room	In staff lounge B-114	WF-04052021-014050	2/28/2022	FT-FY22-02032022-014050-A	<1	FT-FY22-02032022-014050-B	<1	
WS-014051	4/5/2021	4/5/2022	Basement	Health Suite	In wellness room B-113	WF-04052021-014051	2/28/2022	FT-FY22-02032022-014051-A	<1	FT-FY22-02032022-014051-B	<1	
WS-014052	4/5/2021	4/5/2022	Basement	Bottle Filler	In hallway adjacent to B2-0246	WF-04052021-014052	2/28/2022	FT-FY22-02032022-014052-A	<1	FT-FY22-02032022-014052-B	<1	
WS-014053	4/5/2021	4/5/2022	Basement	Cooler	In hallway adjacent to B2-0246	WF-04052021-014053	2/28/2022	FT-FY22-02032022-014053-A	<1	FT-FY22-02032022-014053-B	<1	
WS-014055	4/5/2021	4/5/2022	Basement	Combo Fountain	In makerspace room B2-0245	WF-04052021-014055	2/28/2022	FT-FY22-02032022-014055-A	<1	FT-FY22-02032022-014055-B	<1	
WS-014057	4/5/2021	4/5/2022	Basement	Bottle Filler	In hallway adjacent to B1-0244	WF-04052021-014057	2/28/2022	FT-FY22-02032022-014057-A	<1	FT-FY22-02032022-014057-B	<1	
WS-014058	4/5/2021	4/5/2022	Basement	Cooler	In hallway adjacent to B1-0244	WF-04052021-014058	2/28/2022	FT-FY22-02032022-014058-A	<1	FT-FY22-02032022-014058-B	<1	
WS-014059	4/5/2021	4/5/2022	1	Bottle Filler	In hallway adjacent to all gender restroom 1103A	WF-04052021-014059	2/28/2022	FT-FY22-02032022-014059-A	<1	FT-FY22-02032022-014059-B	<1	
WS-014060	4/5/2021	4/5/2022	1	Cooler	In hallway adjacent to all gender restroom 1103A	High Left	WF-04052021-014060	2/28/2022	FT-FY22-02032022-014060-A	<1	FT-FY22-02032022-014060-B	<1
WS-014061	4/5/2021	4/5/2022	1	Cooler	In hallway adjacent to all gender restroom 1103A	Low Right	WF-04052021-014061	2/28/2022	FT-FY22-02032022-014061-A	<1	FT-FY22-02032022-014061-B	<1
WS-014062	10/6/2021	10/6/2022	1	Bottle Filler	In hallway across from auditorium 1206	WF-10062021-014062	2/28/2022	FT-FY22-02032022-014062-A	<1	FT-FY22-02032022-014062-B	<1	
WS-014063	10/6/2021	10/6/2022	1	Cooler	In hallway across from auditorium 1206	High Left	WF-10062021-014063	2/28/2022	FT-FY22-02032022-014063-A	<1	FT-FY22-02032022-014063-B	<1
WS-014064	10/6/2021	10/6/2022	1	Cooler	In hallway across from auditorium 1206	Low Right	WF-10062021-014064	2/28/2022	FT-FY22-02032022-014064-A	<1	FT-FY22-02032022-014064-B	<1
WS-014065	4/5/2021	4/5/2022	1	Bottle Filler	In hallway adjacent to all gender restroom 1221	WF-04052021-014065	2/28/2022	FT-FY22-02032022-014065-A	<1	FT-FY22-02032022-014065-B	<1	
WS-014066	4/5/2021	4/5/2022	1	Cooler	In hallway adjacent to all gender restroom 1221	High Left	WF-04052021-014066	2/28/2022	FT-FY22-02032022-014066-A	<1	FT-FY22-02032022-014066-B	<1
WS-014067	4/5/2021	4/5/2022	1	Cooler	In hallway adjacent to all gender restroom 1221	Low Right	WF-04052021-014067	2/28/2022	FT-FY22-02032022-014067-A	<1	FT-FY22-02032022-014067-B	<1
WS-014069	4/5/2021	4/5/2022	1	Break Room	In admin suite 1207A-F	WF-04052021-014069	2/28/2022	FT-FY22-02032022-014069-A	<1	FT-FY22-02032022-014069-B	<1	
WS-014071	4/5/2021	4/5/2022	1	Cooler	In hallway adjacent to all gender restroom 1230	High Left	WF-04052021-014071	2/28/2022	FT-FY22-02032022-014071-A	<1	FT-FY22-02032022-014071-B	<1
WS-014072	4/5/2021	4/5/2022	1	Cooler	In hallway adjacent to all gender restroom 1230	Low Right	WF-04052021-014072	2/28/2022	FT-FY22-02032022-014072-A	<1	FT-FY22-02032022-014072-B	<1
WS-014074	4/5/2021	4/5/2022	1	Combo Fountain	In music room 1235	WF-04052021-014074	2/28/2022	FT-FY22-02032022-014074-A	<1	FT-FY22-02032022-014074-B	<1	
WS-014076	4/5/2021	4/5/2022	1	Combo Fountain	In choral room 1233	WF-04052021-014076	2/28/2022	FT-FY22-02032022-014076-A	<1	FT-FY22-02032022-014076-B	<1	
WS-014077	4/5/2021	4/5/2022	1	Health Suite	In health suite treatment room 1231D	WF-04052021-014077	2/28/2022	FT-FY22-02032022-014077-A	<1	FT-FY22-02032022-014077-B	<1	
WS-014078	4/5/2021	4/5/2022	1	Bottle Filler	In cafeteria adjacent to stair 9 exit	WF-04052021-014078	2/28/2022	FT-FY22-02032022-014078-A	<1	FT-FY22-02032022-014078-B	<1	
WS-014079	4/5/2021	4/5/2022	1	Cooler	In cafeteria adjacent to stair 9 exit	High Left	WF-04052021-014079	2/28/2022	FT-FY22-02032022-014079-A	<1	FT-FY22-02032022-014079-B	<1
WS-014080	4/5/2021	4/5/2022	1	Cooler	In cafeteria adjacent to stair 9 exit	Low Right	WF-04052021-014080	2/28/2022	FT-FY22-02032022-014080-A	<1	FT-FY22-02032022-014080-B	<1
WS-014089	4/5/2021	4/5/2022	2	Bottle Filler	In hallway adjacent to all gender restroom 2103A	WF-04052021-014089	2/28/2022	FT-FY22-02032022-014089-A	<1	FT-FY22-02032022-014089-B	<1	
WS-014090	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to all gender restroom 2103A	High Left	WF-04052021-014090	2/28/2022	FT-FY22-02032022-014090-A	<1	FT-FY22-02032022-014090-B	<1
WS-014091	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to all gender restroom 2103A	Low Right	WF-04052021-014091	2/28/2022	FT-FY22-02032022-014091-A	<1	FT-FY22-02032022-014091-B	<1
WS-014092	4/5/2021	4/5/2022	2	Bottle Filler	In hallway adjacent to electrical room 2205A	WF-04052021-014092	2/28/2022	FT-FY22-02032022-014092-A	<1	FT-FY22-02032022-014092-B	<1	
WS-014093	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to electrical room 2205A	High Left	WF-04052021-014093	2/28/2022	FT-FY22-02032022-014093-A	<1	FT-FY22-02032022-014093-B	<1
WS-014094	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to electrical room 2205A	Low Right	WF-04052021-014094	2/28/2022	FT-FY22-02032022-014094-A	<1	FT-FY22-02032022-014094-B	<1
WS-014128	4/5/2021	4/5/2022	2	Health Suite	In training room 2303	WF-04052021-014128	2/28/2022	FT-FY22-02032022-014128-A	<1	FT-FY22-02032022-014128-B	<1	
WS-014131	4/5/2021	4/5/2022	2	Bottle Filler	In hallway across from health room 2306	WF-04052021-014131	2/28/2022	FT-FY22-02032022-014131-A	<1	FT-FY22-02032022-014131-B	<1	
WS-014132	4/5/2021	4/5/2022	2	Cooler	In hallway across from health room 2306	High Left	WF-04052021-014132	2/28/2022	FT-FY22-02032022-014132-A	<1	FT-FY22-02032022-014132-B	<1
WS-014133	4/5/2021	4/5/2022	2	Cooler	In hallway across from health room 2306	Low Right	WF-04052021-014133	2/28/2022	FT-FY22-02032022-014133-A	<1	FT-FY22-02032022-014133-B	<1
WS-014135	4/5/2021	4/5/2022	2	Combo Fountain	In health room 2306	WF-04052021-014135	2/28/2022	FT-FY22-02032022-014135-A	<1	FT-FY22-02032022-014135-B	<1	

WS-014136	10/6/2021	10/6/2022	3	Bottle Filler	In hallway adjacent to all gender restroom 3105A		WF-10062021-014136	2/28/2022	FT-FY22-02032022-014136-A	<1	FT-FY22-02032022-014136-B	<1
WS-014137	10/6/2021	10/6/2022	3	Cooler	In hallway adjacent to all gender restroom 3105A	High Left	WF-10062021-014137	2/28/2022	FT-FY22-02032022-014137-A	<1	FT-FY22-02032022-014137-B	<1
WS-014138	10/6/2021	10/6/2022	3	Cooler	In hallway adjacent to all gender restroom 3105A	Low Right	WF-10062021-014138	2/28/2022	FT-FY22-02032022-014138-A	<1	FT-FY22-02032022-014138-B	<1
WS-014140	10/6/2021	10/6/2022	3	Cooler	In hallway adjacent to SPED 3202	High Left	WF-10062021-014140	2/28/2022	FT-FY22-02032022-014140-A	<1	FT-FY22-02032022-014140-B	<1
WS-014142	10/6/2021	10/6/2022	3	Bottle Filler	In hallway adjacent to PE office 3304		WF-10062021-014142	2/28/2022	FT-FY22-02032022-014142-A	<1	FT-FY22-02032022-014142-B	<1
WS-014143	10/6/2021	10/6/2022	3	Cooler	In hallway adjacent to PE office 3304	High Left	WF-10062021-014143	2/28/2022	FT-FY22-02032022-014143-A	<1	FT-FY22-02032022-014143-B	<1
WS-014144	10/6/2021	10/6/2022	3	Cooler	In hallway adjacent to PE office 3304	Low Right	WF-10062021-014144	2/28/2022	FT-FY22-02032022-014144-A	<1	FT-FY22-02032022-014144-B	<1
WS-014145	4/5/2021	4/5/2022	1	Combo Fountain	In op/pt office		WF-04052021-014145	2/28/2022	FT-FY22-02032022-014145-A	<1	FT-FY22-02032022-014145-B	<1
WS-014148	4/5/2021	4/5/2022	1	Combo Fountain	In room 1223		WF-04052021-014148	2/28/2022	FT-FY22-02032022-014148-A	<1	FT-FY22-02032022-014148-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014084	1/24/2022	1/24/2023	1	Food Prep Sink	In kitchen	WF-01242022-014084	2/28/2022	FT-FY22-02032022-014084-A	<1	FT-FY22-02032022-014084-B	<1	
WS-014087	1/24/2022	1/24/2023	1	Food Prep Sink	In kitchen (dishwashing area)	Left	WF-01242022-014087	2/28/2022	FT-FY22-02032022-014087-A	<1	FT-FY22-02032022-014087-B	<1