



Macfarland Junior High Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003178	6/28/2017	6/28/2018	2	Bottle Filler	In hallway adjacent to classroom 218 (bottle filler)	WF-122017-003178	12/14/2017	FT-FY18-122017-003178-A	<1	FT-FY18-122017-003178-B	<1
WS- 003179	6/27/2017	6/27/2018	1	Cooler	In hallway adjacent to room 159	WF-122017-003179	12/14/2017	FT-FY18-122017-003179-A	<1	FT-FY18-122017-003179-B	<1
WS- 010922	6/28/2017	6/28/2018	Basement	Cooler	In cafeteria	WF-62017-010922	12/14/2017	FT-FY18--62017-010922-A	<1	FT-FY18--62017-010922-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010918	Basement	Food Prep Sink	In kitchen Right	12/14/2017	FT-FY18-102017-010918-A	<1	FT-FY18-102017-010918-B	<1	