



MACOMB REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location			1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	MACOMB RECREATION CENTER	WS- 012698	9/22/2016	1	Cooler	In main room	Low	Right	FT-82016-012698-A	< 1	FT-82016-012698-B	< 1
2	MACOMB RECREATION CENTER	WS- 012699	9/22/2016	1	Cooler	In main room	High	Left	FT-82016-012699-A	< 1	FT-82016-012699-B	< 1