



Malcolm X Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008841	4/13/2021	4/13/2022	1	Bottle Filler	In hallway across from infant/toddler child development center 103	WF-04132021-008841	2/18/2022	FT-FY22-01182022-008841-A	<1	FT-FY22-01182022-008841-B	<1
WS- 008842	4/13/2021	4/13/2022	1	Cooler	In hallway across from infant/toddler child development center 103 High Left	WF-04132021-008842	2/18/2022	FT-FY22-01182022-008842-A	<1	FT-FY22-01182022-008842-B	<1
WS- 008843	4/13/2021	4/13/2022	1	Cooler	In hallway across from infant/toddler child development center 103 Low Right	WF-04132021-008843	2/18/2022	FT-FY22-01182022-008843-A	<1	FT-FY22-01182022-008843-B	<1
WS- 008845	4/13/2021	4/13/2022	1	Classroom Faucet	In infant/toddler child development center 101 Left	WF-04132021-008845	2/18/2022	FT-FY22-01182022-008845-A	<1	FT-FY22-01182022-008845-B	<1
WS- 008846	4/13/2021	4/13/2022	1	Classroom Faucet	In infant/toddler child development center 103 Right	WF-04132021-008846	2/18/2022	FT-FY22-01182022-008846-A	<1	FT-FY22-01182022-008846-B	<1
WS- 008849	9/20/2021	9/20/2022	1	Bathroom	In the bathroom of classroom 123	WF-09202021-008849	2/18/2022	FT-FY22-01182022-008849-A	<1	FT-FY22-01182022-008849-B	<1
WS- 009888	4/13/2021	4/13/2022	1	Cooler	In multi-purpose room	WF-04132021-009888	2/18/2022	FT-FY22-01182022-009888-A	<1	FT-FY22-01182022-009888-B	<1
WS- 009889	4/13/2021	4/13/2022	1	Cooler	In health suite	WF-04132021-009889	2/18/2022	FT-FY22-01182022-009889-A	<1	FT-FY22-01182022-009889-B	<1
WS- 009890	4/13/2021	4/13/2022	1	Break Room	In classroom 138	WF-04132021-009890	2/18/2022	FT-FY22-01182022-009890-A	<1	FT-FY22-01182022-009890-B	<1
WS- 009891	4/13/2021	4/13/2022	1	Cooler	In hallway adjacent to room 136	WF-04132021-009891	2/18/2022	FT-FY22-01182022-009891-A	<1	FT-FY22-01182022-009891-B	<1
WS- 009892	9/20/2021	9/20/2022	1	Classroom Faucet	In classroom 136	WF-09202021-009892	2/18/2022	FT-FY22-01182022-009892-A	2.2	FT-FY22-01182022-009892-B	<1
WS- 009893	4/13/2021	4/13/2022	1	Cooler	In hallway across from health suite	WF-04132021-009893	2/18/2022	FT-FY22-01182022-009893-A	<1	FT-FY22-01182022-009893-B	<1
WS- 009901	4/13/2021	4/13/2022	2	Cooler	In hallway across from room 213	WF-04132021-009901	2/18/2022	FT-FY22-01182022-009901-A	<1	FT-FY22-01182022-009901-B	<1
WS- 009908	4/13/2021	4/13/2022	3	Cooler	In hallway across from room 308	WF-04132021-009908	2/18/2022	FT-FY22-01182022-009908-A	<1	FT-FY22-01182022-009908-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009887	1/10/2022	1/10/2023	1	Food Prep Sink	In kitchen second clockwise from entry door	WF-01102022-009887	2/18/2022	FT-FY22-01182022-009887-A	<1	FT-FY22-01182022-009887-B	<1