



# Malcolm X Elementary School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008841	8/24/2020	8/24/2021	1	Bottle Filler	In hallway across from infant/toddler child development center 103	WF-08242020-008841	3/5/2021	FT-FY21-022021-008841-A	<1	FT-FY21-022021-008841-B	<1
WS-008842	8/24/2020	8/24/2021	1	Cooler	In hallway across from infant/toddler child development center 103 High Left	WF-08242020-008842	3/5/2021	FT-FY21-022021-008842-A	<1	FT-FY21-022021-008842-B	<1
WS-008843	8/24/2020	8/24/2021	1	Cooler	In hallway across from infant/toddler child development center 103 Low Right	WF-08242020-008843	3/5/2021	FT-FY21-022021-008843-A	<1	FT-FY21-022021-008843-B	<1
WS-008844	8/24/2020	8/24/2021	1	Break Room	In staff break room 104	WF-08242020-008844	3/5/2021	FT-FY21-022021-008844-A	<1	FT-FY21-022021-008844-B	<1
WS-008845	8/24/2020	8/24/2021	1	Classroom Faucet	In infant/toddler child development center 101 Left	WF-08242020-008845	3/5/2021	FT-FY21-022021-008845-A	<1	FT-FY21-022021-008845-B	<1
WS-008846	8/24/2020	8/24/2021	1	Classroom Faucet	In infant/toddler child development center 103 Right	WF-08242020-008846	3/5/2021	FT-FY21-022021-008846-A	<1	FT-FY21-022021-008846-B	<1
WS-008849	9/30/2020	9/30/2021	1	Bathroom	In the bathroom of classroom 123	WF-09302020-008849	3/5/2021	FT-FY21-022021-008849-A	<1	FT-FY21-022021-008849-B	<1
WS-009888	5/12/2020	5/12/2021	1	Cooler	In multi-purpose room	WF-05122020-009888	3/5/2021	FT-FY21-022021-009888-A	<1	FT-FY21-022021-009888-B	<1
WS-009889	5/12/2020	5/12/2021	1	Cooler	In health suite	WF-05122020-009889	3/5/2021	FT-FY21-022021-009889-A	<1	FT-FY21-022021-009889-B	<1
WS-009890	5/12/2020	5/12/2021	1	Break Room	In classroom 138	WF-05122020-009890	3/5/2021	FT-FY21-022021-009890-A	<1	FT-FY21-022021-009890-B	<1
WS-009891	5/12/2020	5/12/2021	1	Cooler	In hallway adjacent to room 136	WF-05122020-009891	3/5/2021	FT-FY21-022021-009891-A	<1	FT-FY21-022021-009891-B	<1
WS-009892	9/29/2020	9/29/2021	1	Classroom Faucet	In classroom 136	WF-09292020-009892	3/5/2021	FT-FY21-022021-009892-A	<1	FT-FY21-022021-009892-B	<1
WS-009893	5/12/2020	5/12/2021	1	Cooler	In hallway across from health suite	WF-05122020-009893	3/5/2021	FT-FY21-022021-009893-A	<1	FT-FY21-022021-009893-B	<1
WS-009900	5/12/2020	5/12/2021	2	Cooler	In hallway adjacent to room 222	WF-05122020-009900	3/5/2021	FT-FY21-022021-009900-A	<1	FT-FY21-022021-009900-B	<1
WS-009901	8/17/2020	8/17/2021	2	Cooler	In hallway across from room 213	WF-08172020-009901	3/5/2021	FT-FY21-022021-009901-A	<1	FT-FY21-022021-009901-B	<1
WS-009908	5/12/2020	5/12/2021	3	Cooler	In hallway across from room 308	WF-05122020-009908	3/5/2021	FT-FY21-022021-009908-A	<1	FT-FY21-022021-009908-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009887	1/21/2021	1/21/2022	1	Food Prep Sink	In kitchen second clockwise from entry door	WF-01212021-009887	3/5/2021	FT-FY21-022021-009887-A	<1	FT-FY21-022021-009887-B	<1