



# Malcolm X ES Lead Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009888	5/21/2019	5/21/2020	1	Cooler	In multi-purpose room	WF-05212019-009888	11/4/2019	FT-FY20-102019-009888-A	<1	FT-FY20-102019-009888-B	<1
WS- 009889	5/21/2019	5/21/2020	1	Cooler	In health suite	WF-05212019-009889	11/4/2019	FT-FY20-102019-009889-A	<1	FT-FY20-102019-009889-B	<1
WS- 009890	5/21/2019	5/21/2020	1	Break Room	In staff lounge	WF-05212019-009890	11/4/2019	FT-FY20-102019-009890-A	<1	FT-FY20-102019-009890-B	<1
WS- 009891	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to room 109	WF-05212019-009891	11/4/2019	FT-FY20-102019-009891-A	<1	FT-FY20-102019-009891-B	<1
WS- 009892	10/10/2019	10/10/2020	1	Classroom Faucet	In classroom 109	WF-10102019-009892	11/4/2019	FT-FY20-102019-009892-A	<1	FT-FY20-102019-009892-B	<1
WS- 009893	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to room 115	WF-05212019-009893	11/4/2019	FT-FY20-102019-009893-A	<1	FT-FY20-102019-009893-B	<1
WS- 009894	5/21/2019	5/21/2020	1	Cooler	In hallway across from room 132	WF-05212019-009894	11/4/2019	FT-FY20-102019-009894-A	<1	FT-FY20-102019-009894-B	<1
WS- 009895	5/21/2019	5/21/2020	1	Fountain	In classroom 130	WF-05212019-009895	11/4/2019	FT-FY20-102019-009895-A	<1	FT-FY20-102019-009895-B	<1
WS- 009896	10/10/2019	10/10/2020	1	Classroom Faucet	In classroom 130	WF-10102019-009896	11/4/2019	FT-FY20-102019-009896-A	<1	FT-FY20-102019-009896-B	<1
WS- 009897	5/21/2019	5/21/2020	1	Cooler	In classroom 131	WF-05212019-009897	11/4/2019	FT-FY20-102019-009897-A	<1	FT-FY20-102019-009897-B	<1
WS- 009898	10/10/2019	10/10/2020	1	Classroom Faucet	In classroom 131	WF-10102019-009898	11/4/2019	FT-FY20-102019-009898-A	<1	FT-FY20-102019-009898-B	<1
WS- 009900	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to room 208	WF-05212019-009900	11/4/2019	FT-FY20-102019-009900-A	<1	FT-FY20-102019-009900-B	<1
WS- 009901	5/21/2019	5/21/2020	2	Cooler	In hallway across from room 202	WF-05212019-009901	11/4/2019	FT-FY20-102019-009901-A	<1	FT-FY20-102019-009901-B	<1
WS- 009902	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to room 218	WF-05212019-009902	11/4/2019	FT-FY20-102019-009902-A	<1	FT-FY20-102019-009902-B	<1
WS- 009904	5/21/2019	5/21/2020	2	Combo Fountain	In classroom 224	WF-05212019-009904	11/4/2019	FT-FY20-102019-009904-A	<1	FT-FY20-102019-009904-B	<1
WS- 009905	10/10/2019	10/10/2020	2	Combo Faucet	In classroom 225	WF-10102019-009905	11/4/2019	FT-FY20-102019-009905-A	<1	FT-FY20-102019-009905-B	<1
WS- 009906	5/21/2019	5/21/2020	2	Combo Fountain	In classroom 225	WF-05212019-009906	11/4/2019	FT-FY20-102019-009906-A	<1	FT-FY20-102019-009906-B	<1
WS- 009907	5/21/2019	5/21/2020	3	Cooler	In hallway adjacent to room 308	WF-05212019-009907	11/4/2019	FT-FY20-102019-009907-A	<1	FT-FY20-102019-009907-B	<1
WS- 009908	5/21/2019	5/21/2020	3	Cooler	In hallway across from room 303	WF-05212019-009908	11/4/2019	FT-FY20-102019-009908-A	<1	FT-FY20-102019-009908-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009887	7/10/2019	7/10/2020	1	Food Prep Sink	In kitchen second clockwise from entry door	WF-07102019-009887	11/4/2019	FT-FY20-102019-009887-A	<1	FT-FY20-102019-009887-B	<1

## FY20 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009903	10/10/2019	10/10/2020	2	Combo Faucet	In classroom 224	WF-10102019-009903	11/4/2019	FT-FY20-102019-009903-A	45	FT-FY20-102019-009903-B	1.1

## FY20 Filter Test (After Plumbing Check)

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009903	11/6/2019	11/6/2020	2	Combo Faucet	In classroom 224	WF-11062019-009903	11/17/2019	FT-FY20-112019-009903-A	1.1	FT-FY20-112019-009903-B	<1